

SWRCB – DDW – Mendocino District

Microcystin Barrier Index Score
for Drinking Water Treatment
Plants in Clear Lake, CA
October 2018

*Dolichospermum in coagulated and flocculated waters from a jar test
Photograph courtesy of Norm Birdsey from Highlands Mutual Water Company*



Clear Lake Microcystin Barrier Index Score

- Many approaches to reducing microcystins at a water treatment plant; this is a look at a plant's ability to reduce microcystin
- Developed to assist with assessing which public water systems in Clear Lake are potentially vulnerable *if* there was elevated concentrations of microcystin in Clear Lake.
- MC reduction is more complex than this score and dependent on a wide number of factors.
- **Important to recognize that all the Clear Lake treatment plants have microcystin barriers in place**
- July 2018 operating reports were considered in this evaluation; interferences were not considered
- Each treatment plant was reviewed with a representative of the water system
- DDW does continue to recommend cyanotoxin related monitoring for those on sources impacted by cyanobacteria

MC – microcystin


[MC] – concentration of microcystin

Barriers in place while cells are intact

- Coagulation/Flocculation processes – a complex series including chemical additions, mixing energy, time, and floc formation; it's a critical part of water treatment and can remove some intact cyanobacteria cells; however, at times, aerotype algae can wreck havoc on an upflow clarifier or sediment basin.
- Efficient sludge removal – through water treatment, cyanobacteria cells can accumulate and need removing; efficient sludge removal was considered to be either automated or removed every few days. Black sludge is not desired during the algal season.
- Dissolved air floatation – a process that removes low density suspended solids, including algae
- Filter performance – a process that removes particles; points were distributed based on performance in July 2018

Notes on filter factor:

- The performance based portion was loosely based on the graph shown to the right
- With increasing turbidity on a filter run, particle size breakthrough can increase and, with that, potential cell breakthrough



Barriers in place
when dissolve
MC is present in
source water

- *CT achieved for microcystin reductions* or a look at the disinfection process – typical disinfection operations (in July 2018) were evaluated for potential microcystin reductions
- Polishing oxidant – one water treatment plant installed ozone prior to GAC media and after filtration; this is likely a microcystin reduction zone

Other Factors considered

- Recycle water – this process has the potential to introduce dissolved MC into the treatment process
- Source water treatment – no systems have this measure in place but are considering sonication
- Intake factor – can the diversion of raw water be moved to a different depth or location
- Charge analyzer/active jar testing – are there tools in place to optimize the treatment process?
- SedBasin/Clarifier exposed to sun – processes with long detention times and warm waters have the potential to support growth of cyanobacteria
- Aeration at intake – potentially destratify the water column near the intake and deter cyanobacteria growth
- Biological treatment – biodegradation of MC is possible

Other Factors considered continued...

- Alternate Source Not Impacted – having an intertie (or alternate source) is highly desirable; additional credit was awarded to those with alternate sources; +3 for not Clear Lake; +1 for those with interties; less credit awarded to those with interties because if there was a regional MC event, your neighbor could be impacted, too.
- Monitoring for cyanotoxins – this is an important public health barrier
- Monitoring for cyanobacteria – there are a number of tools available, including fluorometers (even one that detects when cells lyse) and cell counts/IDs; this aids systems with treatment adjustments and anticipating operation intensity

Barriers in place
when dissolve
MC is present in
source water

- Granular activated carbon (GAC) – process for the removal of organic compounds, including disinfection byproducts, those producing taste and odor, pesticides, and other synthetic organic compounds. Microcystin can be reduced with GAC media.
- Powdered activated carbon (PAC) – similar to GAC but injected and removed through the sludge process
- Advanced Oxidative Process (AOP) – specifically UV and hydrogen peroxide in this case; “effective at high UV dosages and dependent on initial cyanotoxin concentration, pH, temperature, and presence of NOM”

Microcystin Barrier Index Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

PAC +2

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

SedBasin/Clarifier exposed to sun -2

~~Pre-oxidant +1~~

~~Presence of MC in source water -3~~

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

total

Q1: Credit for aeration in clearwell? NO

Q2: Credit for anthracite in filter media? NO

Q3: What UV dosage degrades MC? HIGH

City of Lakeport – Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +2

2-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar test +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

Golden State WC - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor: depth +3

Charge analyzer/active jar testing +2

SedBasin/Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source +1

Monitoring for toxins +2

Cyanobacteria monitoring +1

Lake Co. North Lakeport - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

18

Clearlake Oaks County Water District – Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +2

2-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor: depth +3

Charge analyzer/active jar test +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

18

Harbor View MWC - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

18

Lucerne Water – Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous summer ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar test +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

17

Clear Water MWC - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

17

Westwind MHP - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3 (could move)

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

16

Lake Co. – Soda Bay CSA 20: Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

PAC +2

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

16

Highlands MWC – Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

15

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1 (@ 2.7 mg/L)

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar test +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source +1

Monitoring for toxins +2

Cyanobacteria monitoring +1

Buckingham Park Water District - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

15

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

Konocti County Water District – Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

14

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar test +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source +1

Monitoring for toxins +2

Cyanobacteria monitoring +1

Mt. Konocti MWC - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

PAC +2

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Intake factor +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

14

Nice MWC - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

PAC +2

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Moveable Intake +2 (600 feet offshore)

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

14

UV radiation: "Effective at degrading microcystin and cylindrospermopsin but at impractically high doses. "

https://www.epa.gov/sites/production/files/2014-08/documents/cyanobacteria_factsheet.pdf

Crescent Bay Improvement Co. – Microcystin Barrier Score

Cells Intact

Coag +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved MC

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Moveable Intake +3 (exploring)

Charge analyzer/active jar test +2 (+1)

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

13

Cache Creek MHP - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

12

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

PAC +2

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Moveable Intake +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

Richmond Park - Microcystin Barrier Score

Cells Intact

Coag/floc +3

DAF +3

Eff. Sludge removal +3

Filter <0.1 NTU 95% +4

<0.3 +3

< 0.5 +2

< 1 +1

Dissolved microcystin

GAC <2 years +3

GAC <5 years +2

GAC >5 years +1

PAC +2

AOP (continuous ops): +3

AOP (interrupted ops >10 days): +1

Contact time achieved for MC red:

3 log reduction for MC +3

2-log reduction for MC +2

1-log reduction for MC +1

Polishing oxidant +2

Other Factors

Recycle water -1

Source water treatment +2

Moveable Intake +3

Charge analyzer/active jar testing +2

Clarifier exposed to sun -2

Aeration at intake +2

Biological treatment +2

Alternate source not impacted +3

Monitoring for toxins +2

Cyanobacteria monitoring +1

11

Ct Table

- Free chlorine, mg/L times detention time, min = [C] x [t]
- Assume pH = 9, [MC-LR] = 50 ug/L, temp = 25 degC, free chlorine = 2 mg/L
- **Need operating contact time of >253 minutes**

Toxin = Microcystin-LR

Oxidant = Free chlorine

Target = 0.3 µg/L

pH	MC-LR conc [µg/L]	Effective CT [mg/L * min]				
		10°C	15°C	20°C	25°C	30°C
6	10	48.8	42.2	36.6	32.0	28.1
	25	61.5	53.2	46.2	40.4	35.4
	50	71.2	61.5	53.5	46.7	41.0
	100	80.8	69.9	60.7	53.0	46.5
7	10	56.9	50.1	44.3	39.5	35.5
	25	71.8	63.1	55.9	49.8	44.7
	50	83.1	73.0	64.7	57.6	51.7
	100	94.3	82.9	73.4	65.5	58.8
8	10	129.8	119.7	111.2	103.9	97.6
	25	163.7	151.0	140.2	131.0	123.1
	50	189.3	174.7	162.2	151.6	142.4
	100	215.0	198.3	184.2	172.1	161.7
9	10	466.6	421.7	382.0	346.8	315.3
	25	588.5	531.9	481.9	437.4	397.7
	50	680.7	615.3	557.4	505.9	460.0
	100	772.9	698.7	632.9	574.5	522.3

Acknowledgements/References

- Clear Lake public water systems – thank you for taking the time to review microcystin barriers in place at your treatment facilities
- EPA representatives, Katie Foreman, Deborah Vacs Renwick and Tom Waters
- *EPA Resources: Water Treatment Optimization for Cyanotoxins, version 1.0, EPA 810-B-16-007, Oct 2017*
 - https://www.epa.gov/sites/production/files/2014-08/documents/cyanobacteria_factsheet.pdf
- *Integrated Design and Operation of Water Treatment Facilities, Susumu Kawamura, 2nd edition*
- *UV support: EPA webinar, May 2014, Westrick presentation*

Contact Amy Little at amy.little@waterboards.ca.gov or (707) 576-2147 if you have additional questions and/or input.