

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

TENTATIVE MONITORING AND REPORTING PROGRAM R5-2024-00XX

FOR
E. & J. GALLO WINERY
TURNER ROAD VINTNERS
SAN JOAQUIN COUNTY

This Monitoring and Reporting Program (MRP) for the Turner Road Vintners Facilities is issued pursuant to Water Code section 13267. A glossary of terms used in this MRP is included on the last page.

All samples shall be representative of the volume and nature of the discharge or matrix of material sampled. Except as specified otherwise in this MRP, grab samples will be considered representative of water, wastewater, soil, residual solids, and groundwater.

The time, date, and location of each sample shall be recorded on the sample chain of custody form. All analyses shall be performed in accordance with the *Standard Provisions and Reporting Requirements for Waste Discharge Requirements*, 1 March 1991 ed. (Standard Provisions and Reporting Requirements [SPRRs]). Field test instruments (such as those used to measure pH, electrical conductivity, dissolved oxygen, wind speed, and precipitation) may be used provided that:

1. The operator is trained in proper use and maintenance of the instruments.
2. The instruments are field calibrated at the frequency recommended by the manufacturer.
3. The instruments are serviced and/or calibrated at the manufacturer's recommended frequency.
4. Field calibration reports are submitted as described in the "Reporting" section of the MRP.

Laboratory analytical procedures shall comply with the methods and holding times specified in the following (as applicable to the medium to be analyzed):

1. Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater (Environmental Protection Agency [EPA]);
2. Test Methods for Evaluating Solid Waste (EPA);
3. Methods for Chemical Analysis of Water and Wastes (EPA);
4. Methods for Determination of Inorganic Substances in Environmental Samples (EPA); Standard Methods for the Examination of Water and Wastewater (APHA/AWWA/WEF); and
5. Soil, Plant and Water Reference Methods for the Western Region (WREP 125).

Approved editions shall be those that are approved for use by the U.S. Environmental Protection Agency or the State Water Resources Control Board’s Environmental Laboratory Accreditation Program (ELAP). The Discharger may propose alternative methods for approval by the Executive Officer. Where technically feasible, laboratory reporting limits shall be lower than concentrations that implement applicable water quality objectives/limits for the constituents to be analyzed.

Source Water Monitoring

Samples of source water used for processing shall be collected beginning in **2025** and analyzed for the parameters listed in the table below. Data shall be reported in the corresponding fourth quarter monitoring report. Samples are required to be collected from the supply wells actively being used during each monitoring period.

MRP Table 1. Source Water Monitoring

Constituent	Units	Sample Type	Sampling and Reporting Frequency
Electrical Conductivity (EC)	µmhos/cm	Grab	Every three years
Total Dissolved Solids (TDS)	mg/L	Grab	Every three years
Total Nitrogen	mg/L	Grab	Every three years
Nitrate as Nitrogen	mg/L	Grab	Every three years
Dissolved Iron	mg/L	Grab	Every three years
Dissolved Manganese	mg/L	Grab	Every three years
Sodium	mg/L	Grab	Every three years
Chloride	mg/L	Grab	Every three years

Effluent Flow Monitoring

The Discharger shall monitor wastewater flows from both wastewater process sumps (TRV West Process Wastewater Sump and TRV East Process Wastewater) from the two flow meter locations shown on Attachment D of Waste Discharge Requirements (WDRs) Order R5-2024-XXXX. The sum of the flows from both meters shall be representative of the total flow to the Advanced Integrated Pond System (AIPS).

MRP Table 2. Flow Volumes

Flow Source	Units	Sample Type	Sampling Frequency	Reporting Frequency
Flow Meter	Gallons	Meter	Daily (total daily flow)	Quarterly

Pond Monitoring (AIPS, Wetland, and Storage Lake)

The Discharger shall monitor the AIPS, Wetland, and Storage Lake when the ponds contain more than one foot of wastewater in accordance with the requirements shown on Tables 3 and 4. Monitoring and sampling shall be conducted from permanent locations that will provide reasonable samples and observations of the AIPS, Wetland, and Storage Lake.

Sample locations **S1** (AIPS), **S2** (Wetland), and **S3** (Storage Lake) are shown on Attachments B and D in WDRs Order R5-2024-XXXX. Sample location **S2** is the compliance point for effluent limits included in WDRs Order R5-2024-XXXX, Performance Based Effluent Limitations D.

Until permanent staff gauges are installed, as required in WDRs Order R5-2024-XXXX (Provision J.1.b), freeboard shall be estimated vertically from the water surface to the lowest elevation of pond berms (or spillway/overflow pipe invert).

Once the gauges have been installed, freeboard shall be measured vertically from the water surface to the lowest elevation of pond berms (or spillway/overflow pipe invert) and measured to the nearest 0.10 feet. Wastewater samples shall be collected at a depth of one foot, opposite the inlet. If any pond is dry or has less than one foot of water, the monitoring report shall state. Monitoring and sampling shall include, at a minimum, the following.

MRP Table 3. AIPS, Wetland, and Storage Lake Monitoring

Constituent/ Parameter	Units	Sample Type	Monitoring Frequency	Reporting Frequency
Presence/Absence of Water	--	Observation	Monthly	Quarterly
Berm Conditions	--	Observation	Monthly	Quarterly
Freeboard	0.1 feet	Measurement	Weekly	Quarterly
Odors	--	Observation	Weekly	Quarterly
Dissolved Oxygen	mg/L	Grab/Measurement	Weekly	Quarterly
pH	--	Measurement	Weekly	Quarterly

MRP Table 4. Sample Locations S1, S2, and S3 Requirements

Constituent/ Parameter	Units	Sample Type	Monitoring Frequency	Reporting Frequency
BOD ₅	mg/L	Grab	Monthly	Quarterly
Total Nitrogen	mg/L	Grab	Monthly	Quarterly
Nitrate as Nitrogen	mg/L	Grab	Monthly	Quarterly
TKN	mg/L	Grab	Monthly	Quarterly
TDS	mg/L	Grab	Monthly	Quarterly
FDS	mg/L	Grab	Monthly	Quarterly
Sulfate	mg/L	Grab	Monthly	Quarterly

Constituent/ Parameter	Units	Sample Type	Monitoring Frequency	Reporting Frequency
EC	µmhos/cm	Grab	Monthly	Quarterly

Land Application Area Monitoring

The Discharger shall inspect the LAAs at least once monthly during irrigation events, and observations from those inspections shall be documented for inclusion in the quarterly monitoring reports. The following items shall be documented:

1. Condition of each standpipe and flow control valve (if applicable)
2. Condition of all ditches used for the conveyance of wastewater (if applicable).
3. Ponding/Standing water
4. Potential and actual runoff or discharge to off-site areas, including surface water
5. Odors that have the potential to be objectionable at or beyond the property boundary.

Temperature, wind direction, and other relevant field conditions shall also be observed and recorded. The notations shall also document any corrective actions taken based on observations made. A copy of entries made in the log shall be submitted as part of the Quarterly Monitoring Report.

Groundwater Monitoring

The Discharger shall maintain the groundwater monitoring well network. If a groundwater monitoring well is dry for more than four consecutive sampling events or is damaged, the Discharger shall submit to the Central Valley Water Board a workplan and proposed time schedule for its replacement, and the well shall be replaced following approval of the workplan. Alternatively, the Discharger shall submit a report with supporting evidence that a replacement well is not needed.

Prior to construction of any additional groundwater monitoring wells, the Discharger shall submit plans and specifications to the Central Valley Water Board for review and approval. Once installed, all new monitoring wells shall be appropriately incorporated into monitoring conducted under this MRP and shall be monitored on a quarterly basis.

The groundwater monitoring program applies to groundwater monitoring wells **MW-1 through MW-5** and any wells subsequently installed under approval of the Central Valley Water Board.

Prior to sampling, depth to groundwater measurements shall be measured in each monitoring well to the nearest 0.01 feet. Groundwater elevations shall then be calculated to determine groundwater gradient and flow direction. Sampling activities shall be conducted in accordance with an approved Sampling and Analysis Plan. Samples shall be collected and analyzed using standard EPA methods. Groundwater

monitoring shall include, at a minimum, the parameters and constituents listed in the table below. Groundwater elevation shall be determined based on depth-to-water measurements using a surveyed measuring point elevation on the well and a surveyed reference elevation. Samples shall be filtered with a 0.45-micron filter, at the laboratory, prior to sample preservation for standard minerals and shall include, at a minimum, dissolved iron, dissolved manganese, chloride, and sodium.

MRP Table 5. Groundwater Monitoring

Constituent	Units	Type of Sample	Sampling Frequency	Reporting Frequency
Depth to Groundwater	0.01 feet	Measurement	Semi-Annually	Annually
Groundwater Elevation	feet	Calculated	Semi-Annually	Annually
Gradient	feet/feet	Calculated	Semi-Annually	Annually
Gradient Direction	degrees	Calculated	Semi-Annually	Annually
EC	µmhos/cm	Grab	Semi-Annually	Annually
TDS	mg/L	Grab	Semi-Annually	Annually
Total Nitrogen	mg/L	Grab	Semi-Annually	Annually
Nitrate Nitrogen	mg/L	Grab	Semi-Annually	Annually
TKN	mg/L	Grab	Semi-Annually	Annually
Standard Minerals (Note 1)	mg/L	Grab	Annually	Annually

Note 1: See the Glossary for the definition of Standard Minerals

If monitoring consistently shows no significant variation in a constituent concentration or parameter after at least eight consecutive groundwater monitoring events, the Discharger may request this MRP be revised to reduce monitoring frequency, constituent analyses, or monitoring parameters. The proposal must include adequate technical justification for a reduction in monitoring frequency. The Discharger shall not implement any changes to this MRP unless and until the Central Valley Water Board adopts, or the Executive Officer issues, a revised MRP.

Solids Monitoring

The Discharger shall monitor volumes of residual solids generated and disposed of and reported in annual monitoring reports:

1. Volume of Solids Generated. Solids may include pomace, seeds, stems, screenings, and sump solids, or other material.
2. Volume Disposed of Off-site. Describe the disposal method (e.g. animal feed, off-site composting, landfill, etc.); the amount disposed (tons); and the name of the hauling company.

Reporting

All regulatory documents, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to centralvalleysacramento@waterboards.ca.gov.

Documents that are 50 MB or larger should be transferred to a CD, DVD, or flash drive and mailed to the following address:

Central Valley Regional Water Quality Control Board
ECM Mailroom
11020 Sun Center Drive, Suite 200
Rancho Cordova, California 95670

To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any correspondence used to transmit documents to this office:

County: San Joaquin
Facility: Turner Road Vintners
Program: Non-15 Compliance
Order Number: R5-2024-00XX
CIWQS Place ID: 266743

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., effluent, pond, etc.), and reported analytical result for each sample are readily discernible. The data shall be summarized in such a manner to clearly illustrate compliance with waste discharge requirements and spatial or temporal trends, as applicable. The results of any monitoring done more frequently than required at the locations specified in the MRP shall be reported to the Central Valley Water Board.

As required by the Business and Professions Code sections 6735, 7835, and 7835.1, all Groundwater Monitoring Reports shall be prepared under the direct supervision of a Registered Professional Engineer or Professional Geologist and signed by the registered professional.

A. Quarterly Monitoring Reports

Daily, weekly, and monthly monitoring data shall be reported in the quarterly monitoring report. Quarterly reports shall be submitted to the Central Valley Water Board on the **1st day of the third month following the quarter** (i.e. the January - March quarterly report is due by 1 June). At a minimum, the report shall include:

1. Results of wastewater monitoring for the AIPS, Wetlands, and Storage Lake in tabular format for each week and month during the reported quarter.

2. Results of Flow Monitoring in tabular format for each month during the reported quarter, including calculated values for the total flow and average daily flow for each month and total annual flow to date.
3. Results of LAA Monitoring.
4. A comparison of monitoring data to the flow limitations, effluent limitations, and discharge specifications and an explanation of any violation of those requirements.
5. Calculated flow-weighted average annual TDS effluent concentration using the following formula:

$$C_a = \frac{\sum_{i=1}^{12} (C_{P_i} \times V_{P_i})}{\sum_{i=1}^{12} (V_{P_i} + V_{S_i})}$$

Where:

- C_a = Flow-weighted average annual TDS concentration in mg/L
- i = the number of the month (e.g., January = 1, February = 2, etc.)
- C_{P_i} = Monthly average process wastewater TDS concentration for calendar month i in mg/L
- V_{P_i} = volume of process wastewater applied to Use Area during calendar month i in million gallons

6. A calibration log verifying calibration of all handheld monitoring instruments and devices used to comply with the prescribed monitoring program; and
7. Copies of the laboratory analytical data reports shall be maintained by the Discharger and submitted to the Central Valley Water Board.

B. Annual Monitoring Reports (Fourth Quarter Monitoring Report)

An Annual Monitoring Report shall be included in the Fourth Quarter Monitoring Report and shall be submitted to the Central Valley Water Board. The Annual Report shall include the following:

Flow Monitoring

1. Total annual flow discharged into the AIPS and determination of compliance with the flow limitation of the WDRs.

Solids Monitoring

1. Summary of the residual solids monitoring, including volumes of residual solids generated and disposed.

Process Supply Water Monitoring

1. Analytical data table showing historical and current results. A narrative description of changes in water quality over time, if any, and the potential impact on the wastewater quality.

Groundwater Monitoring

1. A narrative description of all preparatory, monitoring, sampling, handling, and analytical testing for groundwater monitoring. The narrative shall be sufficiently detailed to verify compliance with the WDRs Order R5-2024-00XX, this MRP, and the SPRRs.
2. A field log for each well documenting depth to groundwater; method of purging, parameters measured before, during, and after purging; sample preparation (e.g., filtering); and sample preservation. Low or no-purge sampling methods are acceptable if described in an approved Sampling and Analysis Plan.
3. Summary data tables of historical and current water table elevations and analytical results, comparison with previous flow direction and gradient data, and discussion of seasonal trends if any.
4. A scaled map showing relevant structures and features of the facility, the locations of monitoring wells and any other sampling stations, and groundwater elevation contours referenced to an appropriate datum (e.g., NGVD).
5. An evaluation of the groundwater quality beneath the site and determination of compliance with the Groundwater Limitations per WDRs Order R5-2024-00XX. Include all calculations and data input/analysis tables derived from use of statistical software, as applicable.
6. Copies of the laboratory analytical data reports shall be maintained by the Discharger and submitted to the Central Valley Water Board.

Additional Reporting

1. A discussion of compliance and the corrective action taken, as well as any planned or proposed actions needed to bring the discharge into full compliance with the WDRs.
2. Monitoring equipment maintenance and calibration records, as described in Section C.4 of the SPRRs, shall be maintained by the Discharger and provided upon request by the Central Valley Water Board.
3. A discussion of the following:

- a. Waste constituent reduction efforts implemented in accordance with any required workplan;
 - b. Other treatment or control measures implemented during the calendar year either voluntarily or pursuant to the WDRs, this MRP, or any other Order; and
 - c. Based on monitoring data, an evaluation of the effectiveness of the treatment or control measures implemented to date.
4. A discussion of any data gaps and potential deficiencies/redundancies in the monitoring network or reporting program.

A letter transmitting the self-monitoring reports shall accompany each report. The letter shall include a discussion of requirement violations found during the reporting period, and actions taken or planned for correcting noted violations, such as operation or facility modifications. If the submitting Discharger has previously submitted a report describing corrective actions and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. The transmittal letter shall contain the penalty of perjury statement by the submitting Discharger, or its authorized agent, as described in Section B.3 of the SPRRs (General Reporting Requirements).

Enforcement

If, in the opinion of the Executive Officer, the Discharger fails to comply with the provisions of this Order, the Executive Officer may refer this matter to the Attorney General for judicial enforcement, may issue a complaint for administrative civil liability, or may take other enforcement actions. Failure to comply with this Order may result in the assessment of Administrative Civil Liability of up to \$1,000 per violation, per day, depending on the violation, pursuant to Water Code section 13268. The Central Valley Water Board reserves the right to take any enforcement actions authorized by law.

Administrative Review

Any person aggrieved by this action of the Central Valley Water Board may petition the State Water Board for administrative review in accordance with Water Code section 13320, and California Code of Regulations, title 23, section 2050 et seq. To be timely, the State Water Board must receive the petition by 5pm on the 30th day after the date of this Order, except that if the 30th day falls on a Saturday, Sunday or State Holiday, the petition must be received by the State Water Board by 5pm on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the Internet on the [Water Boards Public Notice web page](http://www.waterboards.ca.gov/public_notices/petitions/water_quality) (http://www.waterboards.ca.gov/public_notices/petitions/water_quality).

I, PATRICK PULUPA, Executive Officer, do hereby certify the forgoing is a full, true and correct copy of the Monitoring and Reporting Program R5-2024-00XX issued by the California Regional Water Quality Control Board, Central Valley Region, on XX June 2024.

PATRICK PULUPA, Executive Officer

GLOSSARY

AIPS	Advanced Integrated Pond System
BOD ₅	Five-day biochemical oxygen demand
EC	Electrical conductivity at 25° C
EPA	Environmental Protection Agency
FDS	Fixed dissolved solids
gpd	Gallons per day
LAA	Land application area
mgd	Million gallons per day
MRP	Monitoring and Reporting Program
SPRRs	Standard Provisions and Reporting Requirements
TKN	Total Kjeldahl nitrogen
TDS	Total dissolved solids
WDRs	Waste Discharge Requirements
µmhos/cm	Micromhos per centimeter
Daily	Every day except weekends or holidays
Weekly	Once per week
Monthly	Once per calendar month
Quarterly	Once per calendar quarter
Semi-Annual	Twice per calendar year, once during the first quarter (January-March) and once during the third quarter (July-September)
Annually	Once per year
Standard Minerals	Analysis should include: boron, calcium, iron, magnesium, manganese, sulfate, potassium, total alkalinity (including alkalinity series), hardness, and verification that the analysis is complete (i.e., cation/anion balance). Samples shall be filtered with a 0.45-micron filter, at the laboratory, prior to sample preservation.