

ERRATA SHEET
ITEM NO.
SKYLINE RANCH COUNTRY CLUB
RECYCLED WATER PROJECT

The following shall be added to tentative Addendum No. 1 to Order No. R9-2005-0258 as Discharge Specifications 6, 7, 8, 9, and 10.

6. The permeate cycle for the Membrane Bioreactor shall not be greater than the maximum value of 20 minutes and the relax cycle shall not be less than the minimum value of 1 minute during peak dry weather flow.
7. Peak dry weather flow at SRCC shall not exceed a total of 30.0 GPM through the chlorine contact basin.
8. The water level in the chlorine contact basin during peak dry weather flow shall be maintained at a minimum level of 9 feet 6 inches.
9. The chlorine contact basin effluent shall have a minimum chlorine residual of 3.0 mg/L at all times regardless of flow rate.
10. The baffle positions and over/under serpentine flow pattern present at the time of the tracer study shall, at all times, be maintained during the operation of the chlorine contact basin.