



State of California—Health and Human Services Agency
California Department of Public Health



EDMUND G. BROWN JR
Governor

November 13, 2012
Item No. 8
Supporting Document No. 6

October 30, 2012

David W. Gibson, Executive Officer
RWQCB – San Diego Region
9174 Sky Park Court, Ste. 100
San Diego, CA 92123-4340

PADRE DAM MUNICIPAL WATER DISTRICT, SYSTEM NO. 3710037
Consideration of Adoption of Tentative Addendum No. 1 to Order No. 97-49
Reference Number 247351:oosibodu

Dear Mr. Gibson:

On October 09, 2012, the California Department of Public Health (CDPH) received a letter dated October 3, 2012 and a copy of Tentative Addendum No. 1 to Order No. 97-49 (tentative Addendum) from California Regional Water Quality Control Board, San Diego Region. CDPH has reviewed the tentative Addendum and requests a correction be made to item number: f on page 4 which is in conflict with item number: s on page 5, copied below for reference.

f: Each vehicle shall be completely cleaned and disinfected prior to delivery of potable water for human consumption.

s: Vehicles used to transport recycled water shall not be used to carry water for potable purposes, regardless of the source water. The use of recycled water for street sweeping shall comply with the appropriate municipality's storm water ordinance. Typical compliance measures include preventing overspray, ponding, or runoff of recycled water from the use area.


Please be aware that CDPH Food & Drug Branch has regulatory oversight authority for and issues potable water hauling licenses, which does not allow for the hauling of recycled water in a licensed potable water truck. Recycled Water trucks shall not be used or allowed to be used for providing potable water for consumption. CDPH requires separate trucks, hoses, and equipment for recycled water hauling and potable water hauling. Therefore, CDPH requests that item number f be removed from the tentative Addendum No. 1 in order to be consistent with CDPH recycled water use criteria.

Should you have any questions regarding this letter, please contact Tuba Ertas or me at (619) 525-4159.

David Gibson
October 30, 2012

Regional Water Quality Control Board

November 13, 2012
Item No. 8
Supporting Document No. 6

Sincerely,


Sean Sterchi, P.E.
District Engineer

cc: Julie Chan, P.G, Chief, Cleanup and Land Discharge Branch, 9174 Sky Park Court,
Suite 100, San Diego, CA 92123

Mark McPherson, Chief, Land and Water Quality Division, County of San Diego,
Department of Environmental Health

Frank Kowalski, Director of Operations and Water Quality, Padre Dam Municipal Water
District, 9300 Fanita Parkway, Santee, CA 92071