

**CARNEROS INN and L. PEREZ & SONS VINEYARD  
WATER REUSE REQUIREMENTS  
Self-Monitoring Program, Attachment A**

**TABLE 1**

**SCHEDULE FOR SAMPLING, MEASUREMENTS, AND ANALYSIS**

Sampling Station		PE		E-1 & 2 (1)		PW	PP (1)	RP/RU (1)
Type of Sample Parameter,	Units	C	G	C	G	G	Ob	Ob
Flow Rate	(mgd)	X		X				
BOD <sub>5</sub>	(mg/l)		W					
Tot. Susp. Solids	(mg/L)		W					
Total Coliform	(MPN/100ml)		D		2/W			
Turbidity	(NTU)	X						
pH	(units)		D			M		
D.O.	(mg/L)					W		
Standard Observations							W	W (2)

**LEGEND FOR TABLE 1:**

**Types of Samples**

G = grab sample  
C= Continuously Measured  
Ob = Observations

**Frequency of Sampling**

D Once each day  
W Once each week  
2/W Two days per week  
M Once each month  
X Continuously Monitored

**Type of Stations**

PE = Treatment Plant Effluent  
E = Effluent from Recycled Water Storage Ponds 1 & 2  
PW = Recycled Water Pond 1 & 2 analyses  
PP = Recycled Water Pond 1 & 2 Perimeter Observations  
RP = (Producer)/RU (User) = Irrigation Site Observations

Notes:

- (1) Measurements and analyses required only when pond effluent is discharged to the irrigation sites.

The Recycled Water Use Report shall be completed by the User for each month when recycled water is used for vineyard irrigation. The completed report shall be as part of the required SMP.