

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104341  
 REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK  
 MONTH December  
 YEAR 2003

TYPE OF SAMPLE	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD <sub>5</sub>	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.018387						
2	0.019288						
3	0.017433						
4	0.015443						
5	0.018471						
6	0.020851						
7	0.014684						
8	0.017291						
9	0.019721	14	3	6.93			891
10	0.015894						
11	0.020431						
12	0.019513						
13	0.018625						
14	0.016852						
15	0.021521						
16	0.018283						
17	0.017206						
18	0.014984						
19	0.017723						
20	0.020449						
21	0.019569						
22	0.017457						
23	0.015481						
24	0.017329						
25	0.01849						
26	0.017983						
27	0.02058						
28	0.017329						
29	0.016326						
30	0.020753						
31	0.01782						
30-DAY MEAN							
7-DAY MEAN							
MAXIMUM							

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Norderup

RECEIVED

JAN 15 2004

REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104841  
 REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK  
 QUARTER Dec  
 YEAR 2003

TYPE OF SAMPLE	INFLUENT		RECEIVING WATER - R1 (UPSTREAM)			
	20°C BOD <sub>5</sub>	Sus. Solids	DO	Hydrogen Ion	Chlorine	E. Coli
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly
DESCRIPTION	24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mg/L	mg/L	mg/L	pH Units	mg/L	MPN/100mL
REQUIREMENTS						
30-DAY MEAN						
7-DAY MEAN						
MAXIMUM						
DATE OF SAMPLE						
1						
2						
3						
4						
5						
6						
7						
8						
9		300	88	5.8	7.01	
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
QUARTER MEAN						
MAXIMUM						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: \_\_\_\_\_

*R. Anderson*

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK

QUARTER Dec  
 QUARTERLY REPORT

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104841

RECEIVED

JAN 15 2004  
 REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN

REPORTING FREQUENCY: QUARTERLY

YEAR 2003

TYPE OF SAMPLE:	RECEIVING WATER - R2 (DOWNSTREAM)				EFFLUENT	
	DO	Hydrogen Ion	Chlorine	E. Coli	20°C BOD <sub>5</sub>	Sus. Solids
CONSTITUENTS						
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly		
DESCRIPTION	Grab	Grab	Grab	Grab	% Removal	% Removal
UNITS	mg/L	pH Units	mg/L	MPN/100mL		
REQUIREMENTS					85%	85%
30-DAY MEAN						
MINIMUM	5.0	6.0				
MAXIMUM		9.0	0.02	400		
DATE OF SAMPLE						
1						
2						
3						
4						
5						
6						
7						
8						
9	5.3	6.98				
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
QUARTER MEAN						
MAXIMUM						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: *R. Van der... [Handwritten Signature]*

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104841  
 REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK  
 QUARTER \_\_\_\_\_  
 YEAR \_\_\_\_\_

RECEIVED

JAN 15 2004  
 REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN

1. Is there receiving water at Station R-1?

Yes

No

If the answer is no proceed to Station R-2 Section, otherwise continue with the following questions.

PLEASE CIRCLE THE APPROPRIATE ANSWER

Station R-1 Section (The following questions refer to Station R-1)

- 1. Is there the presence of floating or suspended matter present?
- 2. Is there discoloration present?
- 3. Is there aquatic life present?
- 4. Is there visible film, sheen or coating present?
- 5. Is there fungi, slime or objectionable growths present?
- 6. Is there potential nuisance conditions present?

Yes  
 No  
 Yes  
 No  
 Yes  
 No  
 Yes  
 No

No  
 No  
 No  
 No  
 No  
 No

Station R-2 Section (The following questions refer to Station R-2)

- Is there the presence of floating or suspended matter present?
- Is there discoloration present?
- Is there aquatic life present?
- Is there visible film, sheen or coating present?
- Is there fungi, slime or objectionable growths present?
- Is there potential nuisance conditions present?

Yes  
 No  
 Yes  
 No  
 Yes  
 No  
 Yes  
 No

No  
 No  
 No  
 No  
 No  
 No

Any additional comments.

---



---



---



---



---



---

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Vandergast

RECEIVED  
JAN 15 2004  
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAE  
 TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE M4760-1  
 RECEIVED: 12-9-03 1210PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT  
 DATE GARDENS SAMPLED BY: ROD  
 DATE/TIME: 12-9-03  
 TYPE OF SAMPLE: RAW  
 CHLORINE RESIDUE: 0  
 SITE CODE: 1000-1 SAMPLE SITE: UPSTREAM

TOTAL COLIFORM = PRESENCE DILUTION: 1.0, 0.1, 0.01 ML  
 FECAL COLIFORM = PRESENCE  
 E COLI = PRESENCE

ANALYST: LLW/MO COLIFORM=2400/FECAL=230/ECOLI=230/100ML  
 1230PM

DATE START: 12-9-03 TIME START: 1100AM  
 DATE COMPLETED: 12-11-03 TIME COMPLETED: 9221B/E/F  
 DATE REPORTED: 12-12-03 METHOD:

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4760-2  
 TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE  
 RECEIVED: 12-9-03 1210PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:  
 DATE GARDENS SAMPLED BY: ROD  
 DATE/TIME: 12-9-03  
 TYPE OF SAMPLE: RAW  
 CHLORINE RESIDUE: 0  
 SITE CODE 1000-2 SAMPLE SITE: DOWNSTREAM

TOTAL COLIFORM = PRESENCE DILUTION: 1.0, 0.1, 0.01 ML  
 FECAL COLIFORM = PRESENCE  
 E COLI = PRESENCE

ANALYST: LLW/MO COLIFORM=2400/FECAL=130/ECOLI=130/100ML

DATE START: 12-9-03 TIME START: 1230PM  
 DATE COMPLETED: 12-12-03 TIME COMPLETED: 1000AM  
 DATE REPORTED: 12-12-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4809  
 TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE  
 RECEIVED: 12-15-03 1025AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT  
 DATE GARDENS SAMPLED BY: RV  
 DATE/TIME: 12-15-03 810AM  
 TYPE OF SAMPLE: RAW  
 CHLORINE RESIDUE: 0  
 SITE CODE: 21-2 SAMPLE SITE: EFFLUENT  
 DILUTION: 1.0, 0.1, 0.01 ML

TOTAL COLIFORM = PRESENCE  
 FECAL COLIFORM = PRESENCE  
 E COLI = PRESENCE

ANALYST: LLW/MO COLIFORM=16000/FECAL=16000/ECOLI=16000/100ML

RECEIVED

JAN 15 2004  
 REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER

LAB NO:

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

M4761

RECEIVED: 12-9-03 1210PM ANALYSIS:

SAMPLED FROM CLIENT:

DISTRICT

DATE GARDENS MOBILE PARK

SAMPLED BY:

ROD

DATE/TIME:

12-9-03

TYPE OF SAMPLE:

RAW

CHLORINE RESIDUE:

0

SITE CODE: 21-2

SAMPLE SITE:

EFF

DILUTION: 1.0, 0.1, 0.01 ML

TOTAL COLIFORM = PRESENCE

FECAL COLIFORM = ABSENCE

E COLI = ABSENCE

ANALYST: LLW/MO COLIFORM=>220/FECAL=<20/ECOLI=<20/100ML

DATE START: 12-9-03 TIME START: 1230PM

DATE COMPLETED: 12-13-03 TIME COMPLETED: 900AM

DATE REPORTED: 12-18-03 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER

LAB NO: M4809

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 12-16-03 1000AM ANALYSIS:

SAMPLED FROM CLIENT:

DISTRICT:

DATE GARDENS

SAMPLED BY:

ROD

DATE/TIME:

12-16-03 800AM

TYPE OF SAMPLE:

RAW

CHLORINE RESIDUE:

0

SITE CODE 21-2

SAMPLE SITE:

EFFLUENT

DILUTION: 1.0, 0.1, 0.01 ML

TOTAL COLIFORM = PRESENCE

FECAL COLIFORM = PRESENCE

E COLI = PRESENCE

ANALYST: LLW/MO COLIFORM=>16000/FECAL=>16000/ECOLI=>16000/100ML

DATE START: 12-16-03 TIME START: 1030AM

DATE COMPLETED: 12-18-03 TIME COMPLETED: 900AM

DATE REPORTED: 12-18-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

RECEIVED

JAN 15 2004

REGION 7