

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104841  
 REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK

MONTH April  
 YEAR 2007

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD <sub>5</sub>	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Monthly	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	Grab	MPN/100mL	Grab	Grab
REQUIREMENTS				pH UNITS		mg/L	mg/L
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0084						
2	0.0091						
3	0.0094						
4	0.0096				300		
5	0.0098				2		
6	0.0091						
7	0.0087						
8	0.0084						
9	0.0086						
10	0.0080						
11	0.0081	2.5	14.7	7.1	23		
12	0.0080					0	792.0
13	0.0077						
14	0.0074						
15	0.0078						
16	0.0071						
17	0.0071						
18	0.0076						
19	0.0079						
20	0.0089						
21	0.0083						
22	0.0082						
23	0.0097						
24	0.0090						
25	0.0091						
26	0.0098				50		
27	0.0078						
28	0.0063						
29	0.0068						
30	0.0078						
30-DAY MEAN	0.0083	2.5	14.0	7.1	2		
7-DAY MEAN		2.5	14.7	7.1	6	0	792.0
MAXIMUM	0.0098	2.5	14.7	7.1	300	0	792.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Vandenberg

RECEIVED  
 MAY 11 2007  
 REGION 7

**Date Gardens Waste Water Plant**  
1020 West Evan Hewes SP . 41  
Office- (760) 353-0268 / Fax- (760) 353-0268

May 9, 2006

Jose Cortez  
C.R.W.Q.C.B.  
73-720 Fred Waring Drive, Suite 100  
Palm Desert, CA. 92260

Re: April Monthly Self-Monitoring Report.

Mr. Jose Cortez.

Plant operating normally and all effluent limitations were met during the month of April 2007. If you have any further questions don't hesitate to call, please feel free to contact me at your earliest convenience at (760) 427-4235  
Sincerely,



Rocky Vandergriff.  
Chief Operator  
Date Gardens Waste Water Plant

RECEIVED  
MAY 11 2007  
REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
 ORDER NO.: R7-2003-0054  
 NPDES NO.: CA0104841  
 REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM  
 FOR DATE GARDENS MOBILE HOME PARK  
 MONTH April  
 YEAR 2007

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD <sub>5</sub>	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0084						
2	0.0091						
3	0.0094						
4	0.0096				300		
5	0.0098				2		
6	0.0091						
7	0.0087						
8	0.0084						
9	0.0086						
10	0.0080				23		
11	0.0081	2.5	14.7	7.1		0	792.0
12	0.0080						
13	0.0077						
14	0.0074						
15	0.0078						
16	0.0071						
17	0.0071						
18	0.0076						
19	0.0079						
20	0.0089						
21	0.0083						
22	0.0082						
23	0.0097						
24	0.0090						
25	0.0091				50		
26	0.0098						
27	0.0078						
28	0.0063						
29	0.0088						
30	0.0078				2		
30-DAY MEAN	0.0083	2.5	14.0	7.1	6	0	792.0
7-DAY MEAN		2.5	14.7	7.1		0	792.0
MAXIMUM	0.0098	2.5	14.7	7.1	300	0	792.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: \_\_\_\_\_

*Rocky Wardenoff*

RECEIVED  
 MAY 11 2007  
 REGION 7

# Date Gardens Waste Water Plant

1020 West Evan Hewes SP . 41

Office- (760) 353-0268 / Fax- (760) 353-0268

May 9, 2006

Jose Cortez  
C.R.W.Q.C.B.  
73-720 Fred Waring Drive, Suite 100  
Palm Desert, CA. 92260

Re: April Monthly Self-Monitoring Report.

Mr. Jose Cortez.

Plant operating normally and all effluent limitations were met during the month of April 2007. If you have any further questions don't hesitate to call, please feel free to contact me at your earliest convenience at (760) 427-4235

Sincerely,



Rocky Vandergriff.  
Chief Operator  
Date Gardens Waste Water Plant

RECEIVED  
MAY 11 2007  
REGION 7

**Imperial Valley Environmental Laboratory**

501 E. Third Street  
Calexico CA, 92231  
(Tel) 760-357-8764  
(Fax) 760-357-8765  
ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Date Reported: 04-16-07

Contact : Rocky V.

Date Sampled: 04-11-07

Date Received: 04-11-07

Sample Type: Water

Log Number: 1433

Sample ID: Effluent (1433)

**Analytical Results**

Analysis	Effluent	Units	Method	DLR	Analysis Date
BOD	14.7	mg/L	SM 5210B	1	04-16-07
Tot. Suspended Solids	2.5	mg/L	SM 2540D	1	04-13-07
Total Dissolved Solids	792.0	mg/l.	SM 2540C	1	04-13-07
pH	7.11	units	SM 4500HB	1	04-11-07

Miguel E. Ortega, Laboratory Director



## Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1588  
 Sample ID: M1588R  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 04-03-07, 12:30pm  
 Temperature: 6° Celcius

Received by: Patty Hardin  
 Date Received: 04-03-07  
 Time Received: 2:31pm  
 Test Start Time: 2:40pm  
 Chlorine Residual: 0  
 Date Test Ended: 04-05-07  
 Test End Time: 1:21pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
04-05-07	Total Coliform -	MPN by MTF	300	MPN- 100mL. Water
04-05-07	Fecal Coliform -	MPN by MTF	300	MPN- 100mL. Water
04-05-07	E. Coli -	MPN by MTF	300	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



## Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1597  
 Sample ID: M1597R  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 04-04-07, 1:30pm  
 Temperature: 15° Celcius

Received by: Patty Hardin  
 Date Received: 04-04-07  
 Time Received: 3:00pm  
 Test Start Time: 3:10pm  
 Chlorine Residual: 0  
 Date Test Ended: 04-06-07  
 Test End Time: 2:27pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
04-06-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
04-06-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
04-06-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



## Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.


Log Number: M1603  
 Sample ID: M1603R  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 04-10-07, 1:30pm  
 Temperature: 26° Celcius

Received by: Patty Hardin  
 Date Received: 04-10-07  
 Time Received: 2:50pm  
 Test Start Time: 3:00pm  
 Chlorine Residual: 0  
 Date Test Ended: 04-12-07  
 Test End Time: 2:35pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
04-12-07	Total Coliform -	MPN by MTF	50	MPN- 100mL. Water
04-12-07	Fecal Coliform -	MPN by MTF	23	MPN- 100mL. Water
04-12-07	E. Coli -	MPN by MTF	23	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



## Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1634  
 Sample ID: M1634R  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 04-25-07, 9:30am  
 Temperature: 18° Celcius

Received by: Patty Hardin  
 Date Received: 04-25-07  
 Time Received: 11:20am  
 Test Start Time: 11:32am  
 Chlorine Residual: 0  
 Date Test Ended: 04-27-07  
 Test End Time: 11:32am

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
04-27-07	Total Coliform -	MPN by MTF	50	MPN- 100mL. Water
04-27-07	Fecal Coliform -	MPN by MTF	50	MPN- 100mL. Water
04-27-07	E. Coli -	MPN by MTF	50	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director


**Imperial Valley Environmental Laboratory**

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1640  
 Sample ID: M1640R  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 04-30-07, 1:30pm  
 Temperature: 22° Celcius

Received by: Patty Hardin  
 Date Received: 04-30-07  
 Time Received: 2:50pm  
 Test Start Time: 3:00pm  
 Chlorine Residual: 0  
 Date Test Ended: 05-02-07  
 Test End Time: 2:15pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
05-02-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-02-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-02-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director