

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: MONTHLY

**MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK**
MONTH July
YEAR 2007

TYPE OF SAMPLE: EFFLUENT							
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0078						
2	0.0074						
3	0.0070						
4	0.0075						
5	0.0079						
6	0.0077						
7	0.0087						
8	0.0085						
9	0.0087				2		
10	0.0089						
11	0.0086				2		
12	0.0080						
13	0.0058						
14	0.0087						
15	0.0083						
16	0.0080						
17	0.0087				2		
18	0.0084				2		
19	0.0084	1.4	9.4	6.9		0	982.0
20	0.0086						
21	0.0085						
22	0.0087						
23	0.0080						
24	0.0083						
25	0.0082				9		
26	0.0090						
27	0.0093						
28	0.0097						
29	0.0092						
30	0.0096						
31	0.0090						
30-DAY MEAN	0.0084	1.4	9.4	6.9	3	0	982.0
7-DAY MEAN		1.4	9.4	6.9		0	982.0
MAXIMUM	0.0097	1.4	9.4	6.9	9	0	982.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocoy Nandorff

RECEIVED
AUG 16 2007
Page 1 of 2
REGION 7

MONTHLY REPORT



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Contact : Rocky V.

Log Number: 1548

Sample ID: Effluent (1548)

Date Reported: 07-27-07

Date Sampled: 07-19-07

Date Received: 07-19-07

Sample Type: Water

Analytical Results

Analysis	Effluent	Units	Method	DLR	Analysis Date
BOD	9.4	mg/L	SM 5210B	1	07-24-07
Tot. Suspended Solids	1.4	mg/L	SM 2540D	1	07-19-07
Total Dissolved Solids	982.0	mg/L	SM 2540C	1	07-19-07
pH	6.93	units	SM 4500HB	1	07-18-07

Miguel E. Ortega, Laboratory Director

RECEIVED

AUG 1 6 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1769
Sample ID: M1769R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 07-09-07, 10:45am
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 07-09-07
Time Received: 12:55pm
Test Start Time: 1:33pm
Chlorine Residual: 0
Date Test Ended: 07-11-07
Test End Time: 1:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
07-11-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
07-11-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
07-11-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
AUG 16 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1780
Sample ID: M1780R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 07-11-07, 1:40pm
Temperature: 6° Celcius

Received by: Patty Hardin
Date Received: 07-11-07
Time Received: 2:50pm
Test Start Time: 3:20pm
Chlorine Residual: 0
Date Test Ended: 07-13-07
Test End Time: 12:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
07-13-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
07-13-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
07-13-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
AUG 16 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1783
Sample ID: M1783R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 07-17-07, 10:00am
Temperature: 6° Celcius

Received by: Patty Hardin
Date Received: 07-17-07
Time Received: 2:30pm
Test Start Time: 3:10pm
Chlorine Residual: 0
Date Test Ended: 07-19-07
Test End Time: 2:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
07-19-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
07-19-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
07-19-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
AUG 16 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1792
Sample ID: M1792R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 07-18-07, 12:00pm
Temperature: 1° Celcius


Received by: Patty Hardin
Date Received: 07-18-07
Time Received: 3:25pm
Test Start Time: 3:55pm
Chlorine Residual: 0
Date Test Ended: 07-20-07
Test End Time: 2:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
07-20-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
07-20-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
07-20-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
AUG 16 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Seeley WWTP

Contact : Hector O.

Log Number: M1805
Sample ID: M1805R
Sample Site: Effluent Waste Water
Collected by: Hector O.
Date Sampled and Time: 07-25-07, 11:25am
Temperature: 5° Celcius

Received by: Jorge Ortega
Date Received: 07-25-07
Time Received: 12:55pm
Test Start Time: 1:05pm
Chlorine Residual: 0
Date Test Ended: 07-28-07
Test End Time: 12:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
07-28-07	Total Coliform -	MPN by MTF	9	MPN- 100mL. Water
07-28-07	Fecal Coliform -	MPN by MTF	9	MPN- 100mL. Water
07-28-07	E. Coli -	MPN	9	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

AUG 16 2007

REGION 7