

**California-Registered Water Treatment Devices
for Nitrate Reduction as of May 4, 2016.**

- Generally acceptable for treatment of nitrates at levels of less than of no more than 108 mg/l of nitrate (measured as NO₃)
- Water supply pressure of at least 40 psi is required for effective operation.
- Regular testing of the treated water by a State-certified testing laboratory is recommended to verify performance
- Some manufacturers provide a home test kit that can also be used to evaluate the performance. However, periodic laboratory testing is needed to be sure that nitrate is being effectively reduced.

California Registration Number	Manufacturer	Name of Product
1651	Rayne Corporation	Rayne Pure Plus
1780	Ecodyne Water Systems Inc.	Whirlpool WHER 25
1783a	EcoWater Systems, Inc.	EcoWater ERO-375E
1783c	EcoWater Systems, Inc.	EcoWater ERO-375
1814	North Star Water Conditioning	NorthStar NSRO42C4
1836	EcoPure Systems Inc.	EcoPure ECOP30
1783	EcoWater Systems, Inc.	EcoWater ERO375 HERO
1647	General Electric Company	GE RO Filtration System GXR10RBL
1928	Culligan International	Cleer Advanced Drinking Water System with RO30
1944	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30 and TD
1948	Culligan International	Aqua Cleer Advanced Drinking Water System with RO30 and AS3
1949	Culligan International	Aqua Cleer Advanced Drinking Water System with RO30, TD and AS3
1954	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30
1955	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30
1958	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30 and TD
1959	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30 and TD
1960	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30 and AS3
1961	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30 and AS3
1962	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30, TD and AS3
1963	Culligan International	Aqua-Cleer Advanced Drinking Water System with RO30, TD and AS3
2058	Kinetico Incorporated	K-5 Drinking Water Station with VOC/MTBE auxillary cartridge
2070	Kinetico Incorporated	K5 Drinking Water Station
2086	Protect Plus, LLC	Dupont WF-RO60
1836	EcoPure Systems Inc.	EcoPure EP-RO25
2120	RainSoft Division of Aquion Partners L.P.	Ultrefiner II - FMV
3075	Pionetics Corporation	LINX 160
3078	Pionetics Corporation	LCM 160
2202	3M Purification Inc.	4 US-RO-SO1
3029	Clack Corporation	T.F.C.-335
3042	Multipure International	MP750 Plus RO
3085	Pentair Residential Filtration, LLC	Everpure RO
3087	Pentair Residential Filtration, LLC	American Plumber WRO-3500
3089	Pentair Residential Filtration, LLC	Pentek RO-3500
3030	Clack Corporation	T.F.C.-435
3112	Ecodyne Water Systems Inc.	HDGROS4
3125	Rayne Corporation	RAYNEPURE PLUS
3173	Aquasana, Inc	AQ-RO-3
3177	Sink Warehouse, LP	HF-RO
3210	Ecodyne Water Systems Inc.	HCGROSS5
3214	Ecodyne Water Systems	WHAROS5

