

ORDER REQUIRING THE AMERICAN CANYON COUNTY WATER  
DISTRICT, NAPA COUNTY TO CEASE AND DESIST FROM  
DISCHARGING WASTES CONTRARY TO REQUIREMENTS  
PRESCRIBED BY THE CALIFORNIA REGIONAL WATER  
QUALITY CONTROL BOARD, SAN FRANCISCO BAY REGION

ORDER NO. 71-69

The California Regional Water Quality Control Board, San Francisco Bay Region finds:

A. On July 18, 1963 this regional board adopted Resolution No. 480 prescribing discharge requirements covering the discharge of American Canyon County Water District hereinafter referred to as the discharger.

B. The discharge requirements provide, in part, as follows:

"The quality of the waste discharged to the slough shall be maintained within the following limits:

. . . . .

(3) Total suspended matter - 40 mg/l "

. . . . .

<u>"Condition of Effluent Discharge</u>	<u>Requirement</u>
To slough to which public access is limited by a fence or other physical means	MPN of coliform organisms less than 1000 per 100 ml. "

C. Inspection and reports received by board staff and data submitted by the discharger indicate that the discharger is not complying with requirements for:

Effluent total suspended matter and effluent bacterial quality.

D. By letters dated May 24, 1971 and September 14, 1971 the regional board notified the discharger of violations of requirements and requested immediate action to eliminate such violations.

E. On October 21, 1971, after due notice to the discharger and all other affected persons, a hearing panel of the regional board conducted a public hearing at which the discharger appeared and evidence was received concerning the discharge.

F. Upon the basis of the evidence received, the hearing panel recommended that the board issue a cease and desist order against the discharger requiring that it comply with the aforesaid requirements as indicated below.

G. The discharger is violating the requirements listed in "B" above.

IT IS HEREBY ORDERED THAT

- A. American Canyon County Water District, Napa County, cease and desist from discharging wastes contrary to requirements listed in "B" above.
- B. Compliance with the Board's effluent bacterial requirement be completed by December 27, 1971. Compliance with effluent total suspended matter requirement be completed according to the following schedule:

<u>STEP</u>	<u>COMPLETION DATE</u>	<u>STATUS REPORT DATE</u>
Decide whether to participate in the program recommended by "Napa-Vallejo Wastewater Management Study"	December 30, 1971	January 15, 1972
Submit detailed time schedule for compliance with requirement to include the following steps:	January 31, 1972	February 15, 1972
Authorization of funding		
Completion of final design		
Commence Construction		
Complete 50% of Construction		
Compliance with Requirements		

- C. The Regional Board will review this matter at its April 1972 meeting to consider whether a prohibition of discharges to this sewerage system is necessary to prevent further unreasonable impairment of water quality.
- D. The discharger is required to provide to the Board by December 15, 1971 and monthly thereafter a report, under penalty of perjury, on their progress toward compliance with requirements and on new connections and proposed connections to the sewerage system.
- E. If, in the opinion of the Executive Officer, the discharger fails to comply with the provisions of this order, the Executive Officer is directed to request the Attorney General to take the appropriate enforcement action against the discharger, including injunction and civil monetary remedies, if appropriate.

I, Fred H. Dierker, Executive Officer of the California Regional Water Quality Control Board, San Francisco Bay Region, do hereby certify that the foregoing is a full, true, and correct copy of an order adopted by the Regional Board at a meeting held on October 28, 1971.

---

Executive Officer