

---

**Santa Ana Regional Water Quality Control Board**

**November 1, 2013  
Board Meeting**

**UPDATE TO THE AGENDA**

(Prepared 10-31-13)

**The following item has been removed from the calendar:**

- \*7. Appeal of Staff's Denial of an Exemption from the Minimum Lot Size Requirement – Jose Uribe, 2986 N. California Street, San Bernardino, San Bernardino County - APN 0268-211-22  
{Gary Stewart 951/782-4379 [gary.stewart@waterboards.ca.gov](mailto:gary.stewart@waterboards.ca.gov)}

**The following items have been postponed to the December 6, 2013 Board Meeting:**

- \*9. Renewal of Waste Discharge Requirements and National Pollutant Discharge Elimination Permit (NPDES No. CA0105295) for City of Rialto Municipal Wastewater Treatment Plant - Discharge of up to 11.7 mgd of tertiary treated wastewater to the Santa Ana River, Reach 4.  
{Gary Stewart 951/782-4379 [gary.stewart@waterboards.ca.gov](mailto:gary.stewart@waterboards.ca.gov)} Order No. R8-2013-0034
  
- \*10. Renewal of General Waste Discharge Requirements and National Pollutant Discharge Elimination Permit (NPDES No. CA8000383) for Discharges to Surface Waters of Processed Wastewater Associated with Certain Wellhead Treatment Systems - Renewal of waste discharge requirements contained in Order No. R8-2008-0059, as amended by Order No R8-2009-0059.  
(*This item was postponed from the September 13, 2013 meeting.*)  
{Gary Stewart 951/782-4379 [gary.stewart@waterboards.ca.gov](mailto:gary.stewart@waterboards.ca.gov)} Order No. R8-2013-0031

Item No. 8

November 1, 2013

**ERRATA SHEET**

**CHANGES TO TENTATIVE ORDER NO. R8-2013-0016, NPDES No. CA0105350**

**WASTE DISCHARGE AND WATER RECLAMATION REQUIREMENTS  
FOR THE  
CITY OF RIVERSIDE, DEPARTMENT OF PUBLIC WORKS  
RIVERSIDE REGIONAL WATER QUALITY CONTROL PLANT  
RIVERSIDE COUNTY**

(Language deleted is ~~struck through~~)

(Language added is **bold and shaded**)

1. Order No. R8-2013-0016, page 16, modify Effluent Limitation A.1.f., as follows:

f. Total Chlorine Residual:

- 1) The total time during which the total chlorine residual values are above 0.1 mg/L (instantaneous maximum value) shall not exceed 7 hours and 26 minutes in any calendar month;
- 2) No individual excursion above 0.1 mg/L shall exceed 5 **30** minutes; and
- 3) No individual excursion shall exceed 5.0 mg/L.