

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

ORDER NO. 78-12

CITY OF PACIFICA
ORDER GRANTING ADDITIONAL DISCHARGES
TO THE CITY'S SEWER SYSTEM
PURSUANT TO ORDER NO. 76-101

I. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region, finds that:

- A. On December 6, 1974, this Board adopted Order No. 74-166, an NPDES Permit, prescribing waste discharge requirements for the discharge of the City of Pacifica.
- B. On September 21, 1976, this Board adopted Order No. 76-101, a cease and desist order, which prohibited additional discharges to the City's sewer system.
- C. Order No. 76-101 provided for partial removal of the prohibition and allowance of additional discharges to the sewer system upon forthwith achievement and completion of certain specified tasks or additional tasks not specified in the orders and which represent a measure of substantial progress.
- D. On October 19, 1976, November 16, 1976, April 19, 1977, May 17, 1977, July 19, 1977, and October 18, 1977, this Board adopted Orders Nos. 76-112, 76-123, 77-33, 77-52, 77-104, and 77-136, respectively, granting a partial removal of the prohibition on additional discharges to the City's sewer system.
- E. The Environmental Protection Agency, on December 16, 1977, issued a Finding of Violation to the City for violations of chlorine residual and oil and grease effluent limitations.
- F. Consistent compliance with chlorine residual limitation of Order 76-101 has been demonstrated. This represents the achievement and completion of task number 6 as specified in Section D of the cease and desist order.
- G. Compliance with other limitations of Orders Nos. 74-166 and 76-101 has not deteriorated.
- H. On February 21, 1978, the California Regional Water Quality Control Board, San Francisco Bay Region, after due notice, held a public hearing under provisions of Water Code Section 13301 regarding the discharge of waste and pollutants by the City of Pacifica.

II. IT IS HEREBY ORDERED that the prohibition of additional discharges to the sewer system as provided in Order No. 76-101 is partially removed and the City of Pacifica is allowed additional discharges to the sewer system sufficient to serve those proposed projects for which the City has received and processed all documents required by the City for issuance of a building permit prior to February 21, 1978.

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a true, full, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on February 21, 1978.

FRED H. DIERKER
Executive Officer