

**STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL COAST REGION**

**STAFF REPORT FOR REGULAR MEETING OF FEBRUARY 11, 2005**

Prepared on January 7, 2004

**ITEM:** 19

**SUBJECT:** **Waiver of Waste Discharge Requirements for On-Site Domestic Mounded Septic Disposal System, Kimmich Residence, 6990 San Felipe Road, Hollister (APN 015-060-029), San Benito County, Resolution No. R3-2005-0007**

**KEY INFORMATION**

Disposal Type:	Individual on-site domestic septic system with mounded disposal system
Design Flow:	600 gallons per day
Property:	15.65 Acre agricultural/residential
Landowner/Discharger:	Jack Kimmich
Local Oversight Agency:	San Benito County Division of Environmental Health

**DISCUSSION**

On November 8, 2004, Regional Board staff received a Report of Waste Discharge (ROWD): Supplemental Form for Regional Board Subsurface Disposal Exemption Submittal (Supplemental Form) for a proposed on-site domestic mounded septic disposal system at the above-referenced property from the San Benito County Division of Environmental Health (SBCDEH). The SBCDEH determined the site is not suitable for a standard on-site subsurface disposal system and does not meet Basin Plan requirements because of insufficient vertical separation between standard disposal trench bottom and first encountered groundwater. Consequently, SBCDEH is not authorized to issue a permit without an exemption from the Basin Plan prohibition.

Based on information provided in the ROWD, the Executive Officer approved the Basin Plan exemption and notified the Discharger of this proposed waiver of waste discharge requirements on December 8, 2004.

Waste discharge requirements for on-site wastewater disposal system Basin Plan exemptions were formerly waived under Resolution No. 89-04, *Waiver of Regulation of Specific Types of Waste Discharges*. This waiver policy expired June 30, 2004. State Board staff is currently developing state-wide regulations for on-site systems. Once these regulations are in place, Regional Board staff plans on bringing a general waiver of waste discharge requirements to the Regional Board for review and approval. In the meantime, we propose that on-site systems that local agencies can not permit be authorized by individual waivers of waste discharge requirements, provided the Discharger can demonstrate the system poses no threat to water quality.

**System Design.**

The proposed mound system was designed to accommodate shallow groundwater conditions

(approximately 60 inches below the ground surface) at the subject property. The proposed system was conservatively designed for a peak daily flow of 600 gallons per day with a 2,343 square foot (sq ft) mound basal area. An equivalent reserve mound basal area of 2,343 sq ft was also designated on the property. Semiannual inspection of the septic tank, wet well, alarm system, and depth to groundwater monitoring are required for the life of the system. The owner is also required to have the system inspected by a licensed septic tank contractor at least every two years for solids buildup and pump the system as necessary. SBCDEH staff will provide regular inspection and oversight of the sewage disposal system and will monitor the system after all rainfall events resulting in greater than one inch of precipitation.

The proposed mound system design meets applicable portions of the 1980 State Water Resources Control Board *Guidelines for Mound Systems* and 1989 Final Draft California State Water Resources Control Board *Guidelines for the Design, Installation and Operation of Mound Sewage Disposal Systems* with the exception of reductions in the manifold diameter, hole size and dosing volumes which are consistent with the University of Wisconsin's *Pressure Distribution Network Design, Converse, January 2000*. The SBCDEH approved the initial mound system design and forwarded the Supplemental Form to the Regional Board for final review and approval on November 8, 2004. In addition, the San Benito County Environmental Health, Planning & Building, and Engineering Departments all certified the Supplemental Form and recommended conceptual approval of the exemption request.

Mounded disposal system designs have been successfully applied under similar conditions throughout the state since prior to 1980.

### Conditional Waiver

The waiver of waste discharge requirements and discharge of domestic sewage to the proposed on-site mounded disposal system is subject various conditions and monitoring and reporting requirements as specified in the attached waiver resolution.

The proposed on-site domestic mounded septic disposal system, if operated and maintained in accordance with the San Benito County Division of Environmental Health permit requirements and the waiver conditions, will be in the public interest. This waiver is conditional and can be terminated at any time. This waiver expires on February 11, 2010.

### **CALIFORNIA ENVIRONMENTAL QUALITY ACT (CEQA)**

Individual subsurface disposal systems for domestic residences are categorically exempt from CEQA under CEQA Guideline 15303.

### **RECOMMENDATION**

Adopt Resolution No. R3-2005-0007

### **ATTACHMENT**

1. Proposed Resolution No. R3-2005-0007

S:\WDR\Basin Plan Exemptions\San Benito Co\On-Site Septic\6990 San Felipe\WDR waiver SR 111804.doc