



---

## Central Valley Regional Water Quality Control Board

29 January 2025

Dina Breitstein  
District Manager  
17501 Highway 4  
Discovery Bay, CA 94505

VIA EMAIL:  
dbreitstein@todb.ca.gov

### **MINOR MODIFICATIONS TO TOWN OF DISCOVERY BAY COMMUNITY SERVICES DISTRICT DISCOVERY BAY WASTEWATER TREATMENT PLANT, WASTE DISCHARGE REQUIREMENTS ORDER R5-2023-0068 (NPDES PERMIT CA0078590), CONTRA COSTA COUNTY**

Thank you for contacting us regarding a typographical error in the current Waste Discharge Requirements Order R5-2024-0068 (Order) regarding the Total Coliform minimum sampling frequency at sampling location UVS-001 in Table E-7 in Attachment E Section IX.A.1 of the Order.

The current Order lists the minimum sampling frequency for Total Coliform as 1/day. The intention was to carry forward the sampling frequency from the Previous Order (R5-2019-0082) of 3/week into the Order. WDR Attachment F Section VII and Table F-15 describes the monitoring changes from the Previous Order (R5-2019-0082) and the new Order. Total Coliform was not listed among these parameters because the intention was to carry the 3/week mentoring frequency forward to the new Order. This inadvertent mistake in listing the monitoring frequency is a typographical error. Pursuant to Code of Federal Regulations, 40 CFR 122.63(a), a minor modification of an NPDES permit is allowed to correct typographical errors.

1. The following minor modifications are made to Waste Discharge Requirements, Table E-7 in Attachment E Section IX.A.1, of the Order:

**Table E-7. Filtration System and UV Disinfection System Monitoring Requirements**

<b>Parameter</b>	<b>Units</b>	<b>Sample Type</b>	<b>Monitoring Location</b>	<b>Minimum Sampling Frequency</b>
Flow	MGD	Meter	INT-002	Continuous
Turbidity	NTU	Meter	INT-001 and INT-002	Continuous
Number of UV banks in operation	Number	Observation	N/A	Continuous
UV Transmittance	Percent (%)	Meter	INT-002	Continuous
UV Dose	mJ/cm2	Calculated	N/A	Continuous
Total Coliform Organisms	MPN/100 mL	Grab	UVS-001	3/Week

The corrected Order may be downloaded from the Central Valley Water Board's Adopted Orders web page at:

[Adopted / Issued Orders | Central Valley Regional Water Quality Control Board \(ca.gov\)](https://www.waterboards.ca.gov/centralvalley/board_decisions/adopted_orders/)

([https://www.waterboards.ca.gov/centralvalley/board\\_decisions/adopted\\_orders/](https://www.waterboards.ca.gov/centralvalley/board_decisions/adopted_orders/)).

If you have any questions regarding this minor modification, please contact Matt Richter at (916) 464-4745 or [matthew.richter@waterboards.ca.gov](mailto:matthew.richter@waterboards.ca.gov).

Patrick Pulupa  
Executive Officer

cc:

Peter Kozelka, U.S. EPA, Region IX, San Francisco (email only)  
Prasad Gullapalli, U.S. EPA Region IX, San Francisco (email only)  
Xuan Luo, Central Valley Water Board, Rancho Cordova (email only)  
Gregory Harris, HERWIT Engineering (via email)  
Anthony Harper, Veolia (via email)