

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION**

11020 Sun Center Drive, #200 Rancho Cordova, California 95670-6114  
Phone (916) 464-3291 ○ Fax (916) 464-4645  
[Central Valley Home Page](http://www.waterboards.ca.gov/centralvalley) (<http://www.waterboards.ca.gov/centralvalley>)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) CA0079651  
ORDER R5-2022-0070**

**WASTE DISCHARGE REQUIREMENTS  
FOR LINDA COUNTY WATER DISTRICT, WASTEWATER TREATMENT PLANT, YUBA  
COUNTY AND SUTTER COUNTY**

The following Discharger is subject to waste discharge requirements (WDRs) set forth in this Order:

**Table 1. Discharger Information**

Discharger:	Linda County Water District
Name of Facility:	Wastewater Treatment Plant
Facility Street Address:	909 Myrna Avenue
Facility City, State, Zip:	Marysville, CA 95901
Facility County:	Yuba County and Sutter County

**Table 2. Discharge Location**

Discharge Point	Effluent Description	Discharge Point Latitude (North)	Discharge Point Longitude (West)	Receiving Water
001	Treated Municipal Wastewater	39° 05' 42"	121° 35' 32"	Feather River
002	Treated Municipal Wastewater	39° 05' 42"	121° 35' 20"	Feather River, via evaporation/ percolation ponds within floodplain

**Table 3. Administrative Information**

This Order was Adopted on:	<b>8 December 2022</b>
This Order shall become effective on:	<b>1 February 2023</b>
This Order shall expire on:	<b>31 January 2028</b>
The Discharger shall file a Report of Waste Discharge (ROWD) as an application for reissuance of WDRs in accordance with title 23, California Code of Regulations (CCR), and an application for reissuance of a NPDES permit no later than:	<b>31 January 2027</b>
The United States Environmental Protection Agency (U.S. EPA) and the California Regional Water Quality Control Board, Central Valley Region have classified this discharge as follows:	<b>Major Discharge</b>

I, Patrick Pulupa, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on **8 December 2022**.

\_\_\_\_\_  
**PATRICK PULUPA**, Executive Officer

**WASTE DISCHARGE REQUIREMENTS  
TABLE OF CONTENTS**

I.	Facility Information .....	3
II.	Findings.....	3
III.	Discharge Prohibitions.....	4
IV.	Effluent Limitations and Discharge Specifications .....	5
	A. Effluent Limitations – Discharge Points 001 and 002.....	5
	1. Final Effluent Limitations – Discharge Points 001 and 002.....	5
V.	Receiving Water Limitations .....	6
	A. Surface Water Limitations.....	6
	B. Groundwater Limitations .....	9
VI.	Provisions.....	9
	A. Standard Provisions.....	9
	B. Monitoring and Reporting Program (MRP) Requirements .....	14
	C. Special Provisions.....	14
	1. Reopener Provisions.....	14
	2. Special Studies, Technical Reports and Additional Monitoring Requirements .....	15
	3. Best Management Practices and Pollution Prevention .....	18
	4. Construction, Operation and Maintenance Specifications.....	19
	5. Special Provisions for Publicly-Owned Treatment Works (POTWs) .....	20
	6. Other Special Provisions.....	22
	7. Compliance Schedules – Not Applicable .....	22
VII.	Compliance Determination .....	22

**TABLES**

Table 1.	Discharger Information .....	1
Table 2.	Discharge Location .....	1
Table 3.	Administrative Information .....	1
Table 4.	Effluent Limitations .....	5

**ATTACHMENTS**

Attachment A –	Definitions .....	A-1
Attachment B –	Map .....	B-1
Attachment C –	Figures .....	C-1
Attachment D –	Standard Provisions.....	D-1
Attachment E –	Monitoring and Reporting Program .....	E-1
Attachment F –	Fact Sheet.....	F-1
Attachment G –	Summary Of Reasonable Potential Analysis .....	G-1
Attachment H –	Calculation of WQBELS .....	H-1

## I. FACILITY INFORMATION

Information describing the Linda County Water District, Wastewater Treatment Plant (Facility) is summarized in Table 1 and in sections I and II of the Fact Sheet (Attachment F). Section I of the Fact Sheet also includes information regarding the Facility's permit application.

## II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Central Valley Water Board), finds:

- A. Legal Authorities.** This Order serves as waste discharge requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the California Water Code (commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. EPA and chapter 5.5, division 7 of the Water Code (commencing with section 13370). It shall serve as a National Pollutant Discharge Elimination System (NPDES) permit authorizing the Discharger to discharge into waters of the United States at the discharge location described in Table 2 subject to the WDRs in this Order.
- B. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA, (commencing with section 21100) of Division 13 of Public Resources Code. Additionally, the adoption of Title 22 water reclamation requirements for the Facility constituents permitting of an existing facility that is categorically exempt from the provisions of CEQA pursuant to CCR, title 14, section 15301.
- C. Background and Rationale for Requirements.** The Central Valley Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for the requirements in this Order, is hereby incorporated into and constitutes Findings for this Order. Attachments A through E and G through H are also incorporated into this Order.
- D. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections **V.B** are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- E. Monitoring and Reporting.** 40 C.F.R. section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Central Valley Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This Order and the Monitoring and Reporting Program, provided in Attachment E, establish monitoring and reporting requirements to implement federal and State requirements. The burden, including costs, of these monitoring and reporting

requirements bears a reasonable relationship to the need for these reports and the benefits to be obtained therefrom. The Discharger, as owner and operator of the Facility, is responsible for these requirements, which are necessary to determine compliance with this Order. The need for these requirements is further discussed in the Fact Sheet, Attachment F.

- F. Notification of Interested Persons.** The Central Valley Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of the notification are provided in the Fact Sheet.
- G. Consideration of Public Comment.** The Central Valley Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

THEREFORE, IT IS HEREBY ORDERED that Order R5-2017-0094-01 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order. This action in no way prevents the Central Valley Water Board from taking enforcement action for violations of the previous Order.

### III. DISCHARGE PROHIBITIONS

- A.** Discharge of wastewater from the Facility, as the Facility is specifically described in the Fact Sheet in section II.B, in a manner different from that described in this Order is prohibited.
- B.** The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C.** Neither the discharge nor its treatment shall create a nuisance as defined in section 13050 of the Water Code.
- D.** Discharge of waste classified as 'hazardous', as defined in the CCR, title 22, section 66261.1 et seq., is prohibited.
- E. Average Dry Weather Flow.** Discharges from both Discharge Points 001 and 002 in total combination exceeding an average dry weather flow of 5.0 million gallons per day (MGD) are prohibited.

**IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

**A. Effluent Limitations – Discharge Points 001 and 002**

**1. Final Effluent Limitations – Discharge Points 001 and 002**

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 001 (Feather River), with compliance measured at Monitoring Location EFF-001, and at Discharge Point 002 (evaporation/percolation ponds), with compliance measured at Monitoring Location EFF-002, as described in the Monitoring and Reporting Program, Attachment E. EFF-001 and EFF-002 are the same monitoring location; therefore, they will be referenced as EFF-001/EFF-002 throughout this Order.

- a. The Discharger shall maintain compliance with the effluent limitations specified in Table 4:

**Table 4. Effluent Limitations**

Parameters	Units	Average Monthly	Average Weekly	Maximum Daily
Biochemical Oxygen Demand, 5-day @ 20°Celsius (BOD <sub>5</sub> )	milligrams per liter (mg/L)	10	15	--
Total Suspended Solids (TSS)	mg/L	10	15	--
Chlorodibromomethane	µg/L	18	--	36
Dichlorobromomethane	µg/L	38	--	70
Ammonia Nitrogen, Total (as N)	mg/L	2.9	5.2	--
Nitrate Plus Nitrite (as N)	mg/L	10	17	--

- b. **pH:**
  - i. 6.0 Standard Units (SU) as an instantaneous minimum for discharges to Discharge Point 002.
  - ii. 6.5 SU as an instantaneous minimum for discharges to Discharge Point 001.
  - iii. 8.5 SU as an instantaneous maximum.
- c. **Percent Removal.** The average monthly percent removal of BOD<sub>5</sub> and TSS shall not be less than 85 percent.
- d. **Acute Whole Effluent Toxicity.** At Discharge Point 001 survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

- i. 70%, minimum for any one bioassay; and
- ii. 90%, median for any three consecutive bioassays.
- e. **Total Residual Chlorine.** At Discharge Point 001 effluent total residual chlorine shall not exceed:
  - i. 0.011 mg/L, as a 4-day average; and
  - ii. 0.019 mg/L, as a 1-hour average.
- f. **Total Coliform Organisms.** Effluent total coliform organisms shall not exceed:
  - i. 2.2 most probable number per 100 milliliters (MPN/100 mL), as a 7-day median;
  - ii. 23 MPN/100 mL, more than once in any 30-day period; and
  - iii. 240 MPN/100 mL, at any time.
- g. **Mercury, Total.** For a calendar year, the total annual mass discharge of total mercury shall not exceed **0.46** pounds/year.
- h. **Diazinon and Chlorpyrifos.** Effluent diazinon and chlorpyrifos concentrations shall not exceed the sum of one (1.0) as identified below:
  - i. Average Monthly Effluent Limitation (AMEL)  
$$\text{SAMEL} = \text{CD M-avg}/0.079 + \text{CC M-avg}/0.012 \leq 1.0$$

CD M-AVG = average monthly diazinon effluent concentration in  $\mu\text{g/L}$ .  
CC M-AVG = average monthly chlorpyrifos effluent concentration in  $\mu\text{g/L}$
  - ii. Average Weekly Effluent Limitation (AWEL)  
$$\text{SAWEL} = \text{CD W-avg}/0.14 + \text{CC W-avg}/0.021 \leq 1.0$$

CD W-AVG = average weekly diazinon effluent concentration in  $\mu\text{g/L}$ .  
CC W-AVG = average weekly chlorpyrifos effluent concentration in  $\mu\text{g/L}$ .

## V. RECEIVING WATER LIMITATIONS

### A. Surface Water Limitations

The discharge shall not cause the following in the Feather River when discharging to Discharge Point 001:

1. **Biostimulatory Substances.** Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
2. **Chemical Constituents.** Chemical constituents to be present in concentrations that adversely affect beneficial uses.
3. **Color.** Discoloration that causes nuisance or adversely affects beneficial uses.
4. **Dissolved Oxygen:**
  - a. The monthly median of the mean daily dissolved oxygen concentration to fall below 85 percent of saturation in the main water.
  - b. The 95-percentile dissolved oxygen concentration to fall below 75 percent of saturation; nor
  - c. The dissolved oxygen concentration to be reduced below 7.0 mg/L at any time.
5. **Floating Material.** Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
6. **Oil and Grease.** Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
7. **pH.** The pH to be depressed below 6.5 nor raised above 8.5.
8. **Pesticides:**
  - a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
  - b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;
  - c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by U.S. EPA or the Executive Officer;
  - d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR section 131.12.);
  - e. Pesticide concentrations to exceed the lowest levels technically and economically achievable;

- f. Pesticides to be present in concentration in excess of the maximum contaminant levels (MCLs) set forth in CCR, Title 22, division 4, chapter 15; nor
- g. Thiobencarb to be present in excess of 1.0 µg/L.

**9. Radioactivity:**

- a. Radionuclides to be present in concentrations that are harmful to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life; nor
- b. Radionuclides to be present in excess of the MCLs specified in Table 64442 of section 64442 and Table 64443 of section 64443 of Title 22 of the CCR.

**10. Electrical Conductivity.** Electrical conductivity to exceed 150 µmhos/cm as a 90th percentile in well-mixed waters of the Feather River.

**11. Suspended Sediments.** The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.

**12. Settleable Substances.** Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.

**13. Suspended Material.** Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.

**14. Taste and Odors.** Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.

**15. Temperature.** The natural temperature to be increased by more than 5° Fahrenheit. Compliance to be determined based on the difference in temperature at Monitoring Locations RSW-001 and RSW-002.

**16. Toxicity.** Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.

**17. Turbidity.**

- a. Shall not exceed 2 Nephelometric Turbidity Units (NTU) where natural turbidity is less than 1 NTU;

- b. Shall not increase more than 1 NTU where natural turbidity is between 1 and 5 NTUs;
- c. Shall not increase more than 20 percent where natural turbidity is between 5 and 50 NTUs;
- d. Shall not increase more than 10 NTU where natural turbidity is between 50 and 100 NTUs; nor
- e. Shall not increase more than 10 percent where natural turbidity is greater than 100 NTUs.

**B. Groundwater Limitations**

Release of waste constituents from any storage, treatment, or disposal component associated with the Facility shall not cause the underlying groundwater to contain waste constituents in concentrations greater than background water quality or applicable water quality objectives, whichever is greater.

**VI. PROVISIONS**

**A. Standard Provisions**

- 1. The Discharger shall comply with all Standard Provisions included in Attachment D.
- 2. The Discharger shall comply with the following provisions. In the event that there is any conflict, duplication, or overlap between provisions specified by this Order, the more stringent provision shall apply:
  - a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, CCR, division 3, chapter 26.
  - b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
    - i. violation of any term or condition contained in this Order;
    - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
    - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
    - iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- i. New regulations. New regulations have been promulgated under section 405(d) of the CWA, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- ii. Land application plans. When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- iii. Change in sludge use or disposal practice. Under 40 CFR section 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Central Valley Water Board may review and revise this Order at any time upon application of any affected person or the Central Valley Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Central Valley Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
  - i. Contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
  - ii. Controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by U.S. EPA under section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- i. Safeguard to electric power failure:
  - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
  - ii. Upon written request by the Central Valley Water Board, the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past 5 years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Central Valley Water Board.
  - iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Central Valley Water Board not approve the existing safeguards, the Discharger shall, within 90 days of having been advised in writing by the Central Valley Water Board that the existing safeguards are inadequate, provide to the Central Valley Water Board and U.S. EPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Central Valley Water Board, become a condition of this Order.

- j. The Discharger, upon written request of the Central Valley Water Board, shall file with the Board a technical report on its preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. This report may be combined with that required under the Central Valley Water Board Standard Provision contained in section VI.A.2.i of this Order.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Central Valley Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- k. A publicly owned treatment works whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment and disposal facilities. The projections shall be made in January, based on the last 3 years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in 4 years, the Discharger shall notify the Central Valley Water Board by 31 January. A copy of the notification shall be sent to appropriate local elected officials, local permitting agencies and the press. Within 120 days of the notification, the Discharger shall submit a technical report showing how it will prevent flow volumes from exceeding capacity or how it will increase capacity to handle the larger flows. The Central Valley Water Board may extend the time for submitting the report.
- l. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required

by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.

- m. The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.
- n. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Central Valley Water Board.
- o. This Order may be reopened to transfer ownership of control of this Order. The succeeding owner or operator must apply in writing requesting transfer of the Order. The request must contain the requesting entity's full legal name, the state of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Central Valley Water Board, and a statement. The statement shall comply with the signatory and certification requirements in the federal Standard Provisions (Attachment D, section V.B) and state that the new owner or operator assumes full responsibility for compliance with this Order.
- p. If the Discharger submits a timely and complete Report of Waste Discharge for permit reissuance, this permit shall continue in force and effect until the permit is reissued or the Regional Water Board rescinds the permit.
- q. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- r. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, effluent limitation, or receiving water limitation of this Order, the Discharger shall notify the Central Valley Water Board by telephone (916) 464-3291 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Central Valley Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy the current noncompliance and prevent recurrence including, where applicable, a schedule of implementation. Other noncompliance requires written notification as above at the time of the normal monitoring report.

## **B. Monitoring and Reporting Program (MRP) Requirements**

The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E.

## **C. Special Provisions**

### **1. Reopener Provisions**

- a. Conditions that necessitate a major modification of a permit are described in 40 CFR section 122.62, including, but not limited to:
  - i. If new or amended applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, this permit may be reopened and modified in accordance with the new or amended standards.
  - ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. **Mercury.** If mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted, this Order shall be reopened, and the mass effluent limitation modified (higher or lower) or an effluent concentration limitation imposed. If the Central Valley Water Board determines that a mercury offset program is feasible for Dischargers subject to a NPDES permit, then this Order may be reopened to reevaluate the mercury mass loading limitation(s) and the need for a mercury offset program for the Discharger.
- d. **Whole Effluent Toxicity.** If after review of new data and information, it is determined that the discharge has reasonable potential to cause or contribute to an instream exceedance of the Statewide Toxicity Provisions numeric chronic aquatic toxicity objective and Basin Plan's narrative toxicity objective this Order may be reopened and effluent limitations added for acute and/or chronic toxicity.
- e. **Water Effects Ratios (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating criteria for applicable inorganic constituents. In addition, default dissolved-to-total metal

translators have been used to convert water quality objectives from dissolved to total recoverable. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.

- f. **Central Valley Salinity Alternatives for Long-Term Sustainability (CV-SALTS).** On 17 January 2020, certain Basin Plan Amendments to incorporate new strategies for addressing ongoing salt and nitrate accumulation in the Central Valley became effective. Other provisions subject to U.S. EPA approval became effective on 2 November 2020, when approved by U.S. EPA. As the Central Valley Water Board moves forward to implement those provisions that are now in effect, this Order may be amended or modified to incorporate new or modified requirements necessary for implementation of the Basin Plan Amendments. More information regarding these Amendments can be found on the [Central Valley Salinity Alternatives for Long-Term Sustainability \(CV-SALTS\) web page:](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/)  
([https://www.waterboards.ca.gov/centralvalley/water\\_issues/salinity/](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/))
- g. **Facility Expansion to 6.7 MGD.** The Discharger may request an expansion of allowable flows to be discharged to the Feather River to accommodate flows associated with the regionalization project with the City of Marysville. If the following conditions are met, this Order may be reopened to revise the applicable average dry weather flow prohibition to 6.7 MGD:
  - i. **Effluent and Receiving Water Limitation Compliance.** The Discharger shall demonstrate compliance with the effluent limitations and receiving water limitations contained in sections IV.A.2 and V.A, respectively, of this Order.
  - ii. **Facility Expansion.** The Discharger shall have completed construction of an expansion project, that results in a design treatment capacity of 6.7 MGD ADWF.
  - iii. **Request for Increase.** The Discharger shall submit to the Central Valley Water Board a request for an increase in the permitted discharge flow rate, which demonstrates compliance with items (a) and (b) of this provision.

## 2. **Special Studies, Technical Reports and Additional Monitoring Requirements**

- a. **Toxicity Reduction Evaluation Requirements.** This Provision requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate, effluent toxicity. If the discharge exceeds the chronic toxicity thresholds defined in this Provision, the Discharger is

required to initiate a Toxicity Reduction Evaluation (TRE) in accordance with an approved TRE Work Plan and take actions to mitigate the impact of the discharge and prevent recurrence of toxicity. A TRE is a site-specific study conducted in a stepwise process to identify the source(s) of toxicity and the effective control measures for effluent toxicity. TREs are designed to identify the causative agents and sources of whole effluent toxicity, evaluate the effectiveness of the toxicity control options, and confirm the reduction in effluent toxicity. Alternatively, under certain conditions as described in this provision below, the Discharger may participate in an approved Toxicity Evaluation Study (TES) in lieu of conducting a site-specific TRE.

- i. **Numeric Toxicity Monitoring Trigger.** The numeric Toxicity Unit (TUc) monitoring trigger is 12 TUc (where TUc = 100/NOEC). The monitoring trigger is not an effluent limitation; it is the toxicity threshold above which the Discharger is required to initiate additional actions to evaluate effluent toxicity as specified in subsection ii, below.
- ii. **Chronic Toxicity Effluent Trigger Exceeded.** When a chronic whole effluent toxicity result during routine monitoring exceeds the chronic toxicity effluent trigger, the Discharger shall proceed as follows:
  - (a) **Initial Toxicity Check.** If the the percent effect is less than 25 percent at 8.3 percent effluent, check for any operation or sample collection issues and return to routine chronic toxicity monitoring. Otherwise, proceed to step (b).
  - (b) **Evaluate 6-week Median.** The Discharger may take two additional samples within 6 weeks of the initial routine sampling event exceeding the chronic toxicity numeric trigger to evaluate the 6-week median. If the 6-week median is greater than 12 TUc (as 100/EC25) and the percent effect is greater than 25 percent at 8.3percent effluent, proceed with subsection (c). Otherwise, the Discharger shall check for any operation or sample collection issues and return to routine chronic toxicity monitoring. See Compliance Determination Section VII.H for procedures for calculating 6-week median.
  - (c) **Toxicity Source Easily Identified.** If the source(s) of the toxicity is easily identified (e.g., temporary plant upset), the Discharger shall make necessary corrections to the facility and shall resume routine chronic toxicity monitoring; If the source of toxicity is not easily identified the Discharger shall conduct a site-specific TRE as described in the following subsections.
  - (d) **Toxicity Reduction Evaluation.** The Discharger shall initiate a site-specific TRE as follows:

- (i) **Within thirty (30) days** of exceeding the chronic toxicity numeric trigger, the Discharger shall submit a TRE Action Plan to the Central Valley Water Board including, at minimum:
    - Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including a TRE WET monitoring schedule;
    - Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
    - A schedule for these actions.
- b. **Pretreatment Program Submittal Requirements.** The Discharger shall develop and submit a POTW Pretreatment Program as specified in 40 C.F.R. 403 to the Central Valley Water Board for approval as directed in the Technical Reports Table of the MRP (Attachment E).
- c. **Most Sensitive Species Screening Study.** The Discharger shall perform screening to evaluate the most sensitive species. The species sensitivity screening shall be conducted as follows and the results submitted with the Report of Waste Discharge on the date provided in the Technical Reports Table of the MRP (Attachment E).
  - i. *Frequency of Testing for Most Species Sensitivity Screening Study.* Species sensitivity screening for chronic toxicity shall include, at a minimum, chronic WET testing **quarterly** between **1 January 2026 and 31 December 2026** when discharging to either **Discharge Point 001 or 002** using the water flea (*Ceriodaphnia dubia*), fathead minnow (*Pimephales promelas*), and green alga (*Pseudokirchneriella subcapitata*). The tests shall be performed at an IWC of no less than 8.3 percent effluent and be used for future determination of the most sensitive species at the time of permit renewal.
  - ii. *Determination of Most Sensitive Species.* If a single test in the species sensitivity screening testing results in a “Fail” using the TST statistical approach, then the species used in that test shall be established as the most sensitive species. If there is more than a single test that results in a “Fail”, then of the species with results of a “Fail”, the species that exhibits the highest percent effect shall be established as the most sensitive species. If none of the tests in the species sensitivity screening results in a “Fail”, but at least one of the species exhibits a percent effect greater than **10** percent, then the single species that exhibits the highest percent effect shall be established as the most sensitive species. Otherwise, if the most sensitive species is indeterminate then the Discharger can request an annual rotating schedule of the three species.

- d. **Groundwater Monitoring Well Study.** The Discharger shall conduct an assessment of the current groundwater monitoring well network to determine if the current well network is adequate for determining compliance with groundwater limitations, including establishment of background concentrations, and determining groundwater gradients. The Discharger must submit the Groundwater Monitoring Well Study to the Central Valley Water Board with the Report of Waste Discharge on the date provided in the Technical Reports Table of the MRP (Attachment E). If the Discharger determines there is a need to install new groundwater monitoring wells, then the Discharger shall include a summary of the purpose of the relocation, a project schedule, a detail map of the location of the proposed new wells, a work plan for developing the new wells, and if necessary a closure plan for decommissioning of the existing wells, as part of the Groundwater Monitoring Well Study.

### 3. **Best Management Practices and Pollution Prevention**

- a. **Salinity Evaluation and Minimization Plan (SEMP).** The Discharger shall continue to implement a SEMP to identify and address sources of salinity discharged from the Facility. The Discharger submitted a Notice of Intent to comply with the Salt Control Program and selected the Alternative Permitting Approach. Accordingly, the Discharger shall participate in the CV-SALTS Prioritization and Optimization (P&O) Study. Furthermore, an evaluation of the effectiveness of the SEMP shall be submitted with the ROWD. The evaluation shall include, at minimum, the calendar annual average concentrations of effluent electrical conductivity during the term of the Order. If the average electrical conductivity concentration for any calendar year exceeds a performance-based **trigger of 1,000 µmhos/cm**, the Discharger shall evaluate possible sources of salinity contributing to the exceedance of the trigger and update the SEMP to include a plan of action to control salinity.
- b. **Facility Performance Triggers for Chlorodibromomethane, and Dichlorobromomethane.** This Order retains the application of dilution credits and contains performance-based final effluent limitations for chlorodibromomethane and dichlorobromomethane. The dilution credits applied are significantly below the assimilative capacity of the receiving water however, the Discharger must maintain at least the current level of performance for the Facility. Therefore, this Order includes performance-based triggers for chlorodibromomethane, and dichlorobromomethane (see section IV.C.2.c.iii.(I) of the Fact Sheet). If the concentration for any of these constituents exceeds the trigger listed in Table F-9 over a 12-month period beginning on the 1st of the calendar year and the exceedances demonstrate a consistent increasing trend, the Discharger shall perform a study to determine the cause of the increase in the effluent concentration of the constituent(s). In the case where uncontrollable

factors are documented as responsible for the increasing trend, a study is not required.

#### 4. **Construction, Operation and Maintenance Specifications**

- a. **Filtration System Operating Specifications.** To ensure the filtration system is operating properly to provide adequate disinfection of the wastewater, the turbidity of the filter effluent measured at Monitoring Location FIL-001 shall not exceed:
  - i. 2 NTU as a daily average;
  - ii. 5 NTU more than 5 percent of the time within a 24-hour period; and
  - iii. 10 NTU, at any time.
- b. With the exception of the percolation ponds located within the Feather River levees, the treatment, storage, and disposal facilities shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
- c. **Percolation Pond Operating Requirements.**
  - i. Objectionable odors originating at the Facility shall not be perceived beyond the limits of the wastewater treatment and disposal areas.
  - ii. As a means of discerning compliance with section VI.C.4.c.i, the dissolved oxygen content in the upper one foot of the percolation ponds shall not be less than 1.0 mg/L for three consecutive sampling events.
  - iii. Ponds shall be managed to prevent breeding of mosquitos. In particular,
    - (a) An erosion control program should assure that small coves and irregularities are not created around the perimeter of the water surface.
    - (b) Weeds shall be minimized.
    - (c) Dead algae, vegetation, and debris shall not accumulate on the water surface.
  - iv. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.
  - v. Ponds shall have a minimum of 2 feet of freeboard (measured vertically to the lowest, non-spillway point of overflow) and sufficient capacity to accommodate allowable wastewater flow and design

seasonal precipitation and ancillary inflow and infiltration except for ponds located within the Feather River levees when inundated with river water.

d. **Storm Water Detention Basin Operating Requirements.**

- i. The discharge of storm water to detention basins shall not cause or contribute to violations of groundwater limitations included in section V.B. of this Order.
- ii. Storm water detention basins shall be managed to prevent breeding of mosquitoes. In particular,
  - (a) An erosion control program should assure that small coves and irregularities are not created around the perimeter of the water surface.
  - (b) Weeds shall be minimized.
  - (c) Dead algae, vegetation, and debris shall not accumulate on the water surface.

**5. Special Provisions for Publicly-Owned Treatment Works (POTWs)**

a. **Pretreatment Requirements**

- i. The Discharger shall be responsible and liable for the performance of all Control Authority pretreatment requirements contained in 40 C.F.R. Part 403, including any subsequent regulatory revisions to 40 C.F.R. Part 403. Where 40 C.F.R. Part 403 or subsequent revision places mandatory actions upon the Discharger as Control Authority but does not specify a timetable for completion of the actions, the Discharger shall complete the required actions within 6 months from the issuance date of this permit or the effective date of the 40 CFR Part 403 revisions, whichever comes later. For violations of pretreatment requirements, the Discharger shall be subject to enforcement actions, penalties, fines, and other remedies by U.S. EPA or other appropriate parties, as provided in the CWA. U.S. EPA may initiate enforcement action against a nondomestic user for noncompliance with applicable standards and requirements as provided in the CWA.
- ii. The Discharger shall enforce the requirements promulgated under sections 307(b), 307(c), 307(d), and 402(b) of the CWA with timely, appropriate and effective enforcement actions. The Discharger shall cause all nondomestic users subject to federal categorical standards to achieve compliance no later than the date specified in those requirements or, in the case of a new nondomestic user, upon commencement of the discharge.

- iii. The Discharger shall perform the pretreatment functions as required in 40 C.F.R. Part 403 including, but not limited to:
  - (a) Implement the necessary legal authorities as provided in 40 CFR Part 403.8(f)(1);
  - (b) Enforce the pretreatment requirements under 40 C.F.R. sections 403.5 and 403.6;
  - (c) Implement the programmatic functions as provided in 40 C.F.R. section 403.8(f)(2); and
  - (d) Provide the requisite funding and personnel to implement the pretreatment program as provided in 40 C.F.R. section 403.8(f)(3).
- iv. **Pretreatment Reporting Requirements.** Pretreatment reporting requirements are included in the Monitoring and Reporting Program, section X.D.6 of Attachment E.
- b. **Sludge/Biosolids Treatment or Discharge Specifications.** Sludge in this document means the solid, semisolid, and liquid residues removed during primary, secondary, or advanced wastewater treatment processes. Solid waste refers to grit and screening material generated during preliminary treatment. Residual sludge means sludge that will not be subject to further treatment at the wastewater treatment plant. Biosolids refer to sludge that has been treated and tested and shown to be capable of being beneficially and legally used pursuant to federal and state regulations as a soil amendment for agricultural, silvicultural, horticultural, and land reclamation activities as specified under 40 C.F.R. Part 503.
  - i. Collected screenings, residual sludge, biosolids, and other solids removed from liquid wastes shall be disposed of in a manner consistent with Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste, as set forth in Title 27, CCR, division 2, subdivision 1, section 20005, et seq. Removal for further treatment, storage, disposal, or reuse at sites (e.g., landfill, composting sites, soil amendment sites) that are operated in accordance with valid waste discharge requirements issued by a Regional Water Board will satisfy these specifications.

Sludge and solid waste shall be removed from screens, sumps, ponds, clarifiers, etc. as needed to ensure optimal plant performance.

The treatment of sludge generated at the Facility shall be confined to the Facility property and conducted in a manner that precludes infiltration of waste constituents into soils in a mass or concentration that will violate groundwater limitations in section V.B. of this Order. In addition, the storage of residual sludge, solid waste, and biosolids on Facility property shall be temporary and controlled, and contained in a manner that

minimizes leachate formation and precludes infiltration of waste constituents into soils in a mass or concentration that will violate groundwater limitations included in section V.B. of this Order.

- ii. The use, disposal, storage, and transportation of biosolids shall comply with existing federal and state laws and regulations, including permitting requirements and technical standards included in 40 C.F.R. Part 503. If the State Water Board and the Central Valley Water Board are given the authority to implement regulations contained in 40 C.F.R. Part 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 C.F.R. Part 503 whether or not they have been incorporated into this Order.
  - iii. The Discharger shall comply with section IX.A. Biosolids of the Monitoring and Reporting Program, Attachment E.
  - iv. The Discharger shall implement onsite sludge/biosolids treatment, processing, and storage for the Facility as described in the Fact Sheet (Attachment F, section II.A). This Order may be reopened to address any proposed change in the onsite treatment, processing, or storage of sludge/biosolids.
- c. Limited portions of the wastewater collection system may be outside the service area of the Discharger. In order to assure compliance with the Discharge Prohibitions and to assure protection of the entire collection system and treatment works from industrial discharges, it is necessary that the Discharger control discharges into the system. To control discharges into the entire collection system, the Discharger shall establish interagency agreements with the collection system owners. The interagency agreements shall contain, at a minimum, requirements for implementation of an industrial pretreatment program that meets the minimum requirements of this permit. The Discharger shall comply with the time schedule in the Technical Reports Table E-13.

## 6. Other Special Provisions

- a. **Title 22, or Equivalent, Disinfection Requirements.** Wastewater shall be oxidized, coagulated, filtered, and adequately disinfected consistent with the State Water Board, Division of Drinking Water (DDW) reclamation criteria, CCR, Title 22, division 4, chapter 3, (Title 22), or equivalent.

## 7. Compliance Schedules – Not Applicable

## VII. COMPLIANCE DETERMINATION

- A. **BOD<sub>5</sub> and TSS Effluent Limitations (Sections IV.A.1.a).** Compliance with the final effluent limitations for BOD<sub>5</sub> and TSS required in Waste Discharge Requirements

section IV.A.1.a shall be ascertained by 24-hour composite samples. Compliance with effluent limitations required in Waste Discharge Requirements section IV.A.1.a for percent removal shall be calculated using the arithmetic mean of BOD<sub>5</sub> and TSS in effluent samples collected over a monthly period as a percentage of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

**B. Total Mercury Mass Loading Effluent Limitations (Section IV.A.1.g).** The procedures for calculating mass loadings are as follows:

1. The total pollutant mass load for each individual calendar month shall be determined using an average of all concentration data collected that month and the corresponding total monthly flow. All effluent monitoring data collected under the monitoring and reporting program, pretreatment program, and any special studies shall be used for these calculations. The total annual mass loading shall be the sum of the individual calendar months.
2. In calculating compliance, the Discharger shall count all non-detect measures at one-half of the detection level. If compliance with the effluent limitation is not attained due to the non-detect contribution, the Discharger shall improve and implement available analytical capabilities and compliance shall be evaluated with consideration of the detection limits.

**C. Average Dry Weather Flow Prohibition (Section III.E).** The average dry weather discharge flow represents the daily average flow when groundwater is at or near normal and runoff is not occurring. Compliance with the average dry weather flow discharge prohibition will be determined annually based on the average daily flow over three consecutive dry weather months (e.g., July, August, and September).

**D. Total Coliform Organisms Effluent Limitations (Section IV.A.1.f).** For each day that an effluent sample is collected and analyzed for total coliform organisms, the 7-day median shall be determined by calculating the median concentration of total coliform bacteria in the effluent utilizing the bacteriological results of the last 7 days. For example, if a sample is collected on a Wednesday, the result from that sampling event and all results from the previous 6 days (i.e., Tuesday, Monday, Sunday, Saturday, Friday, and Thursday) are used to calculate the 7-day median. If the 7-day median of total coliform organisms exceeds a most probable number (MPN) of 2.2 per 100 milliliters, the Discharger will be considered out of compliance.

**E. Total Residual Chlorine Effluent Limitations (Section IV.A.1.e).** Continuous monitoring analyzers for chlorine residual or for dechlorination agent residual in the effluent are appropriate methods for compliance determination. A positive residual dechlorination agent in the effluent indicates that chlorine is not present in the discharge, which demonstrates compliance with the effluent limitations. This type of monitoring can also be used to prove that some chlorine residual exceedances are false positives. Continuous monitoring data showing either a positive dechlorination agent residual or a chlorine residual at or below the prescribed limit are sufficient to show compliance with the total residual chlorine effluent limitations, as long as the

instruments are maintained and calibrated in accordance with the manufacturer's recommendations.

Any excursion above the 1-hour average or 4-day average total residual chlorine effluent limitations is a violation. If the Discharger conducts continuous monitoring and the Discharger can demonstrate, through data collected from a back-up monitoring system, that a chlorine spike recorded by the continuous monitor was not actually due to chlorine, then any excursion resulting from the recorded spike will not be considered an exceedance, but rather reported as a false positive. Records supporting validation of false positives shall be maintained in accordance with Section IV Standard Provisions (Attachment D).

- F. Effluent Limitations.** Compliance with effluent limitations shall be determined in accordance with section 2.4.5 of the SIP, as follows:
1. Dischargers shall be deemed out of compliance with an effluent limitation, if the concentration in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).
  2. Dischargers shall be required to conduct a Pollutant Minimization Program (PMP) in accordance with section 2.4.5.1 of the SIP when there is evidence that the priority pollutant is present in the effluent above an effluent limitation and either:
    - a. sample result is reported as detected, but not quantified (DNQ) and the effluent limitation is less than the RL; or
    - b. sample result is reported as non-detect (ND) and the effluent limitation is less than the method detection limit (MDL).
  3. When determining compliance with an AMEL or AWEL and more than one sample result is available in the respective month or week, the discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
    - a. The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
    - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

4. If a sample result, or the arithmetic mean or median of multiple sample results, is below the RL, and there is evidence that the priority pollutant is present in the effluent above an effluent limitation and the discharger conducts a PMP (as described in section 2.4.5.1), the discharger shall **not** be deemed out of compliance.

**G. Dissolved Oxygen Receiving Water Limitation (Section V.A.4.a-c).** The Facility provides a high level of treatment including tertiary filtration and nitrification, which results in minimal dissolved oxygen impacts in the receiving water. Weekly receiving water monitoring is required, when discharging to Discharge Point 001, in the Monitoring and Reporting Program (Attachment E) and is sufficient to evaluate the impacts of the discharge and compliance with this Order. Weekly receiving water monitoring data, measured at Monitoring Locations RSW- 001 and RSW-002, will be used to determine compliance with part “c” of the dissolved oxygen receiving water limitation to ensure the discharge does not cause the dissolved oxygen concentrations in the Feather River to be reduced below 7.0 mg/L at any time. However, should more frequent dissolved oxygen and temperature receiving water monitoring be conducted, Central Valley Water Board staff may evaluate compliance with parts “a” and “b”.

**H. Chronic Whole Effluent Toxicity Effluent Trigger.** To determine an exceedance of the chronic whole effluent toxicity effluent trigger, the median chronic toxicity units (TUc) shall be (1) the median of up to three consecutive chronic toxicity bioassays (routine chronic toxicity monitoring event and two subsequent optional monitoring events) during a six-week period; or (2) the median will be the arithmetic mean of the routine monitoring event and the additional event If only one additional monitoring event is conducted. or (3) the result for the routine chronic toxicity monitoring event if additional monitoring events are not conducted.

Where the median chronic toxicity units exceed 12 TUc (as 100/NOEC) for any end point, the Discharger will be deemed to have exceeded the chronic toxicity effluent trigger if the median chronic toxicity units for any endpoint also exceeds a reporting level of 12 TUc (as 100/EC25) AND the percent effect at 8.3 percent effluent exceeds 25 percent. The percent effect used to evaluate the exceedance of the chronic toxicity effluent trigger shall be based on the chronic toxicity bioassay result(s) from the sample(s) used to establish the median TUc result. If the median TUc is based on two equal chronic toxicity bioassay results, the percent effect of the sample with the greatest percent effect shall be used to evaluate the exceedance of the chronic toxicity effluent trigger.

## ATTACHMENT A – DEFINITIONS

### **Arithmetic Mean ( $\mu$ )**

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n$$

where:  $\Sigma x$  is the sum of the measured ambient water concentrations, and  $n$  is the number of samples.

### **Average Monthly Effluent Limitation (AMEL)**

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

### **Average Weekly Effluent Limitation (AWEL)**

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

### **Bioaccumulative**

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

### **Carcinogenic**

Pollutants are substances that are known to cause cancer in living organisms.

### **Coefficient of Variation (CV)**

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

### **Detected, but Not Quantified (DNQ)**

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

### **Dilution Credit**

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

### **Effluent Concentration Allowance (ECA)**

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance

(Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

### **Enclosed Bays**

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

### **Estimated Chemical Concentration**

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

### **Estuaries**

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

### **Inland Surface Waters**

All surface waters of the state that do not include the ocean, enclosed bays, or estuaries.

### **Instantaneous Maximum Effluent Limitation**

The highest allowable value for any single grab sample (i.e., each grab sample is independently compared to the instantaneous maximum limitation).

### **Instantaneous Minimum Effluent Limitation**

The lowest allowable value for any single grab sample (i.e., each grab is independently compared to the instantaneous minimum limitation).

### **Instream Waste Concentration (IWC)**

The concentration of effluent in the receiving water after mixing.

### **Maximum Daily Effluent Limitation (MDEL)**

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

**Median**

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median =  $X_{(n+1)/2}$ . If n is even, then the median =  $(X_{n/2} + X_{(n/2)+1})/2$  (i.e., the midpoint between the n/2 and n/2+1).

**Method Detection Limit (MDL)**

MDL is the minimum measured concentration of a substance that can be reported with 99 percent confidence that the measured concentration is distinguishable from method blank results, as defined in 40 C.F.R. Part 136, Attachment B.

**Minimum Level (ML)**

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

**Mixing Zone**

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

**Not Detected (ND)**

Sample results which are less than the laboratory's MDL.

**Null Hypothesis**

A statement used in statistical testing that has been put forward either because it is believed to be true or because it is to be used as a basis for argument, but has not been proved.

**Ocean Waters**

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

**Percent Effect**

The percent effect at the instream waste concentration (IWC) shall be calculated using untransformed data and the following equation:

$$\text{Percent Effect of the Sample} = \frac{\text{Mean Control Response} - \text{Mean Sample Response}}{\text{Mean Control Response}} \cdot 100$$

**Persistent Pollutants**

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

### **Pollutant Minimization Program (PMP)**

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Central Valley Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

### **Pollution Prevention**

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Resources Control Board (State Water Board) or Central Valley Water Board.

### **Satellite Collection System**

The portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

### **Source of Drinking Water**

Any water designated as municipal or domestic supply (MUN) in a Central Valley Water Board Basin Plan.

### **Species Sensitivity Screening**

An analysis to determine the single most sensitive species from an array of test species to be used in a single species laboratory test series.

### **Standard Deviation ( $\sigma$ )**

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum [(x - \mu)^2] / (n - 1))^{0.5}$$

where:

- x is the observed value;
- $\mu$  is the arithmetic mean of the observed values; and
- n is the number of samples.

**Statewide Toxicity Provisions**

Refers to Section III.B and Section IV.B of the Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California.


**Toxicity Reduction Evaluation (TRE)**

TRE is a study conducted in a stepwise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.).


**Test of Significant Toxicity (TST)**

A statistical approach used to analyze aquatic toxicity test data, as described in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010), Appendix A, Figure A-1 and Table A-1 (Chronic Freshwater and East Coast Methods) and Appendix B, Table B-1.

ATTACHMENT B – MAP



**ATTACHMENT C – FIGURES  
FLOW SCHEMATIC**



**ATTACHMENT C – FIGURES**  
**GROUNDWATER MONITORING WELL NETWORK**



## ATTACHMENT D – STANDARD PROVISIONS

### I. STANDARD PROVISIONS – PERMIT COMPLIANCE

#### A. Duty to Comply:

1. The Discharger must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action; permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 C.F.R. section 122.41(a); Wat. Code, sections 13261, 13263, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. section 122.41(a)(1).)

#### B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. section 122.41(c).)

#### C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. section 122.41(d).)

#### D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes having adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. section 122.41(e).)

#### E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. section 122.41(g).)

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. section 122.5(c).)

#### **F. Inspection and Entry**

The Discharger shall allow the Central Valley Water Board, State Water Board, U.S. EPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. section 1318(a)(4)(B); 40 C.F.R. section 122.41(i); Wat. Code, section 13267, 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(1); Wat. Code, sections 13267, 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(2); Wat. Code, sections 13267, 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(3); Wat. Code, section 13267, 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (33 U.S.C section 1318(a)(4)(B); 40 C.F.R. section 122.41(i)(4); Wat. Code, sections 13267, 13383.)

#### **G. Bypass**

1. Definitions
  - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. section 122.41(m)(1)(i).)
  - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. section 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not

subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. section 122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Central Valley Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. section 122.41(m)(4)(i)):
  - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. section 122.41(m)(4)(i)(A));
  - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. section 122.41(m)(4)(i)(B)); and
  - c. The Discharger submitted notice to the Central Valley Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. section 122.41(m)(4)(i)(C).)
4. The Central Valley Water Board may approve an anticipated bypass, after considering its adverse effects, if the Central Valley Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. section 122.41(m)(4)(ii).)
5. **Notice**
  - a. **Anticipated bypass.** If the Discharger knows in advance of the need for a bypass, it shall submit prior notice if possible, at least 10 days before the date of the bypass. The notice shall be sent to the Central Valley Water Board. As of 21 December 2023, all notices shall be submitted electronically to the initial recipient (State Water Board's [California Integrated Water Quality System \(CIWQS\) Program website](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/) ([http://www.waterboards.ca.gov/water\\_issues/programs/ciwqs/](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/)), defined in Standard Provisions – Reporting V.J below. Notices shall comply with 40 C.F.R. Part 3, section 122.22, and 40 C.F.R. Part 127. (40 C.F.R. section 122.41(m)(3)(i).)
  - b. **Unanticipated bypass.** The Discharger shall submit a notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). The notice shall be sent to the Central Valley Water Board. As of 21 December 2023, all notices shall be submitted electronically to the initial recipient (State Water Board's [California Integrated Water Quality System \(CIWQS\) Program website](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/). ([http://www.waterboards.ca.gov/water\\_issues/programs/ciwqs/](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/)), defined in Standard Provisions – Reporting V.J below. Notices shall comply with 40

C.F.R. Part 3, section 122.22, and 40 C.F.R. Part 127. (40 C.F.R. section 122.41(m)(3)(ii).)

## H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. section 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. section 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. section 122.41(n)(3)):
  - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. section 122.41(n)(3)(i));
  - b. The permitted facility was, at the time, being properly operated (40 C.F.R. section 122.41(n)(3)(ii));
  - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. section 122.41(n)(3)(iii)); and
  - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. section 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. section 122.41(n)(4).)

## II. STANDARD PROVISIONS – PERMIT ACTION

### A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. section 122.41(f).)

### B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. section 122.41(b).)

### C. Transfers

This Order is not transferable to any person except after notice to the Central Valley Water Board. The Central Valley Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. section 122.41(l)(3); 122.61.)

## III. STANDARD PROVISIONS – MONITORING

A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. section 122.41(j)(1).)

B. Monitoring must be conducted according to test procedures approved under 40 C.F.R. Part 136 for the analyses of pollutants unless another method is required under 40 C.F.R. subchapters N or O. Monitoring must be conducted according to sufficiently sensitive test methods approved under 40 C.F.R. Part 136 for the analysis of pollutants or pollutant parameters or as required under 40 C.F.R. chapter 1, subchapter N or O. For the purposes of this paragraph, a method is sufficiently sensitive when the method has the lowest ML of the analytical methods approved under 40 C.F.R. Part 136 or required under 40 C.F.R. chapter 1, subchapter N or O for the measured pollutant or pollutant parameter, or when:

1. The method minimum level (ML) is at or below the level of the most stringent effluent limitation established in the permit for the measured pollutant or pollutant parameter, and;
  - a. The method ML is at or below the level of the most stringent applicable water quality criterion for the measured pollutant or pollutant parameter, or;
  - b. The method ML is above the applicable water quality criterion but the amount of the pollutant or pollutant parameter in the facility's discharge is

high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge.

In the case of pollutants or pollutant parameters for which there are no approved methods under 40 C.F.R. Part 136 or otherwise required under 40 C.F.R. chapter 1, subchapters N or O, monitoring must be conducted according to a test procedure specified in this Order for such pollutants or pollutant parameters. (40 C.F.R. sections 122.21(e)(3), 122.41(j)(4); 122.44(i)(1)(iv).)

#### **IV. STANDARD PROVISIONS – RECORDS**

- A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 C.F.R. part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Central Valley Water Board Executive Officer at any time. (40 C.F.R. section 122.41(j)(2).)
- B.** Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements (40 C.F.R. section 122.41(j)(3)(i));
  2. The individual(s) who performed the sampling or measurements (40 C.F.R. section 122.41(j)(3)(ii));
  3. The date(s) analyses were performed (40 C.F.R. section 122.41(j)(3)(iii));
  4. The individual(s) who performed the analyses (40 C.F.R. section 122.41(j)(3)(iv));
  5. The analytical techniques or methods used (40 C.F.R. section 122.41(j)(3)(v)); and
  6. The results of such analyses. (40 C.F.R. section 122.41(j)(3)(vi).)
- C.** Claims of confidentiality for the following information will be denied (40 C.F.R. section 122.7(b)):
1. The name and address of any permit applicant or Discharger (40 C.F.R. section 122.7(b)(1)); and
  2. Permit applications and attachments, permits and effluent data. (40 C.F.R. section 122.7(b)(2).)

## **V. STANDARD PROVISIONS – REPORTING**

### **A. Duty to Provide Information**

The Discharger shall furnish to the Central Valley Water Board, State Water Board, or U.S. EPA within a reasonable time, any information which the Central Valley Water Board, State Water Board, or U.S. EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Central Valley Water Board, State Water Board, or U.S. EPA copies of records required to be kept by this Order. (40 C.F.R. section 122.41(h); Wat. Code, sections 13267, 13383.)

### **B. Signatory and Certification Requirements**

1. All applications, reports, or information submitted to the Central Valley Water Board, State Water Board, and/or U.S. EPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, V.B.5, and V.B.6 below. (40 C.F.R. section 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of U.S. EPA). (40 C.F.R. section 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Central Valley Water Board, State Water Board, or U.S. EPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. section 122.22(b)(1));
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. section 122.22(b)(2)); and
  - c. The written authorization is submitted to the Central Valley Water Board and State Water Board. (40 C.F.R. section 122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Central Valley Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. section 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. section 122.22(d).)
6. Any person providing the electronic signature for such documents described in Standard Provision – V.B.1, V.B.2, or V.B.3 that are submitted electronically shall meet all relevant requirements of Standard Provisions – Reporting V.B, and shall ensure that all of the relevant requirements of 40 C.F.R. part 3 (Cross-Media Electronic Reporting) and 40 C.F.R. part 127 (NPDES Electronic Reporting Requirements) are met for that submission. (40 C.F.R section 122.22(e).)

### **C. Monitoring Reports**

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. section 122.41(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Central Valley Water Board or State Water Board for reporting the results of monitoring, sludge use, or disposal practices. As of 21 December 2016, all reports and forms must be submitted electronically to the initial recipient, defined in Standard Provisions – Reporting V.J, and comply with 40 C.F.R. part 3, section 122.22, and 40 C.F.R. part 127. (40 C.F.R. section 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 C.F.R. part 136, or another method required for an industry-specific waste stream under 40 C.F.R. subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting

form specified by the Central Valley Water Board. (40 C.F.R. section 122.41(l)(4)(ii).)

4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. section 122.41(l)(4)(iii).)

#### **D. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. section 122.41(l)(5).)

#### **E. Twenty-Four Hour Reporting**

1. The Discharger shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A report shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (combined sewer overflows, sanitary sewer overflows, or bypass events), type of sewer overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volumes untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the sewer overflow event, and whether the noncompliance was related to wet weather.

As of 21 December 2020 all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events must be submitted electronically to the initial recipient (State Water Board) defined in Standard Provisions – Reporting V.J. The reports shall comply with 40 C.F.R. part 3. They may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. section 122.41(l)(6)(i).)

#### **F. Planned Changes**

The Discharger shall give notice to the Central Valley Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. section 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. section 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1). (40 C.F.R. section 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 C.F.R. section 122.41(l)(1)(iii).)

**G. Anticipated Noncompliance**

The Discharger shall give advance notice to the Central Valley Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 C.F.R. section 122.41(l)(2).)

**H. Other Noncompliance**

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in Standard Provision – Reporting V.E and the applicable required data in appendix A to 40 C.F.R. part 127. The Central Valley Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. section 122.41(l)(7).)

**I. Other Information**

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Central Valley Water Board, State Water Board, or U.S. EPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. section 122.41(l)(8).)

**J. Initial Recipient for Electronic Reporting Data**

The owner, operator, or the duly authorized representative is required to electronically submit NPDES information specified in appendix A to 40 C.F.R. part

127 to the appropriate initial recipient, as determined by U.S. EPA, and as defined in 40 C.F.R. section 127.2(b). U.S. EPA will identify and publish the list of initial recipients on its website and in the Federal Register, by state and by NPDES data group [see 40 C.F.R. section 127.2(c)]. U.S. EPA will update and maintain this listing. (40 C.F.R. section 122.41(l)(9).)

## **VI. STANDARD PROVISIONS – ENFORCEMENT**

- A.** The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

## **VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS**

### **A. Publicly-Owned Treatment Works (POTWs)**

All POTWs shall provide adequate notice to the Central Valley Water Board of the following (40 C.F.R. section 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 C.F.R. section 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 C.F.R. section 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. section 122.42(b)(3).)

**ATTACHMENT E – MONITORING AND REPORTING PROGRAM**

**Table of Contents**

- I. General Monitoring Provisions..... E-2
- II. Monitoring Locations ..... E-3
- III. Influent Monitoring Requirements..... E-4
  - A. Monitoring Location INF-001..... E-4
- IV. Effluent Monitoring Requirements ..... E-5
  - A. Monitoring Location EFF-001/EFF-002..... E-5
- V. Whole Effluent Toxicity Testing Requirements ..... E-7
- VI. Land Discharge Monitoring Requirements – Not applicable..... E-11
- VII. Recycling Monitoring Requirements – not applicable ..... E-11
- VIII. Receiving Water Monitoring Requirements ..... E-11
  - A. Monitoring Location RSW-001 and RSW-002..... E-11
  - B. Monitoring Location GW-001, GW-002, and GW-003..... E-13
- IX. Other Monitoring Requirements..... E-14
  - A. Biosolids ..... E-14
  - B. Filtration System ..... E-14
  - C. Pyrethroid Pesticides Monitoring ..... E-15
  - D. Effluent and Receiving Water Characterization ..... E-18
  - E. Percolation Ponds..... E-25
- X. Reporting Requirements..... E-26
  - A. General Monitoring and Reporting Requirements..... E-26
  - B. Self-Monitoring Reports (SMRs) ..... E-26
  - C. Discharge Monitoring Reports (DMRs) ..... E-30
  - D. Other Reports ..... E-30

**Tables**

- Table E-1. Monitoring Station Locations ..... E-3
- Table E-2. Influent Monitoring..... E-4
- Table E-3. Effluent Monitoring ..... E-5
- Table E-4. Chronic Toxicity Testing Dilution Series ..... E-9
- Table E-5. Receiving Water Monitoring Requirements ..... E-11
- Table E-6. Groundwater Monitoring Requirements ..... E-13
- Table E-7. Filtration System Monitoring Requirements ..... E-14
- Table E-8. Pyrethroid Pesticides Monitoring..... E-15
- Table E-9. Pyrethroid Pesticide Partition Coefficients ..... E-17
- Table E-10. Effluent and Receiving Water Characterization Monitoring ..... E-18
- Table E-11 Percolation Ponds Monitoring Requirements ..... E-25
- Table E-12. Monitoring Periods and Reporting Schedule ..... E-27
- Table E-13. Technical Reports ..... E-35

## **ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)**

The Code of Federal Regulations (40 C.F.R. section 122.48) requires that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 authorize the Central Valley Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring and reporting requirements that implement federal and California requirements.

### **I. GENERAL MONITORING PROVISIONS**

- A.** Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of the Central Valley Water Board.
- B.** Final effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to mixing with the receiving waters. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
- C.** Chemical, bacteriological, and bioassay analyses of any material required by this Order shall be conducted by a laboratory accredited for such analyses by the State Water Resources Control Board (State Water Board), Division of Drinking Water (DDW; formerly the Department of Public Health), in accordance with the provision of Water Code section 13176. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Central Valley Water Board. In the event an accredited laboratory is not available to the Discharger for any onsite field measurements such as pH, dissolved oxygen (DO), turbidity, temperature, and residual chlorine, such analyses performed by a non-accredited laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program for any onsite field measurements such as pH, DO, turbidity, temperature, and residual chlorine must be kept onsite in the treatment facility laboratory and shall be available for inspection by Central Valley Water Board staff. The Discharger must demonstrate sufficient capability (qualified and trained employees, properly calibrated and maintained field instruments, etc.) to adequately perform these field measurements. The Quality Assurance-Quality Control Program must conform to U.S. EPA guidelines or to procedures approved by the Central Valley Water Board.
- D.** Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary, at least yearly, to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.

- E.** Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.
- F.** Laboratory analytical methods shall be sufficiently sensitive in accordance with the Sufficiently Sensitive Methods Rule (SSM Rule) specified under 40 C.F.R. 122.21(e)(3) and 122.44(i)(1)(iv). A U.S. EPA-approved analytical method is sufficiently sensitive for a pollutant/parameter where:
  1. The method minimum level (ML) is at or below the applicable water quality objective for the receiving water, or;
  2. The method ML is above the applicable water quality objective for the receiving water but the amount of the pollutant/parameter in the discharge is high enough that the method detects and quantifies the level of the pollutant/parameter, or;
  3. the method ML is above the applicable water quality objective for the receiving water, but the ML is the lowest of the 40 C.F.R. 136 U.S. EPA-approved analytical methods for the pollutant/parameter.
- G.** The Discharger shall ensure that the results of the Discharge Monitoring Report-Quality Assurance (DMR-QA) Study or the most recent Water Pollution Performance Evaluation Study are submitted annually to the State Water Resources Control Board at the following address or electronically via email to the DMR-QA Coordinator:

State Water Resources Control Board  
Quality Assurance Program Officer  
Office of Information Management and Analysis  
1001 I Street, Sacramento, CA 95814
- H.** The Discharger shall file with the Central Valley Water Board technical reports on self-monitoring performed according to the detailed specifications contained in this Monitoring and Reporting Program.

**II. MONITORING LOCATIONS**

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

**Table E-1. Monitoring Station Locations**

<b>Discharge Point Name</b>	<b>Monitoring Location Name</b>	<b>Monitoring Location Description</b>
--	INF-001	A location where a representative sample of the influent into the Facility can be collected.
001 and 002	EFF-001 and EFF-002 (EFF-	Downstream of the last connection through which wastes can be admitted to the outfall before being

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
	001/EFF-002)	discharged to the Feather River or the percolation ponds.
--	RSW-001	In the Feather River, 100 feet upstream of the percolation ponds.
--	RSW-002	In the Feather River, 100 feet downstream of the percolation ponds.
--	PND-001	Percolation Pond 1
--	PND-002	Percolation Pond 2
--	PND-003	Percolation Pond 3
--	PND-004	Percolation Pond 4
--	PND-005	Percolation Pond 5
--	GW-001	Groundwater monitoring well (identified as MW-1 in the Discharger's Hydrogeologic Assessment Report).
--	GW-002	Groundwater monitoring well (identified as MW-2 in the Discharger's Hydrogeologic Assessment Report).
--	GW-003	Groundwater monitoring well (identified as MW-3 in the Discharger's Hydrogeologic Assessment Report).
	FIL-001	Monitoring of the filter effluent to be measured downstream of the filters and chlorine disinfection system, but before being discharged to the Feather River or the percolation ponds.
	SPL-001	A location where a representative sample of the municipal supply water can be obtained. If this is impractical, water quality data provided by the water supplier(s) may be used.
	BIO-001	A location where a representative sample of the biosolids can be obtained.

### III. INFLUENT MONITORING REQUIREMENTS

#### A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the Facility at Monitoring Location INF-001 in accordance with Table E-2 and the testing requirements described in section III.A.2 below:

**Table E-2. Influent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow	MGD	Meter	Continuous
pH	standard units	Meter	Continuous
Biochemical Oxygen Demand, 5-day @ 20°Celsius (BOD <sub>5</sub> )	mg/L	24-hour Composite	3/Week

Parameter	Units	Sample Type	Minimum Sampling Frequency
Total Suspended Solids (TSS)	mg/L	24-hour Composite	3/Week

2. **Table E-2 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-2:
- a. **Applicable to all parameters.** Parameters shall be analyzed using the analytical methods described in 40 CFR part 136; or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.
  - b. **24-Hour Composite Samples.** All composite samples shall be collected from a 24-hour flow proportional composite.

#### IV. EFFLUENT MONITORING REQUIREMENTS

##### A. Monitoring Location EFF-001/EFF-002

1. The Discharger shall monitor treated wastewater at Monitoring Location EFF-001/EFF-002 when discharging at Discharge Points 001 or 002 as follows. EFF-001 and EFF-002 are located at the same monitoring location. For reporting purposes, the Discharger shall use EFF-001 as the monitoring location when discharging to Discharge Point 001 and shall use EFF-002 as the monitoring location when discharging to Discharge Point 002. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

**Table E-3. Effluent Monitoring**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow	MGD	Meter	Continuous
Biochemical Oxygen Demand, 5-day @ 20°Celcius (BOD <sub>5</sub> )	mg/L	24-hour Composite	3/Week
BOD <sub>5</sub>	% removal	Calculate	1/Month
Dibromochloromethane	µg/L	Grab	1/Month
Dichlorobromomethane	µg/L	Grab	1/Month
Total Suspended Solids (TSS)	mg/L	24-hour Composite	3/Week
TSS	% removal	Calculate	1/Month
pH	standard units	Meter	Continuous

Ammonia Nitrogen, Total (as N)	mg/L	Grab	3/Week
Chlorine, Total Residual	mg/L	Meter	Continuous
Chlorpyrifos	µg/L	Grab	1/Year
Diazinon	µg/L	Grab	1/Year
Dissolved Organic Carbon	mg/L	24-hour Composite	1/Quarter
Dissolved Oxygen	mg/L	Meter	1/Week
Dechlorination Agent	mg/L	Meter	Continuous
Electrical Conductivity @ 25°Celcius	µmhos/cm	Grab	1/Month
Hardness, Total (as CaCO3)	mg/L	Grab	1/Quarter
Mercury, Total	ng/L	Grab	1/Quarter
Nitrate Nitrogen, Total (as N)	mg/L	Grab	2/Month
Nitrite Nitrogen, Total (as N)	mg/L	Grab	2/Month
Nitrate plus Nitrite (as N)	mg/L	Grab	2/Month
Temperature	°F	Grab	3/Week
Total Coliform Organisms	MPN/100 mL	Grab	3/Week

2. **Table E-3 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-3:

- a. **Applicable to all parameters.** Parameters shall be analyzed using the analytical methods described in 40 CFR part 136 or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.
- b. **24-hour composite samples** shall be collected from a 24-hour flow proportional composite.
- c. **Handheld Field Meter.** A handheld field meter may be used for **temperature, dissolved oxygen, pH, and electrical conductivity**, provided the meter utilizes a U.S. EPA-approved algorithm/method and is calibrated and maintained in accordance with the manufacturer's instructions. A calibration and maintenance log for each meter used for monitoring required by this Monitoring and Reporting Program shall be maintained at the Facility.
- d. **Temperature** and **pH** shall be recorded at the time of **ammonia** sample collection.
- e. **Total Residual Chlorine** must be monitored using an analytical method that is sufficiently sensitive to measure at the permitted level of 0.01 mg/L.

- f. **Total Mercury and Methyl Mercury.** Unfiltered methyl mercury and total mercury samples shall be taken using **clean hands/dirty hands procedures**, as described in U.S. EPA method 1669: Sampling Ambient Water for Trace Metals at U.S. EPA Water Quality Criteria Levels, for collection of equipment blanks (section 9.4.4.2). The analysis of methyl mercury and total mercury shall be by U.S. EPA method 1630 and 1631 (Revision E), respectively, with a **reporting limit of 0.05 ng/L for methyl mercury and 0.5 ng/L for total mercury**.
- g. **Total Coliform Organisms.** Samples for total coliform organisms may be collected at any point following disinfection.
- h. **Chlorpyrifos and Diazinon** shall be sampled using U.S. EPA Method 625M, Method 8141, or equivalent GC/MS method with a lower Reporting Limit than the Basin Plan Water Quality Objectives of 0.015 µg/L and 0.1 µg/L for chlorpyrifos and diazinon, respectively.
- i. **Dissolved Organic Carbon monitoring** shall be conducted concurrently with pH and hardness sampling.
- j. **Effluent pH** shall be measured continuously at 1-second intervals and tracked as a 20-minute running average. The highest and lowest 20-minute averages each day shall be reported.
- k. **Total Chlorine Residual** must be monitored only when discharging at Discharge Point 001 and with a method sensitive to and accurate at the permitted level of 0.01 mg/L.
- l. **Dechlorination Agent.** If chlorine disinfection is utilized at the Facility, the chemical used to dechlorinate the effluent (e.g., sulfur dioxide) shall be monitored only when discharging to Discharge Point 001.
- m. **Nitrate and Nitrite.** Monitoring for nitrite and nitrate shall be conducted concurrently.
- n. **Total Coliform Organisms.** Samples for total coliform organisms may be collected at any point following disinfection.
- o. **Concurrent Monitoring.** When conducting receiving water monitoring as required in this Monitoring and Reporting Program, effluent sampling shall be conducted concurrently with upstream receiving water monitoring.

## V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

- A. **Acute Toxicity Testing.** The Discharger shall conduct acute toxicity testing to determine whether the treatment system effluent is contributing acute toxicity to the receiving water. Acute toxicity shall be monitored at Monitoring Location EFF-001. Inability to collect samples for the acute toxicity test, after making three attempts shall be described and documented (e.g. with photographs) in an addendum to the

quarterly monitoring report. The Discharger shall meet the following acute toxicity testing requirements:

1. **Monitoring Frequency** – The Discharger shall perform **quarterly** acute toxicity testing when discharging to Discharge Point 001 if discharge has occurred for 15 days combined or more in a calendar quarter. Sampling will be concurrent with effluent ammonia sampling.
2. **Sample Types** – The Discharger may use flow-through or static renewal testing. For static renewal testing, the samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001/EFF-002.
3. **Test Species** – Test species shall be **rainbow trout** (*Oncorhynchus mykiss*).
4. **Methods** – The acute toxicity testing samples shall be analyzed using EPA-821-R-02-012, Fifth Edition. Temperature and pH shall be recorded at the time of sample collection. No pH adjustment may be made unless approved by the Executive Officer.
5. **Test Failure** – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.

**B. Chronic Toxicity Testing.** The Discharger shall meet the following chronic toxicity testing requirements:

1. **Monitoring Frequency** –The Discharger shall perform routine **quarterly** chronic toxicity testing when discharging to **Discharge Point 001** if discharge has occurred for 15 days combined or more in a calendar quarter. If the result of the routine chronic toxicity testing event from Discharge Point 001 exhibit toxicity, demonstrated by a result greater than 12 TUc (as 100/EC<sub>25</sub>) AND a percent effect greater than 25 percent at 8.3 percent effluent, the Discharger has the option of conducting two additional compliance monitoring events and perform chronic toxicity testing using the species that exhibited toxicity in order to calculate a median. The optional compliance monitoring events shall occur at least one week apart, and the final monitoring event shall be initiated no later than 6 weeks from the routine monitoring event that exhibited toxicity. See Compliance Determination section VII.H for procedures for calculating 6-week median.
2. **Sample Types** – Effluent samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001/EFF-002. The receiving water control shall be a grab sample obtained from the RSW-001 sampling location, as identified in this Monitoring and Reporting Program.

3. **Sample Volumes** – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.
4. **Test Species** – Chronic toxicity testing measures sublethal (e.g., reduced growth, reproduction) and/or lethal effects to test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
  - a. The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
  - b. The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
  - c. The green alga, *Pseudokirchneriella subcapitata* (growth test).
5. **Methods** – The presence of chronic toxicity shall be estimated as specified in Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002.
6. **Reference Toxicant** – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.
7. **Dilutions** – For routine and accelerated chronic toxicity monitoring, it is not necessary to perform the test using a dilution series. The test may be performed using 100% effluent and one control. For TRE monitoring, the chronic toxicity testing shall be performed using the dilution series identified in Table E-4, below, unless an alternative dilution series is detailed in the submitted TRE Action Plan. A receiving water control or laboratory water control may be used as the diluent.

**Table E-4. Chronic Toxicity Testing Dilution Series**

Sample	Dilution (33.2%)	Dilution (16.6%)	Dilution (8.3%)	Dilution (4.2%)	Dilution (2.1%)	Control
% Effluent	33.2	16.6	8.3	4.2	2.1	0
% Control Water	66.8	83.4	91.7	95.8	97.9	100

**Table E-4 Testing Requirements.** Receiving water control or laboratory water control may be used as the diluent.

8. **Test Failure** – If a chronic toxicity test does not meet all test acceptability criteria and test requirements, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.
  - a. The reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the Short-term Methods for Estimating

the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821- R-02-013, October 2002 (Method Manual), and its subsequent amendments or revisions; or

- b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in Table 6 on page 52 of the Method Manual. (A retest is only required in this case if the test results do not exceed the monitoring trigger specified in the Special Provision at section VI. 2.a.iii of the Order.)

**C. WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:

1. **Test of Significant Toxicity (TST).** For both acute and chronic toxicity testing, the toxicity monitoring results shall be reported to the Central Valley Water Board with the quarterly self-monitoring report, and shall contain, at minimum:
  - a. The valid toxicity test results for the Test of Significance Toxicity (TST) statistical approach, reported as "Pass" or "Fail" and "Percent Effect" at the Instream Waste Concentration (IWC) for the discharge at 8.3% effluent.
  - b. The statistical analysis used in National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document (EPA 833-R10-003, 2010) Appendix A, Figure A-1 and Table A-1, and Appendix B, Table B-1.
  - c. Statistical program (e.g., TST calculator, CETIS, etc.) output results, including graphical plots, for each toxicity test.
2. **Chronic WET Reporting.** Regular chronic toxicity monitoring results shall be reported to the Central Valley Water Board with the quarterly Self-Monitoring Report (SMR), and shall contain, at minimum:
  - a. The results expressed in TU<sub>c</sub>, measured as 100/NOEC, and also measured as 100/LC50, 100/EC25, 100/IC25, and 100/IC50, as appropriate.
  - b. The statistical methods used to calculate endpoints;
  - c. The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD);
  - d. The dates of sample collection and initiation of each toxicity test; and

- e. The results compared to the numeric toxicity monitoring trigger.

Additionally, the quarterly SMRs shall contain an updated chronology of chronic toxicity test results expressed in TUC, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency, i.e., either quarterly, monthly, accelerated, or TRE.

2. **Acute WET Reporting.** Acute toxicity test results shall be submitted with the monthly SMR and reported as percent survival.
3. **TRE or TES Reporting.** Reports for TRE's or a TES shall be submitted in accordance with the schedule contained in the Discharger's approved TRE Workplan, or as amended by the Discharger's TRE Action Plan.
4. **Quality Assurance (QA).** The Discharger must provide the following information for QA purposes:
  - a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
  - b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
  - c. Any information on deviations or problems encountered and how they were dealt with.

**VI. LAND DISCHARGE MONITORING REQUIREMENTS – NOT APPLICABLE**

**VII. RECYCLING MONITORING REQUIREMENTS – NOT APPLICABLE**

**VIII. RECEIVING WATER MONITORING REQUIREMENTS**

**A. Monitoring Location RSW-001 and RSW-002**

1. Receiving water monitoring is not required when discharging at Discharge Point 002. The Discharger shall monitor the Feather River at Monitoring Locations RSW-001 and RSW-002 when the Feather River is flowing within its normal channel at a flow less than approximately 25,000 cfs during the weekly period Sunday through Saturday, for the following:

**Table E-5. Receiving Water Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency
pH	Standard Units	Grab	1/Week
Dissolved Oxygen	mg/L	Grab	1/Week

Parameter	Units	Sample Type	Minimum Sampling Frequency
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Quarter
Hardness	mg/L	Grab	1/Quarter
Temperature	°Celcius	Grab	1/Week
Turbidity	NTU	Grab	1/Week

2. **Table E-5 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-5:
  - a. **Applicable to all parameters.** Parameters shall be analyzed using the analytical methods described in 40 CFR part 136 or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.
  - b. **Handheld Field Meter.** A handheld field meter may be used for **temperature, dissolved oxygen, pH, and electrical conductivity**, provided the meter utilizes a U.S. EPA-approved algorithm/method and is calibrated and maintained in accordance with the manufacturer's instructions. A calibration and maintenance log for each meter used for monitoring required by this Monitoring and Reporting Program shall be maintained at the Facility.
  
3. In conducting the receiving water sampling, a log shall be kept of the receiving water conditions throughout the reach bounded by Monitoring Locations RSW-001 and RSW-002 when discharging to Discharge Point 001. Notes on the following receiving water conditions shall be summarized in an attachment to the self monitoring report, including the presence or absence of:
  - a. Floating or suspended matter;
  - b. Discoloration;
  - c. Bottom deposits;
  - d. Aquatic life;
  - e. Visible films, sheens, or coatings;
  - f. Fungi, slimes, or objectionable growths; and
  - g. Potential nuisance conditions.

**B. Monitoring Location GW-001, GW-002, and GW-003**

1. Prior to sampling, the groundwater elevations shall be measured and the wells shall be purged of at least three well volumes until temperature, pH, and electrical conductivity have stabilized. Depth to groundwater shall be measured to the nearest 0.01 feet. Groundwater monitoring at Monitoring Locations GW-001, GW-002, and GW-003 shall include, at a minimum, the following:

**Table E-6. Groundwater Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Depth to Groundwater	±0.01 feet	Measurement	1/Quarter
Groundwater Elevation	±0.01 feet	Calculated	1/Quarter
Gradient	feet/feet	Calculated	1/Quarter
Gradient Direction	degrees	Calculated	1/Quarter
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Quarter
pH	standard units	Grab	1/Quarter
Total Nitrogen as N	mg/L	Grab	1/Quarter
Total Dissolved Solids	mg/L	Grab	1/Quarter
Total Organic Carbon	mg/L	Grab	1/Quarter
Iron, Dissolved	µg/L	Grab	1/Quarter
Manganese, Dissolved	µg/L	Grab	1/Quarter
Arsenic, Dissolved	µg/L	Grab	1/Quarter
Hardness, Total (as CaCO <sub>3</sub> )	mg/L	Grab	1/Quarter
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	Grab	1/Quarter
Standard Minerals	µg/L	Grab	1/Quarter
Total Trihalomethanes	µg/L	Grab	1/Quarter

2. **Table E-6 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-6:
  - a. **Groundwater elevation** shall be determined based on depth-to-water measurements from a surveyed measuring point elevation on the well. The groundwater elevation shall be used to calculate the direction and gradient of groundwater flow, which must be reported.
  - b. **Applicable to all parameters.** Parameters shall be analyzed using the analytical methods described in 40 CFR part 136 or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type. Samples shall be collected once from January through June, and once from July through December.

- c. **Standard minerals** shall include the following: boron, calcium, iron, magnesium, potassium, sodium, chloride, manganese, phosphorus, total alkalinity (including alkalinity series), and hardness, and include verification that the analysis is complete (i.e., cation/anion balance).
- d. **Total Trihalomethanes** shall include the following: chloroform, bromoform, chlorodibromomethane, and dichlorobromomethane.
- e. **Minimum Sampling Frequency.** For each constituent the Discharger can demonstrate, after three years of quarterly monitoring, that the data ranges, averages, and standard deviations are similar for quarterly versus twice a year, the minimum sample frequency can be reduced to twice a year.

**IX. OTHER MONITORING REQUIREMENTS**

**A. Biosolids**

**1. Monitoring Location BIO-001**

- a. A composite sample of sludge shall be collected once per permit term at Monitoring Location BIO-001 in accordance with EPA's POTW Sludge Sampling and Analysis Guidance Document, August 1989, and tested for priority pollutants (excluding asbestos).
- b. Biosolids monitoring shall be conducted using the methods in Test Methods for Evaluating Solid Waste, Physical/Chemical methods (EPA publication SW-846), as required in 40 C.F.R. section 503.8(b)(4). All results must be reported on a 100% dry weight basis. Records of all analyses must state on each page of the laboratory report whether the results are expressed in "100% dry weight" or "as is."

**B. Filtration System**

- 1. **Monitoring Locations FIL-001.** The Discharger shall monitor the filtration system at Monitoring Location FIL-001 as follows:

**Table E-7. Filtration System Monitoring Requirements**

Parameter	Units	Sample Type	Monitoring Location	Minimum Sampling Frequency
Turbidity	NTU	Meter	FIL-001	Continuous

- 2. **Table E-7 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-7:
  - a. **Turbidity.** Report daily average and maximum turbidity.

**C. Pyrethroid Pesticides Monitoring**

- 1. Water Column Chemistry Monitoring Requirements.** The Discharger shall conduct effluent and receiving water (RSW-001 and RSW-002, during periods of discharge to the Feather River at Discharge Point 001 for at least 15 days in a quarter) baseline monitoring in accordance with Table E-8. **Quarterly monitoring shall be conducted for one year concurrent with the Effluent and Receiving Water Characterization Monitoring**, to the extent practicable. The discharger shall also submit a minimum of one quality assurance/quality control (QA/QC) sample during the year to be analyzed for the constituents listed in Table E-10.

The monitoring shall be conducted in the effluent at monitoring location EFF-001 and downstream receiving water at monitoring location RSW-002, during periods of discharge to the Feather River at Discharge Point 001, and the results of such monitoring shall be submitted to the Central Valley Water Board with the quarterly self-monitoring reports. The Discharger shall use Environmental Laboratory Accreditation Program (ELAP)-accredited laboratories and methods for pyrethroid pesticides water column chemistry monitoring. ELAP-accredited methods are acceptable for pyrethroid chemical analysis provided that the method meets the analytical capability described in Table E-8. A current list of ELAP approved laboratories and points of contact can be found on the [Central Valley Water Board’s Pyrethroid Pesticides TMDL and Basin Plan Amendment Webpage](https://www.waterboards.ca.gov/centralvalley/water_issues/tmdl/central_valley_projects/central_valley_pesticides/pyrethroid_tmdl_bpa/index.html),

[https://www.waterboards.ca.gov/centralvalley/water\\_issues/tmdl/central\\_valley\\_projects/central\\_valley\\_pesticides/pyrethroid\\_tmdl\\_bpa/index.html](https://www.waterboards.ca.gov/centralvalley/water_issues/tmdl/central_valley_projects/central_valley_pesticides/pyrethroid_tmdl_bpa/index.html).

Monitoring can either be conducted by the Discharger or can be done as part of a group monitoring effort. If the Discharger chooses to participate in a group monitoring effort, the timing and the other study requirements of the monitoring can be modified by the Executive Officer.

**Table E-8. Pyrethroid Pesticides Monitoring**

Parameter	CAS Number	Sample Units	Sample Type	Analytical Method	Reporting Level
Total Bifenthrin	82657-04-3	ng/L	Grab	To be determined	1.3
Total Cyfluthrin	68359-37-5	ng/L	Grab	To be determined	1.3
Total Cypermethrin	52315-07-8	ng/L	Grab	To be determined	1.7
Total Esfenvalerate	51630-58-1	ng/L	Grab	To be determined	3.3
Total Lambda-cyhalothrin	91465-08-6	ng/L	Grab	To be determined	1.2
Total Permethrin	52645-53-1	ng/L	Grab	To be determined	10

Parameter	CAS Number	Sample Units	Sample Type	Analytical Method	Reporting Level
Freely Dissolved Bifenthrin	82657-04-3	ng/L	Calculated	Calculated from total concentration	
Freely Dissolved Cyfluthrin	68359-37-5	ng/L	Calculated	Calculated from total concentration	
Freely Dissolved Cypermethrin	52315-07-8	ng/L	Calculated	Calculated from total concentration	
Freely Dissolved Esfenvalerate	51630-58-1	ng/L	Calculated	Calculated from total concentration	
Freely Dissolved Lambda-cyhalothrin	91465-08-6	ng/L	Calculated	Calculated from total concentration	
Freely Dissolved Permethrin	52645-53-1	ng/L	Calculated	Calculated from total concentration	
Dissolved Organic Carbon (DOC)		mg/L	Grab		
Total Organic Carbon (TOC)		mg/L	Grab		

The freely dissolved concentration of each quantified pyrethroid pesticide in a sample may be directly measured or estimated using partition coefficients. Methods for direct measurement must be approved by the Executive Officer before they are used to determine the freely dissolved pyrethroid concentrations that are used for determining exceedances of the pyrethroid pesticides numeric triggers.

To estimate the freely dissolved concentration of a pyrethroid pesticide with partition coefficients, the following equation shall be used:

$$C_{dissolved} = \frac{C_{total}}{1 + (K_{OC} \times [POC]) + (K_{DOC} \times [DOC])}$$

Where:

C dissolved = concentration of a an individual pyrethroid pesticide that is in the freely dissolved phase (ng/L),

C total = total concentration of an individual pyrethroid pesticide in water (ng/L),

KOC = organic carbon-water partition coefficient for the individual pyrethroid pesticide (L/kg),

[POC] = concentration of particulate organic carbon in the water sample (kg/L), which can be calculated as [POC]=[TOC]-[DOC],

[TOC] = total organic carbon in the sample (kg/L)

KDOC = dissolved organic carbon-water partition coefficient (L/kg),

[DOC] = concentration of dissolved organic carbon in the sample (kg/L).

Site-specific or alternative study-based partition coefficients approved by the Executive Officer may be used for KOC and KDOC in the above equation. If site-specific or alternative study-based partition coefficients are not available or have not been approved, the following partition coefficients shall be used for KOC and KDOC in the above equation:

**Table E-9. Pyrethroid Pesticide Partition Coefficients**

Pyrethroid Pesticide	Receiving water KOC (L/kg)	Receiving water KDOC (L/kg)	Effluent KOC (L/kg)	Effluent KDOC (L/kg)
Bifenthrin	4,228,000	1,737,127	15,848,932	800,000
Cyfluthrin	3,870,000	2,432,071	3,870,000	2,432,071
Cypermethrin	3,105,000	762,765	6,309,573	200,000
Esfenvalerate	7,220,000	1,733,158	7,220,000	1,733,158
Lambda-cyhalothrin	2,056,000	952,809	7,126,428	200,000
Permethrin	6,075,000	957,703	10,000,000	200,000

- 2. Water Column Toxicity Monitoring Requirements.** When discharging to the Feather River at Discharge Point 001, the Discharger shall monitor the toxicity of the downstream receiving water at monitoring location RSW-002 using U.S. EPA method EPA-821-R-02-012 (Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, USEPA, October 2002, or most recent edition). Except as specified in this order, water column toxicity testing shall follow the measurement quality objectives provided in the Surface Water Ambient Monitoring Program (SWAMP) Quality Assurance Program Plan (SWRCB, 2018). When feasible, the Discharger shall use the Southern California Coastal Water Research Project (SCCWRP) guidance (Schiff and Greenstein, 2016) on test organism age and size for *Hyaella azteca*.

For consistency with U.S. EPA Method EPA-821-R-02-012 and ELAP accreditation, *Hyaella Azteca* water column toxicity testing for baseline monitoring must be performed at 20 degrees Celsius.

**Quarterly monitoring shall be conducted for one year** concurrent with the Pyrethroid Pesticides Water Column Chemistry Monitoring during Effluent and Receiving Water Characterization Monitoring (see section IX.D of this MRP for specific dates) to the extent practicable. Downstream receiving water monitoring shall be conducted at monitoring location RSW-002, during periods of discharge to the Feather River at Discharge Point 001 and the results of such monitoring shall be submitted to the Central Valley Water Board with the quarterly self-

monitoring reports. Monitoring can either be conducted by the Discharger or as part of a group monitoring effort. If the Discharger chooses to participate in a group monitoring effort, the timing of the monitoring can be modified by the Executive Officer.

**D. Effluent and Receiving Water Characterization**

**1. Monitoring Frequency**

- a. **Effluent Sampling.** Samples shall be collected from the effluent (Monitoring Location EFF-001) **quarterly between 1 April 2024 and 31 March 2025.**
- b. **Receiving Water Sampling.** Samples shall be collected from the upstream receiving water (Monitoring Location RSW-001) **quarterly between 1 April 2024 and 31 March 2025.**

2. **Analytical Methods.** Constituents shall be collected and analyzed consistent with the Discharger’s Analytical Methods Report (MRP, X.D.1) using sufficiently sensitive analytical methods and Reporting Levels (RLs) per the SSM Rule specified in 40 C.F.R. 122.21(e)(3) and 122.44(i)(1)(iv). The “Reporting Level” is synonymous with the “Method Minimum Level” described in the SSM Rule. The results of the monitoring shall be submitted to the Central Valley Water Board with the quarterly self-monitoring reports. Each individual monitoring event shall provide representative sample results for the effluent and upstream receiving water.

3. **Analytical Methods Report Certification.** Prior to beginning the Effluent and Receiving Water Characterization monitoring, the Discharger shall provide a certification acknowledging the scheduled start date of the Effluent and Receiving Water Characterization monitoring and confirming that samples will be collected and analyzed as described in the previously submitted Analytical Methods Report. If there are changes to the previously submitted Analytical Methods Report, the Discharger shall outline those changes. A one-page certification form will be provided by Central Valley Water Board staff with the permit’s Notice of Adoption that the Discharger can use to satisfy this requirement. The certification form shall be submitted electronically via CIWQS submittal by the due date in the Technical Reports Table E-13.

4. The Discharger shall conduct effluent and receiving water characterization monitoring in accordance with Table E-10 and the testing requirements described in section IX.D.5 below.

**Table E-10. Effluent and Receiving Water Characterization Monitoring**

**VOLATILE ORGANICS**

CTR Number	Volatile Organic Parameters	CAS Number	Units	Effluent Sample Type
25	2-Chloroethyl vinyl Ether	110-75-8	µg/L	Grab

CTR Number	Volatile Organic Parameters	CAS Number	Units	Effluent Sample Type
17	Acrolein	107-02-8	µg/L	Grab
18	Acrylonitrile	107-13-1	µg/L	Grab
19	Benzene	71-43-2	µg/L	Grab
20	Bromoform	75-25-2	µg/L	Grab
21	Carbon Tetrachloride	56-23-5	µg/L	Grab
22	Chlorobenzene	108-90-7	µg/L	Grab
24	Chloroethane	75-00-3	µg/L	Grab
26	Chloroform	67-66-3	µg/L	Grab
35	Methyl Chloride	74-87-3	µg/L	Grab
23	Dibromochloromethane	124-48-1	µg/L	Grab
27	Dichlorobromomethane	75-27-4	µg/L	Grab
36	Methylene Chloride	75-09-2	µg/L	Grab
33	Ethylbenzene	100-41-4	µg/L	Grab
89	Hexachlorobutadiene	87-68-3	µg/L	Grab
34	Methyl Bromide (Bromomethane)	74-83-9	µg/L	Grab
94	Naphthalene	91-20-3	µg/L	Grab
38	Tetrachloroethylene (PCE)	127-18-4	µg/L	Grab
39	Toluene	108-88-3	µg/L	Grab
40	trans-1,2-Dichloroethylene	156-60-5	µg/L	Grab
43	Trichloroethylene (TCE)	79-01-6	µg/L	Grab
44	Vinyl Chloride	75-01-4	µg/L	Grab
21	Methyl-tert-butyl ether (MTBE)	1634-04-4	µg/L	Grab
41	1,1,1-Trichloroethane	71-55-6	µg/L	Grab
42	1,1,2-Trichloroethane	79-00-5	µg/L	Grab
28	1,1-Dichloroethane	75-34-3	µg/L	Grab
30	1,1-Dichloroethylene (DCE)	75-35-4	µg/L	Grab
31	1,2-Dichloropropane	78-87-5	µg/L	Grab
32	1,3-Dichloropropylene	542-75-6	µg/L	Grab
37	1,1,2,2-Tetrachloroethane	79-34-5	µg/L	Grab
101	1,2,4-Trichlorobenzene	120-82-1	µg/L	Grab
29	1,2-Dichloroethane	107-06-2	µg/L	Grab
75	1,2-Dichlorobenzene	95-50-1	µg/L	Grab
76	1,3-Dichlorobenzene	541-73-1	µg/L	Grab
77	1,4-Dichlorobenzene	106-46-7	µg/L	Grab

**SEMI-VOLATILE ORGANICS**

CTR Number	Semi-Organic Volatile Parameters	CAS Number	Units	Effluent Sample Type
60	Benzo(a)Anthracene	56-55-3	µg/L	Grab
85	1,2-Diphenylhydrazine	122-66-7	µg/L	Grab
45	2-Chlorophenol	95-57-8	µg/L	Grab
46	2,4-Dichlorophenol	120-83-2	µg/L	Grab

CTR Number	Semi-Organic Volatile Parameters	CAS Number	Units	Effluent Sample Type
47	2,4-Dimethylphenol	105-67-9	µg/L	Grab
49	2,4-Dinitrophenol	51-28-5	µg/L	Grab
82	2,4-Dinitrotoluene	121-14-2	µg/L	Grab
55	2,4,6-Trichlorophenol	88-06-2	µg/L	Grab
83	2,6-Dinitrotoluene	606-20-2	µg/L	Grab
50	2-Nitrophenol	88-75-5	µg/L	Grab
71	2-Chloronaphthalene	91-58-7	µg/L	Grab
78	3,3-Dichlorobenzidine	91-94-1	µg/L	Grab
62	Benzo(b)Fluoranthene	205-99-2	µg/L	Grab
52	4-Chloro-3-methylphenol	59-50-7	µg/L	Grab
48	2-Methyl-4,6-Dinitrophenol	534-52-1	µg/L	Grab
51	4-Nitrophenol	100-02-7	µg/L	Grab
69	4-Bromophenyl Phenyl Ether	101-55-3	µg/L	Grab
72	4-Chlorophenyl Phenyl Ether	7005-72-3	µg/L	Grab
56	Acenaphthene	83-32-9	µg/L	Grab
57	Acenaphthylene	208-96-8	µg/L	Grab
58	Anthracene	120-12-7	µg/L	Grab
59	Benzidine	92-87-5	µg/L	Grab
61	Benzo(a)Pyrene	50-32-8	µg/L	Grab
63	Benzo(ghi)Perylene	191-24-2	µg/L	Grab
64	Benzo(k)Fluoranthene	207-08-9	µg/L	Grab
65	Bis (2-Chloroethoxy) Methane	111-91-1	µg/L	Grab
66	Bis (2-Chloroethyl) Ether	111-44-4	µg/L	Grab
67	Bis (2-Chloroisopropyl) Ether	108-60-1	µg/L	Grab
68	Bis(2-Ethylhexyl) Phthalate	117-81-7	µg/L	Grab
70	Butylbenzyl Phthalate	85-68-7	µg/L	Grab
73	Chrysene	218-01-9	µg/L	Grab
81	Di-n-butyl Phthalate	84-74-2	µg/L	Grab
84	Di-n-Octyl Phthalate	117-84-0	µg/L	Grab
74	Dibenzo(a,h)anthracene	53-70-3	µg/L	Grab
79	Diethyl Phthalate	84-66-2	µg/L	Grab
80	Dimethyl Phthalate	131-11-3	µg/L	Grab
86	Fluoranthene	206-44-0	µg/L	Grab
87	Fluorene	86-73-7	µg/L	Grab
88	Hexachlorobenzene	118-74-1	µg/L	Grab
90	Hexachlorocyclopentadiene	77-47-4	µg/L	Grab
91	Hexachloroethane	67-72-1	µg/L	Grab
92	Indeno(1,2,3-cd) Pyrene	193-39-5	µg/L	Grab
93	Isophorone	78-59-1	µg/L	Grab
98	N-Nitrosodiphenylamine	86-30-6	µg/L	Grab
96	N-Nitrosodimethylamine	62-75-9	µg/L	Grab
97	N-Nitrosodi-n-Propylamine	621-64-7	µg/L	Grab
95	Nitrobenzene	98-95-3	µg/L	Grab

CTR Number	Semi-Organic Volatile Parameters	CAS Number	Units	Effluent Sample Type
53	Pentachlorophenol (PCP)	87-86-5	µg/L	Grab
99	Phenanthrene	85-01-8	µg/L	Grab
54	Phenol	108-95-2	µg/L	Grab
100	Pyrene	129-00-0	µg/L	Grab

**INORGANICS**

CTR Number	Inorganic Parameters	CAS Number	Units	Effluent Sample Type
NL	Aluminum	7429-90-5	µg/L	24-hour Composite
1	Antimony, Total	7440-36-0	µg/L	24-hour Composite
2	Arsenic, Total	7440-38-2	µg/L	24-hour Composite
15	Asbestos	1332-21-4	µg/L	24-hour Composite
3	Beryllium, Total	7440-41-7	µg/L	24-hour Composite
4	Cadmium, Total	7440-43-9	µg/L	24-hour Composite
5a	Chromium, Total	7440-47-3	µg/L	24-hour Composite
6	Copper, Total	7440-50-8	µg/L	24-hour Composite
14	Iron, Total	7439-89-6	µg/L	24-hour Composite
7	Lead, Total	7439-92-1	µg/L	24-hour Composite
8	Mercury, Total	7439-97-6	µg/L	Grab
NL	Mercury, Methyl	22967-92-6	µg/L	Grab
NL	Manganese, Total	7439-96-5	µg/L	24-hour Composite
9	Nickel, Total	7440-02-0	µg/L	24-hour Composite
10	Selenium, Total	7782-49-2	µg/L	24-hour Composite
11	Silver, Total	7440-22-4	µg/L	24-hour Composite
12	Thallium, Total	7440-28-0	µg/L	24-hour Composite
13	Zinc, Total	7440-66-6	µg/L	24-hour Composite

**NON-METALS/MINERALS**

CTR Number	Non-Metal/Mineral Parameters	CAS Number	Units	Effluent Sample Type
NL	Boron	7440-42-8	µg/L	24-hour Composite
NL	Chloride	16887-00-6	mg/L	24-hour Composite
14	Cyanide, Total (as CN)	57-12-5	µg/L	Grab
NL	Sulfate	14808-79-8	mg/L	24-hour Composite
NL	Sulfide (as S)	5651-88-7	mg/L	24-hour Composite

**PESTICIDES/PCBs/DIOXINS**

CTR Number	Pesticide/PCB/Dioxin Parameters	CAS Number	Units	Effluent Sample Type
110	4,4-DDD	72-54-8	µg/L	24-hour Composite
109	4,4-DDE	72-55-9	µg/L	24-hour Composite

CTR Number	Pesticide/PCB/Dioxin Parameters	CAS Number	Units	Effluent Sample Type
108	4,4-DDT	50-29-3	µg/L	24-hour Composite
112	alpha-Endosulfan	959-98-8	µg/L	24-hour Composite
103	alpha-BHC (Benzene hexachloride)	319-84-6	µg/L	24-hour Composite
102	Aldrin	309-00-2	µg/L	24-hour Composite
113	beta-Endosulfan	33213-65-9	µg/L	24-hour Composite
104	beta-BHC (Benzene hexachloride)	319-85-7	µg/L	24-hour Composite
107	Chlordane	57-74-9	µg/L	24-hour Composite
106	delta-BHC (Benzene hexachloride)	319-86-8	µg/L	24-hour Composite
111	Dieldrin	60-57-1	µg/L	24-hour Composite
114	Endosulfan Sulfate	1031-07-8	µg/L	24-hour Composite
115	Endrin	72-20-8	µg/L	24-hour Composite
116	Endrin Aldehyde	7421-93-4	µg/L	24-hour Composite
117	Heptachlor	76-44-8	µg/L	24-hour Composite
118	Heptachlor Epoxide	1024-57-3	µg/L	24-hour Composite
105	gamma-BHC (Benzene hexachloride or Lindane)	58-89-9	µg/L	24-hour Composite
119	Polychlorinated Biphenyl (PCB) 1016	12674-11-2	µg/L	24-hour Composite
120	PCB 1221	11104-28-2	µg/L	24-hour Composite
121	PCB 1232	11141-16-5	µg/L	24-hour Composite
122	PCB 1242	53469-21-9	µg/L	24-hour Composite
123	PCB 1248	12672-29-6	µg/L	24-hour Composite
124	PCB 1254	11097-69-1	µg/L	24-hour Composite
125	PCB 1260	11096-82-5	µg/L	24-hour Composite
126	Toxaphene	8001-35-2	µg/L	24-hour Composite
16	2,3,7,8-TCDD (Dioxin)	1746-01-6	mg/L	24-hour Composite

**CONVENTIONAL PARAMETERS**

CTR Number	Conventional Parameters	CAS Number	Units	Effluent Sample Type
NL	pH	--	SU	Grab
NL	Temperature	--	°C	Grab

**NON-CONVENTIONAL PARAMETERS**

CTR Number	Nonconventional Parameters	CAS Number	Units	Effluent Sample Type
NL	Foaming Agents (MBAS)	MBAS	mg/L	24-hour Composite
NL	Hardness (as CaCO <sub>3</sub> )	471-34-1	mg/L	Grab
NL	Specific Conductance (Electrical Conductivity or EC)	EC	µmhos/cm	24-hour Composite
NL	Total Dissolved Solids (TDS)	TDS	mg/L	24-hour Composite
NL	Dissolved Organic Carbon (DOC)	DOC	mg/L	24-hour Composite

**NUTRIENTS**

CTR Number	Nutrient Parameters	CAS Number	Units	Effluent Sample Type
NL	Ammonia (as N)	7664-41-7	mg/L	24-hour Composite
NL	Nitrate (as N)	14797-55-8	mg/L	24-hour Composite
NL	Nitrite (as N)	14797-65-0	mg/L	24-hour Composite
NL	Phosphorus, Total (as P)	7723-14-0	mg/L	24-hour Composite

**OTHER CONSTITUENTS OF CONCERN**

CTR Number	Other Constituents of Concern	CAS Number	Units	Effluent Sample Type
NL	1,2,3-Trichloropropane (TCP)	96-18-4	µg/L	Grab
NL	Trichlorofluoromethane	75-69-4	µg/L	Grab
NL	1,1,2-Trichloro-1,2,2-Trifluoroethane	76-13-1	µg/L	Grab
NL	Styrene	100-42-5	µg/L	Grab
NL	Xylenes	1330-20-7	µg/L	Grab
NL	Barium	7440-39-3	µg/L	24-hour Composite
NL	Fluoride	16984-48-8	mg/L	24-hour Composite
NL	Molybdenum	7439-98-7	µg/L	24-hour Composite
NL	Tributyltin	688-73-3	µg/L	24-hour Composite
NL	Alachlor	15972-60-8	µg/L	24-hour Composite
NL	Atrazine	1912-24-9	µg/L	24-hour Composite
NL	Bentazon	25057-89-0	µg/L	24-hour Composite
NL	Carbofuran	1563-66-2	µg/L	24-hour Composite
NL	2,4-D	94-75-7	µg/L	24-hour Composite
NL	Dalapon	75-99-0	µg/L	24-hour Composite
NL	1,2-Dibromo-3-chloropropane (DBCP)	96-12-8	µg/L	24-hour Composite

CTR Number	Other Constituents of Concern	CAS Number	Units	Effluent Sample Type
NL	Di(2-ethylhexyl)adipate	103-23-1	µg/L	24-hour Composite
NL	Dinoseb	88-85-7	µg/L	24-hour Composite
NL	Diquat	85-00-7	µg/L	24-hour Composite
NL	Endothal	145-73-3	µg/L	24-hour Composite
NL	Ethylene Dibromide (EDB)	106-93-4	µg/L	24-hour Composite
NL	Methoxychlor	72-43-5	µg/L	24-hour Composite
NL	Molinate (Ordram)	2212-67-1	µg/L	24-hour Composite
NL	Oxamyl	23135-22-0	µg/L	24-hour Composite
NL	Picloram	1918-02-1	µg/L	24-hour Composite
NL	Simazine (Princep)	122-34-9	µg/L	24-hour Composite
NL	Thiobencarb	28249-77-6	µg/L	24-hour Composite
NL	2,4,5-TP (Silvex)	93-72-1	µg/L	24-hour Composite
NL	Chlorpyrifos	2921-88-2	µg/L	24-hour Composite
NL	Diazinon	333-41-5	µg/L	24-hour Composite

5. **Table E-10 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-10:
- a. **Applicable to All Parameters.** Pollutants shall be analyzed using the analytical methods described in 40 C.F.R. Part 136 or by methods approved by the Central Valley Water Board or the State Water Board.
  - b. **Grab Samples.** A grab sample is defined as an individual discrete sample collected over a period of time not exceeding 15 minutes. It can be taken manually, using a pump, scoop, vacuum, or other suitable device.
  - c. **24-hour Composite Samples.** All 24-hour composite samples shall be collected from a 24-hour flow proportional composite.
  - d. **Redundant Sampling.** The Discharger is not required to conduct effluent monitoring for constituents that have already been sampled in a given month, as required in Table E-3, with the exception of hardness which shall be sampled concurrently with the hardness-dependent metals (cadmium, chromium III, lead, nickel, silver, and zinc).
  - e. **Concurrent Sampling.** Effluent and receiving water sampling shall be performed at approximately the same time, on the same date.
  - f. **Sample Type.** All receiving water samples shall be taken as grab samples. Effluent samples shall be taken as described in Table E-10.
  - g. **Bis (2-ethylhexyl) phthalate.** In order to verify if bis (2-ethylhexyl) phthalate is truly present, the Discharger shall take steps to assure that sample containers, sampling apparatus, and analytical equipment are not sources of the detected contaminant.
  - h. **Total Mercury and Methyl Mercury.** Unfiltered methyl mercury and total mercury samples shall be taken using clean hands/dirty hands procedures, as described in U.S. EPA method 1669: Sampling Ambient Water for Trace

Metals at EPA Water Quality Criteria Levels, for collection of equipment blanks (section 9.4.4.2). The analysis of methyl mercury and total mercury shall be by U.S. EPA method 1630 and 1631 (Revision E), respectively, with a reporting limit of 0.05 ng/L for methyl mercury and 0.5 ng/L for total mercury.

- i. **Ammonia (as N).** Sampling is only required in the upstream receiving water.
- j. **Chlorpyrifos and Diazinon** shall be sampled using U.S. EPA Method 625M, Method 8141, or equivalent GC/MS method with a lower Reporting Limit than the Basin Plan Water Quality Objectives of 0.015 µg/L and 0.1 µg/L for chlorpyrifos and diazinon, respectively.

**E. Percolation Ponds**

- 1. **Monitoring Locations PND-001 through PND-005.** The Discharger shall monitor the percolation ponds when water is present at Monitoring Locations PND-001 through PND-005 as follows:

**Table E-11 Percolation Ponds Monitoring Requirements**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Water Present	Yes/No	Observation	1/Week
Discharge to Ponds	Yes/No	Observation	1/Week
Freeboard	Feet	Measure	1/Week
Dissolved Oxygen	mg/L	Grab	1/Week
Odors	--	Observation	1/Week

- 2. **Table E-11 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-11:
  - a. **Applicable to all parameters.** Parameters shall be analyzed using the analytical methods described in 40 CFR part 136; or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.
  - b. **Dissolved Oxygen.** Samples shall be collected at a depth of one foot from each pond in use, opposite the inlet, and analyzed for dissolved oxygen. If dissolved oxygen results for any pond in use indicate noncompliance with the discharge specification, the Discharger shall implement corrective measures as specified in the operation and maintenance manual and monitor said pond daily until its dissolved oxygen stabilizes above 1 mg/L. If there is insufficient pond depth to accurately measure the dissolved oxygen concentration, the Discharger shall include in its report the pond depth and an explanation why dissolved oxygen monitoring was not performed.

- c. **Freeboard.** Freeboard, as defined in Provision VI.C.4.c.v, shall be monitored to the nearest tenth of a foot.
- d. **Handheld Field Meter.** A handheld field meter may be used for **dissolved oxygen**, provided the meter utilizes a U.S. EPA-approved algorithm/method and is calibrated and maintained in accordance with the manufacturer's instructions. A calibration and maintenance log for each meter used for monitoring required by this Monitoring and Reporting Program shall be maintained at the Facility.

## X. REPORTING REQUIREMENTS

### A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. Upon written request of the Central Valley Water Board, the Discharger shall submit a summary monitoring report. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year(s).
3. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Central Valley Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Central Valley Water Board by letter when it returns to compliance with the compliance time schedule.
4. The Discharger shall report to the Central Valley Water Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act" of 1986.

### B. Self-Monitoring Reports (SMRs)

1. The Discharger shall electronically submit SMRs using the State Water Board's [California Integrated Water Quality System \(CIWQS\) Program website](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/) ([http://www.waterboards.ca.gov/water\\_issues/programs/ciwqs/](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/)). The CIWQS website will provide additional information for SMR submittal in the event there will be a planned service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Discharger shall submit monthly, quarterly, and annual SMRs including the results of all required monitoring using U.S. EPA-approved test methods or other test methods specified in this Order. SMRs are to include all new monitoring results obtained since the last SMR was submitted. If the Discharger monitors any pollutant more frequently than required

by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR. Monthly SMRs are required even if there is no discharge. If no discharge occurs during the month, the monitoring report must be submitted stating that there has been no discharge.

- Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

**Table E-12. Monitoring Periods and Reporting Schedule**

Sampling Frequency	Monitoring Period Begins On	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with Monthly SMR
1/Day	Permit effective date	Midnight through 11:59 PM or any 24-hour period that reasonably represents a calendar day for purposes of sampling	Submit with Monthly SMR
1/Week, 2/Week, 3/Week	Permit effective date	Sunday through Saturday	Submit with Monthly SMR
1/Month	Permit effective date	1st day of calendar month through last day of calendar month	First day of second calendar month following month of sampling
2/Month	Permit effective date	1st day of calendar month through the 15 <sup>th</sup> day of the calendar month and the 16 <sup>th</sup> day through the last day of the calendar month	Submit with Monthly SMR
1/Quarter	Permit effective date	1 January through 31 March 1 April through 30 June 1 July through 30 September 1 October through 31 December	1 May 1 August 1 November 1 February of following year
2/Year	Permit effective date	1 January through 30 June 1 July through 31 December	1 August 1 February of following year
1/Year	Permit effective date	1 January through 31 December	1 February of following year

- Reporting Protocols.** The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current laboratory's Method Detection Limit (MDL), as determined by the procedure in 40 C.F.R. part 136.

The Discharger shall report the results of analytical determinations for the

presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy ( $\pm$  a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
  - d. Dischargers are to instruct laboratories to establish calibration standards so that the Minimum Level (ML) value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
5. **Multiple Sample Data.** When determining compliance with an AMEL, AWEL, or MDEL and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
  - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower

of the two data points where DNQ is lower than a value and ND is lower than DNQ.

6. **The Discharger shall submit SMRs** in accordance with the following requirements:
  - a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
  - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the waste discharge requirements; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
  - c. The Discharger shall attach all final laboratory reports from all contracted commercial laboratories, including quality assurance/quality control information, with all its SMRs for which sample analyses were performed.
7. The Discharger shall submit in the SMRs calculations and reports in accordance with the following requirements:
  - a. **Removal Efficiency (BOD<sub>5</sub> and TSS).** The Discharger shall calculate and report the percent removal of BOD<sub>5</sub> and TSS in the SMRs. The percent removal shall be calculated as specified in section VII.A of the Waste Discharge Requirements.
  - b. **Total Coliform Organisms Effluent Limitations.** The Discharger shall calculate and report the 7-day median of total coliform organisms for the effluent. The 7-day median of total coliform organisms shall be calculated as specified in section VII.D of the Waste Discharge Requirements.
  - c. **Dissolved Oxygen Receiving Water Limitations.** The Discharger shall report monthly in the self-monitoring report the dissolved oxygen concentrations in the effluent (EFF-001) and the receiving water (Monitoring Locations RSW-001 and RSW-002).
  - d. **Turbidity Receiving Water Limitations.** The Discharger shall calculate and report the turbidity increase in the receiving water applicable to the natural turbidity condition specified in section V.A.17.a-e. of the Waste Discharge Requirements.

### C. Discharge Monitoring Reports (DMRs)

1. DMRs are U.S. EPA reporting requirements. The Discharger shall electronically certify and submit DMRs together with SMRs using Electronic Self-Monitoring Reports module eSMR 2.5 or any upgraded version. Electronic DMR submittal will be in addition to electronic SMR submittal.

[Information about electronic DMR submittal](http://www.waterboards.ca.gov/water_issues/programs/discharge_monitoring/)

([http://www.waterboards.ca.gov/water\\_issues/programs/discharge\\_monitoring/](http://www.waterboards.ca.gov/water_issues/programs/discharge_monitoring/)) is available on the Internet.

### D. Other Reports

1. **Analytical Methods Report.** The Discharger shall complete and submit an Analytical Methods Report, electronically via CIWQS submittal, by the due date shown in the Technical Reports Table E-13. The Analytical Methods Report shall include the following for each constituent to be monitored in accordance with this Order: 1) applicable water quality objective, 2) reporting level (RL), 3) method detection limit (MDL), and 4) analytical method. The analytical methods shall be sufficiently sensitive with RLs consistent with the SSM Rule per 40 C.F.R. 122.21(e)(3) and 122.44(i)(1)(iv), and with the Minimum Levels (MLs) in the SIP, Appendix 4. The "Reporting Level or RL" is synonymous with the "Method Minimum Level" described in the SSM Rule. If an RL is not less than or equal to the applicable water quality objective for a constituent, the Discharger shall explain how the proposed analytical method complies with the SSM Rule as outlined above in Attachment E, Section I.F. Central Valley Water Board staff will provide a tool with the permit's Notice of Adoption to assist the Discharger in completing this requirement. The tool will include the constituents and associated applicable water quality objectives to be included in the Analytical Methods Report.
2. **Annual Operations Report.** The Discharger shall submit a written report to the Central Valley Water Board, electronically via CIWQS submittal, containing the following by the due date in the Technical Reports Table E-13:
  - a. The names, certificate grades, and general responsibilities of all persons employed at the Facility.
  - b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
  - c. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration.
  - d. A statement certifying whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last revised and last reviewed for adequacy.

- e. The Discharger may also be requested to submit an annual report to the Central Valley Water Board with both tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the compliance record. If violations have occurred, the report shall also discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

3. **Recycled Water Policy Annual Reports.** In accordance with Section 3 of the Water Quality Control Policy for Recycled Water (Recycled Water Policy), the Discharger shall electronically submit an annual report of monthly data to the State Water Board by 30 April annually covering the previous calendar year using the State Water Board's [GeoTracker website](https://geotracker.waterboards.ca.gov/) (<https://geotracker.waterboards.ca.gov/>). Information for setting up and using the GeoTracker system can be found in the *ESI Guide for Responsible Parties* document on the State Water Board's website for [Electronic Submittal of Information](https://www.waterboards.ca.gov/ust/electronic_submittal/index.html) ([https://www.waterboards.ca.gov/ust/electronic\\_submittal/index.html](https://www.waterboards.ca.gov/ust/electronic_submittal/index.html)).

The annual report to GeoTracker must include volumetric reporting of the items listed in Section 3.2 of the [Recycled Water Policy](https://www.waterboards.ca.gov/board_decisions/adopted_orders/resolutions/2018/121118_7_final_amendment_oal.pdf) ([https://www.waterboards.ca.gov/board\\_decisions/adopted\\_orders/resolutions/2018/121118\\_7\\_final\\_amendment\\_oal.pdf](https://www.waterboards.ca.gov/board_decisions/adopted_orders/resolutions/2018/121118_7_final_amendment_oal.pdf)). A pdf of the upload confirmation from GeoTracker for the Recycled Water Policy Annual Report shall be uploaded into CIWQS annually as a technical report per Table E-15, to demonstrate compliance with this reporting requirement.

4. **Report of Waste Discharge (ROWD).** For the 5-year permit renewal, the Discharger shall submit a written report to the Central Valley Water Board, electronically via CIWQS submittal, containing, at minimum, the following by the due date in the Technical Reports Table E-13:
  - a. Report of Waste Discharge (Form 200);
  - b. NPDES Form 1 (not needed if submitting Form 2A);
  - c. NPDES Form 2A;
  - d. NPDES Form 2S;
  - e. **Salinity Evaluation and Minimization Plan (SEMP).** The Discharger shall evaluate the effectiveness of the SEMP and provide a summary with the Report of Waste Discharge;
  - f. **Mixing Zone Requests.** A mixing zone analysis for constituents the Discharger is requesting the continuation of dilution credits and mixing zones in the calculation of water quality-based effluent limits (e.g., chlorodibromomethane and dichlorobromomethane);

- g. **Local Limits Evaluation.** In accordance with 40 C.F.R. section 122.44(j)(2)(ii) the Discharger shall provide a written technical evaluation of the need to revise the local limits under 40 C.F.R. section 403.5(c)(1); and,
  - h. **Most Sensitive Species Screening Study.** See section VI.C.2.c of the Waste Discharge Requirements.
  - i. **Groundwater Monitoring Well Study.** See section VI.C.2.d of the Waste Discharge Requirements.
5. **Annual Pretreatment Reporting Requirements.** The Discharger shall submit annually a report to the Central Valley Water Board, with copies to U.S. EPA Region 9 and the State Water Board, describing the Discharger's pretreatment activities over the previous 12 months (1 January through 31 December). In the event that the Discharger is not in compliance with any conditions or requirements of this Order, including noncompliance with pretreatment audit/compliance inspection requirements, then the Discharger shall also include the reasons for noncompliance and state how and when the Discharger shall comply with such conditions and requirements.

An annual report shall be submitted by the due date shown in the Technical Reports Table E-13 and include at least the following items:

- a. A summary of analytical results from representative sampling of the POTW's influent and effluent for those pollutants U.S. EPA has identified under section 307(a) of the CWA which are known or suspected to be discharged by nondomestic users. This will consist of an annual full priority pollutant scan. The sample types for each priority pollutant constituent shall be consistent with the sample types specified in Table E-11 (Effluent and Receiving Water Characterization Monitoring). The Discharger is not required to sample and analyze for asbestos. The Discharger shall submit the results of the annual priority pollutant scan electronically to the Central Valley Water Board using the State Water Board's CIWQS Program Website.

Sludge shall be sampled during the same 24-hour period and analyzed for the same pollutants as the influent and effluent sampling and analysis. The sludge analyzed shall be a **composite sample of a minimum of 12 discrete samples taken at equal time intervals over the 24-hour period or grab sample**. Wastewater and sludge sampling and analysis shall be performed at least annually. The Discharger shall also provide any influent, effluent or sludge monitoring data for nonpriority pollutants which may be causing or contributing to Interference, Pass-Through or adversely impacting sludge quality. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 C.F.R. part 136 and amendments thereto;

- b. A discussion of Upset, Interference, or Pass-Through incidents, if any, at the treatment plant, which the Discharger knows, or suspects were caused by nondomestic users of the POTW. The discussion shall include the reasons why the incidents occurred, the corrective actions taken and, if known, the name and address of, the nondomestic user(s) responsible. The discussion shall also include a review of the applicable pollutant limitations to determine whether any additional limitations, or changes to existing requirements, may be necessary to prevent Pass-Through, Interference, or noncompliance with sludge disposal requirements;
- c. The cumulative number of nondomestic users that the Discharger has notified regarding Baseline Monitoring Reports and the cumulative number of nondomestic user responses;
- d. An updated list of the Discharger's significant industrial users (SIUs) including their names and addresses, or a list of deletions, additions and SIU name changes keyed to a previously submitted list. The Discharger shall provide a brief explanation for each change. The list shall identify the SIUs subject to federal categorical standards by specifying which set(s) of standards are applicable to each SIU. The list shall indicate which SIUs, or specific pollutants from each industry, are subject to local limitations. Local limitations that are more stringent than the federal categorical standards shall also be identified;
- e. The Discharger shall characterize the compliance status through the year of record of each SIU by employing the following descriptions:
  - i. complied with baseline monitoring report requirements (where applicable);
  - ii. consistently achieved compliance;
  - iii. inconsistently achieved compliance;
  - iv. significantly violated applicable pretreatment requirements as defined by 40 C.F.R. section 403.8(f)(2)(vii);
  - v. complied with schedule to achieve compliance (include the date final compliance is required);
  - vi. did not achieve compliance and not on a compliance schedule; and
  - vii. compliance status unknown.
- f. A summary of the inspection and sampling activities conducted by the Discharger during the past year to gather information and data regarding the SIUs. The summary shall include:

- i. The names and addresses of the SIUs subjected to surveillance and an explanation of whether they were inspected, sampled, or both and the frequency of these activities at each user; and
  - ii. The conclusions or results from the inspection or sampling of each industrial user.
- g. The Discharger shall characterize the compliance status of each SIU by providing a list or table which includes the following information:
  - i. Name of SIU;
  - ii. Category, if subject to federal categorical standards;
  - iii. The type of wastewater treatment or control processes in place;
  - iv. The number of samples taken by the POTW during the year;
  - v. The number of samples taken by the SIU during the year;
  - vi. For a SIU subject to discharge requirements for total toxic organics, whether all required certifications were provided;
  - vii. A list of the standards violated during the year. Identify whether the violations were for categorical standards or local limits;
  - viii. Whether the facility is in significant noncompliance (SNC) as defined at 40 C.F.R. section 403.8(f)(2)(viii) at any time during the year;
  - ix. A summary of enforcement or other actions taken during the year to return the SIU to compliance. Describe the type of action (e.g., warning letters or notices of violation, administrative orders, civil actions, and criminal actions), final compliance date, and the amount of fines and penalties collected, if any. Describe any proposed actions for bringing the SIU into compliance;
  - x. Restriction of flow to the POTW; and
  - xi. Disconnection from discharge to the POTW.
- h. A brief description of any programs the POTW implements to reduce pollutants from nondomestic users that are not classified as SIUs;
- i. A brief description of any significant changes in operating the pretreatment program which differ from the previous year including, but not limited to, changes concerning: the program's administrative structure, local limits, monitoring program or monitoring frequencies, legal-authority, enforcement policy, funding levels, or staffing levels;

- j. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases; and
- k. A summary of activities to involve and inform the public of the program including a copy of the newspaper notice, if any, required under 40 C.F.R. section 403.8(f)(2)(viii).

Pretreatment Program reports shall be submitted electronically to the Central Valley Water Board via CIWQS submittal and the:

State Water Resources Control Board  
NPDES [Wastewater@waterboards.ca.gov](mailto:Wastewater@waterboards.ca.gov)  
and the  
U.S. EPA Region 9 Pretreatment Coordinator  
[R9Pretreatment@epa.gov](mailto:R9Pretreatment@epa.gov)

6. **Technical Report Submittals.** This Order includes requirements to submit a ROWD, special study technical reports, progress reports, and other reports identified in the MRP (hereafter referred to collectively as “technical reports”). The Technical Reports Table E-13 and subsequent table notes below summarize all technical reports required by this Order and the due dates for submittal. All technical reports shall be submitted electronically via CIWQS submittal. Technical reports should be uploaded as a PDF, Microsoft Word, or Microsoft Excel file attachment.

**Table E-13. Technical Reports**

Report #	Technical Report	Due Date	CIWQS Report Name
Intentionally left blank	Standard Reporting Requirements	Intentionally left blank	Intentionally left blank
1	Report of Waste Discharge	31 January 2027	ROWD
2	Analytical Methods Report	1 April 2023	MRP X.D.1
3	Analytical Methods Report Certification	1 January 2024	MRP IX.D.3.
4	Annual Operations Report	1 February 2023	MRP X.D.2
5	Annual Operations Report	1 February 2024	MRP X.D.2
6	Annual Operations Report	1 February 2025	MRP X.D.2
7	Annual Operations Report	1 February 2026	MRP X.D.2
8	Annual Operations Report	1 February 2027	MRP X.D.2
Intentionally left blank	Other Reports	Intentionally left blank	Intentionally left blank
9	POTW Pretreatment Program	1 February 2025	WDR VI.C.2.b
10	Annual Pretreatment Report	28 February 2026	MRP X.D.6
11	Annual Pretreatment Report	28 February 2027	MRP X.D.6

**ATTACHMENT F – FACT SHEET**

**Table of Contents**

I.	Permit Information .....	F-3
II.	Facility Description .....	F-5
	A. Description of Wastewater and Biosolids Treatment and Controls .....	F-5
	B. Discharge Points and Receiving Waters .....	F-6
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data .....	F-6
	D. Compliance Summary .....	F-10
	E. Planned Changes .....	F-10
III.	Applicable Plans, Policies, and Regulations .....	F-11
	A. Legal Authorities .....	F-11
	B. California Environmental Quality Act (CEQA) .....	F-11
	C. State and Federal Laws, Regulations, Policies, and Plans .....	F-11
	D. Impaired Water Bodies on CWA 303(d) List .....	F-14
	E. Other Plans, Policies and Regulations .....	F-15
IV.	Rationale For Effluent Limitations and Discharge Specifications .....	F-18
	A. Discharge Prohibitions .....	F-18
	B. Technology-Based Effluent Limitations .....	F-19
	1. Scope and Authority .....	F-19
	2. Applicable Technology-Based Effluent Limitations .....	F-20
	C. Water Quality-Based Effluent Limitations (WQBELs) .....	F-21
	1. Scope and Authority .....	F-21
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives .....	F-22
	3. Determining the Need for WQBELs .....	F-33
	4. WQBEL Calculations .....	F-48
	5. Whole Effluent Toxicity (WET) .....	F-51
	D. Final Effluent Limitation Considerations .....	F-54
	1. Mass Based Effluent Limitations – Not Applicable .....	F-54
	2. Averaging Periods for Effluent Limitations .....	F-54
	3. Satisfaction of Anti-Backsliding Requirements .....	F-54
	4. Antidegradation Policies .....	F-56
	5. Stringency of Requirements for Individual Pollutants .....	F-67
	E. Interim Effluent Limitations – Not Applicable .....	F-70
	F. Land Discharge Specifications – Not Applicable .....	F-70
	G. Recycling Specifications – Not Applicable .....	F-70
V.	Rationale for Receiving Water Limitations .....	F-70
	A. Surface Water .....	F-70
	B. Groundwater .....	F-71
VI.	Rationale for Provisions .....	F-72
	A. Standard Provisions .....	F-72
	B. Special Provisions .....	F-72
	1. Reopener Provisions .....	F-72
	2. Special Studies and Additional Monitoring Requirements .....	F-73
	3. Best Management Practices and Pollution Prevention .....	F-77

4. Construction, Operation, and Maintenance Specifications.....	F-78
5. Special Provisions for POTWs.....	F-78
6. Other Special Provisions.....	F-80
7. Compliance Schedules – Not Applicable .....	F-80
VII. Rationale for Monitoring and Reporting Requirements.....	F-80
A. Influent Monitoring .....	F-81
B. Effluent Monitoring.....	F-81
C. Receiving Water Monitoring.....	F-81
1. Surface Water.....	F-81
2. Groundwater .....	F-81
D. Other Monitoring Requirements.....	F-85
VIII. Public Participation .....	F-86
A. Notification of Interested Persons .....	F-86
B. Written Comments .....	F-87
C. Public Hearing .....	F-87
D. Reconsideration of Waste Discharge Requirements.....	F-87
E. Information and Copying.....	F-88
F. Register of Interested Persons .....	F-88
G. Additional Information .....	F-88

**Tables**

Table F-1 Facility Information .....	F-3
Table F-2 Historic Effluent Limitations and Monitoring Data – Discharges to the Ponds, Discharge Point 002 (1.8 MGD).....	F-6
Table F-3 Historic Effluent Limitations and Monitoring Data – Discharges to the Ponds or to the Feather River, Discharge Points 001 and 002 (5.0 MGD) .....	F-8
Table F-4 Basin Plan Beneficial Uses .....	F-12
Table F-5 303 (d) List for the Lower Feather River.....	F-15
Table F-6 pH Groundwater Monitoring Data (standard units).....	F-16
Table F-7 Electrical Conductivity Groundwater Monitoring Data (µmhos/cm) .....	F-16
Table F-8 Fecal Coliform Groundwater Monitoring Data (MPN/100 mL) .....	F-17
Table F-9 Total Nitrogen (as N) Groundwater Monitoring Data (mg/L).....	F-17
Table F-10 Summary of Technology-based Effluent Limitations .....	F-20
Table F-11 Mixing Zones and Dilution Credits.....	F-27
Table F-12 Triggers Associated with Performance-Based Effluent Limitations .....	F-29
Table F-13. Summary of Criteria for CTR Hardness-dependent Metals .....	F-32
Table F-14 Salinity Water Quality Criteria/Objectives.....	F-36
Table F-15 Summary of Water Quality-Based Effluent Limitations.....	F-50
Table F-16 Summary of Final Effluent Limitations .....	F-68
Table F-17 Summary of Monitoring Changes .....	F-83

**ATTACHMENT F – FACT SHEET**

As described in section II.B of this Order, the Central Valley Water Board incorporates this Fact Sheet as findings of the Central Valley Water Board supporting the issuance of this Order. This Fact Sheet discusses the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

**I. PERMIT INFORMATION**

The following table summarizes administrative information related to the Facility.

**Table F-1 Facility Information**

<b>Waste Discharge ID:</b>	5A580100002
<b>CIWQS Facility Place ID:</b>	237060
<b>Discharger:</b>	Linda County Water District
<b>Name of Facility:</b>	Wastewater Treatment Plant
<b>Facility Address:</b>	909 Myrna Avenue
<b>Facility City, State Zip:</b>	Marysville, CA 95901
<b>Facility County:</b>	Yuba County and Sutter County
<b>Facility Contact, Title and Phone Number:</b>	Brian Davis, General Manager, (530) 743-2043
<b>Authorized Person to Sign and Submit Reports:</b>	Brian Davis, General Manager, (530) 743-2043
<b>Mailing Address:</b>	1280 Scales Street, Marysville, CA 95901
<b>Billing Address:</b>	Same as Mailing Address
<b>Type of Facility:</b>	Publicly Owned Treatment Works (POTW)
<b>Major or Minor Facility:</b>	Major
<b>Threat to Water Quality:</b>	2
<b>Complexity:</b>	A
<b>Pretreatment Program:</b>	Yes
<b>Recycling Requirements:</b>	Not Applicable

<b>Facility Permitted Flow:</b>	Existing Plant – 5.0 million gallons per day (MGD) Upgraded and Regionalized Plant – 6.7 MGD
<b>Facility Design Flow:</b>	Existing Plant – 5.0 MGD Upgraded and Regionalized Plant – 6.7 MGD
<b>Watershed:</b>	Lower Feather
<b>Receiving Water:</b>	Feather River
<b>Receiving Water Type:</b>	Inland Surface Water

- A.** The Linda County Water District (hereinafter Discharger) is the owner and operator of the Linda County Water District, Wastewater Treatment Plant (hereinafter Facility), a POTW.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Facility discharges wastewater to the Feather River, a water of the United States, within the Lower Feather watershed. The Discharger was previously regulated by Order R5-2017-0094 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0079651 adopted on 11 August 2017 and expires on 30 September 2022. Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.
- C.** When applicable, state law requires dischargers to file a petition with the State Water Board, Division of Water Rights and receive approval for any change in the point of discharge, place of use, or purpose of use of treated wastewater that decreases the flow in any portion of a watercourse. The State Water Board retains separate jurisdictional authority to enforce any applicable requirements under Water Code section 1211. This is not an NPDES permit requirement.
- D.** The Discharger filed a report of waste discharge (ROWD) and submitted an application for reissuance of its waste discharge requirements (WDRs) and NPDES permit on 9 September 2021. The application was deemed complete on 29 March 2022.
- E.** Regulations at 40 C.F.R. section 122.46 limit the duration of NPDES permits to a fixed term not to exceed five years. Accordingly, Table 3 of this Order limits the duration of the discharge authorization. Under 40 C.F.R. section 122.6(d), States authorized to administer the NPDES program may administratively continue State-issued permits beyond their expiration dates until the effective date of the new permits, if State law allows it. Pursuant to California Code of Regulations (CCR), title 23, section 2235.4, the terms and conditions of an expired permit are automatically continued pending reissuance of the permit if the Discharger complies with all federal NPDES requirements for continuation of expired permits.

## **II. FACILITY DESCRIPTION**

The Discharger provides sewerage service to wastewater customers for the community of Linda, portions of unincorporated Yuba County south of Marysville, and the City of Marysville. The City of Marysville wastewater conveyance to the WWTP began in November 2019. Wastewater primarily consists of domestic residential connections with limited commercial customers. No industrial uses occur within the current service area. The current design average dry weather flow capacity of the Facility is 5.0 MGD. The Discharger is planning a regionalization project with the City of Marysville to accommodate planned and approved growth within the service area. The Discharger anticipates that the current permitted discharger rate is adequate for the service area needs through the next permit term with a current average dry weather flowrate of 2.6 MGD.

### **A. Description of Wastewater and Biosolids Treatment and Controls**

The treatment system at the Facility consists of the headworks, two rectangular primary clarifiers, four air activated sludge basins (that provide nitrification and denitrification), two secondary clarifiers, compressible media filters, a chlorine contact basin, and dechlorination using sulfur dioxide.

The Facility discharges to land using a series of five percolation ponds that lie within the Feather River floodplain. Currently the Discharger discharges to a single pond at a time and once that pond reaches a predetermined level they stop discharging to that pond and start discharging to the next pond in series. They rotate through the five ponds using this sequence, allowing them to perform pond maintenance including discing and mowing prior to reuse. The pond berms have been overtopped during high river stages five times since the Facility was constructed in 1960, most recently in February 2017, resulting in tertiary treated wastewater from the ponds being discharged to the Feather River. The most southeastern point of the Discharger's percolation ponds is approximately 1600 feet upstream from the City of Yuba City's most northern percolation pond. Yuba City is currently discharging to six percolation ponds a majority of the year, while they are working to construct a new diffuser that is submerged year-round, allowing less frequent discharge to their percolation ponds. The Facility currently provides wastewater treatment to a population of approximately 24,000, after the connection of Marysville's collection system to the Discharger's facility in November 2019. The Discharger also maintains a wastewater outfall pipeline terminating on the bank of the Feather River; however, this outfall is rarely used and was not used during the term of previous Order R5-2017-0094.

Solids handling facilities include a rotary drum thickener, two anaerobic digesters, eight sludge drying beds and two facultative sludge lagoons. One of the sludge lagoons is lined with a 60-mil fused HPDE liner and the other sludge lagoon and eight sludge drying beds are concrete lined with waterstops at the construction and expansion joints. The sludge lagoons each have a decant structure that allows liquid to flow to the headworks. The eight drying beds have underdrains that also flow back

to the headworks. Therefore, the sludge lagoons and drying beds are all lined and have drains or decant structures to preventing a release of contaminants to groundwater.

The Discharger has received odor complaints by residents at the north end of the plant, which corresponds to the prevailing wind from the southwest, as the HDPE lined sludge lagoon is unable to be adequately emptied before warm weather months, causing the odors. The HDPE lined lagoon stores a majority of sludge produced in the wet weather months when the drying beds are less efficient. The construction of the new 8-million-gallon concrete-lined flow equalization and sludge storage basin is anticipated to allow the complete draining and drying of sludge from the HDPE lined lagoon, which should help to mitigate future odor complains from nearby residents. Annually, the sludge drying beds are manually cleaned and approximately 400 tons of dewatered solids are disposed of in a landfill. Also, the Discharger has not observed windborne contamination to the chlorine contact basins from the biosolids storage area, especially since the prevailing winds are from the southwest and there is a building just west of the storage area.

**B. Discharge Points and Receiving Waters**

1. The Facility is located in Section 1, T14N, R3E, MDB&M, as shown in Attachment B, a part of this Order.
2. The Facility is permitted to discharge treated municipal wastewater at Discharge Point 001 to the Feather River, a water of the United States at a point latitude 39° 05' 42" N and longitude 121° 35' 32" W.
3. The Facility is permitted to discharge treated municipal wastewater at Discharge Point 002 to the Feather River, a water of the United States, via evaporation and percolation ponds within the floodplain at a point latitude 39° 05' 42" N and longitude 121° 35' 20" W.

**C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data**

Effluent limitations contained in Order R5-2017-0094 for discharges from Discharge Points 001 and 002 and representative monitoring data (Monitoring Location EFF-001) from the term of Order R5-2017-0094 are as follows. Note that the Facility did not discharge at Discharge Point 001 during the term of Order R5-2017-0094.

**Table F-2 Historic Effluent Limitations and Monitoring Data – Discharges to the Ponds, Discharge Point 002 (1.8 MGD)**

Parameter	Units	Historic Effluent Limitations	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Average Dry Weather Flow	MGD	AMEL -- AWEL --	--	--	3.26 (see table note)

Parameter	Units	Historic Effluent Limitations	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
		MDEL 1.8 (see table note 1. below)			2. below)
Biochemical Oxygen Demand (5-day @ 20°C)	mg/L	AMEL 10 AWEL 15 MDEL 20	2	2.2	2.6
Biochemical Oxygen Demand (5-day @ 20°C)	% Removal	AMEL 85 AWEL -- MDEL --	99 (see table note 3. below)	--	--
pH	Standard Units	Instantaneous Minimum 6.0 Instantaneous Maximum 8.0	--	--	6.0 8.0
Total Suspended Solids	mg/L	AMEL 10 AWEL 15 MDEL 20	7	8	11
Total Suspended Solids	% Removal	AMEL 85 AWEL -- MDEL --	97 (see table note 3. below)	--	--
Ammonia Nitrogen Total (as N)	mg/L	AMEL 2.4 AWEL -- MDEL 3.3	<0.2	--	0.47
Nitrate Plus Nitrite (as N)	mg/L	AMEL 10 AWEL -- MDEL --	13.5	--	--
Total Coliform Organisms	MPN/100 ml	AMEL 23 (see table note 4. below) AWEL 2.2 (see table note 5. below) MDEL 240 (see table note 6. below)	--	--	1600
Mercury, Total Recoverable	lbs/year	AMEL 0.19 (see table note 7. below) AWEL -- MDEL --	0.0002	--	--
Diazinon and Chlorpyrifos	µg/L	AMEL (see table note 8. below) AWEL -- MDEL (see table note 9. below)	<0.062	--	<0.062

**Table F-2 Notes:**

1. The average dry weather discharge flow shall not exceed 1.8 MGD.
2. Represents the maximum observed daily discharge flow.
3. Represents the minimum observed percent removal.
4. Not to be exceeded more than once in any 30-day period.
5. Applied as a 7-day median effluent limitation.
6. Applied as an instantaneous maximum effluent limitation.
7. The total annual mass discharge of total mercury shall not exceed 0.19 lbs at 1.8 MGD.
8. Average Monthly Effluent Limit:  

$$\text{SAMEL} = \text{CD M-avg}/0.079 + \text{CC M-avg}/0.012 \leq 1.0$$

CD M-AVG = average monthly diazinon effluent concentration in µg/L.  
 CC M-AVG = average monthly chlorpyrifos effluent concentration in µg/L
9. Average Weekly Effluent Limit:  

$$\text{SAWEL} = \text{CD W-avg}/0.14 + \text{CC W-avg}/0.021 \leq 1.0$$

CD W-AVG = average weekly diazinon effluent concentration in µg/L.  
 CC W-AVG = average weekly chlorpyrifos effluent concentration in µg/L.

**Table F-3 Historic Effluent Limitations and Monitoring Data – Discharges to the Ponds or to the Feather River, Discharge Points 001 and 002 (5.0 MGD)**

Parameter	Units	Historic Effluent Limitations	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
Average Dry Weather Flow	MGD	AMEL -- AWEL -- MDEL 5.0 (see table note 1. below)	--	--	3.68 (see table note 2. below)
Biochemical Oxygen Demand (5-day @ 20°C)	mg/L	AMEL 10 AWEL 15 MDEL 20	6.2	9.3	21
Biochemical Oxygen Demand (5-day @ 20°C)	% Removal	AMEL 85 AWEL -- MDEL --	97 (see table note 3. below)	--	--
pH	Standard Units	Instantaneous Minimum 6.5 at Discharge Point 001 And 6.0 at Discharge Point	--	--	6.0 7.9

Parameter	Units	Historic Effluent Limitations	Highest Average Monthly Discharge	Highest Average Weekly Discharge	Highest Daily Discharge
		002 (see table note 6) Instantaneous Maximum 8.0			
Total Suspended Solids	mg/L	AMEL 10 AWEL 15 MDEL 20	10	14	16
Total Suspended Solids	% Removal	AMEL 85 AWEL -- MDEL --	96 (see table note 3. below)	--	--
Ammonia Nitrogen Total (as N)	mg/L	AMEL 2.4 AWEL -- MDEL 3.3	1.3	--	12
Nitrate Plus Nitrite (as N)	mg/L	AMEL 10 AWEL -- MDEL --	11	--	--
Total Coliform Organisms	MPN/100 ml	AMEL 23 (see table note 4. below) AWEL 2.2 (see table note 5. below) MDEL 240 (see table note 6. below)	--	--	540
Mercury, Total Recoverable	lbs/year	AMEL 0.19 (see table note 7. below) AWEL -- MDEL --	0.0016	--	--
Diazinon and Chlorpyrifos	µg/L	AMEL (see table note 8. below) AWEL -- MDEL (see table note 9. below)	<0.0044	--	<0.0044

**Table F-3 Notes:**

1. The average dry weather discharge flow to the percolation ponds at Discharge Point 002 shall not exceed 1.8 MGD. The average dry weather discharge flow to the Feather River at Discharge Point 001 shall not exceed 5.0 MGD. The total combined average dry weather flow from the Facility at Discharge Points 001 and 002 shall not exceed 5.0 MGD.
2. Represents the maximum observed daily discharge flow.
3. Represents the minimum observed percent removal.
4. Not to be exceeded more than once in any 30-day period.
5. Applied as a 7-day median effluent limitation.

6. Applied as an instantaneous maximum effluent limitation. Effluent data reflect samples collected at Discharge Point 002.
7. The total annual mass discharge of total mercury shall not exceed 0.19 lbs.
8. Average Monthly Effluent Limit:  
$$\text{SAMEL} = \text{CD M-avg}/0.079 + \text{CC M-avg}/0.012 \leq 1.0$$

CD M-AVG = average monthly diazinon effluent concentration in  $\mu\text{g/L}$ .  
CC M-AVG = average monthly chlorpyrifos effluent concentration in  $\mu\text{g/L}$
9. Average Weekly Effluent Limit:  
$$\text{SAWEL} = \text{CD W-avg}/0.14 + \text{CC W-avg}/0.021 \leq 1.0$$

CD W-AVG = average weekly diazinon effluent concentration in  $\mu\text{g/L}$ .  
CC W-AVG = average weekly chlorpyrifos effluent concentration in  $\mu\text{g/L}$ .

#### **D. Compliance Summary**

Since the permit adoption, 11 August 2017, the Discharger was issued 2 Administrative Civil Liability (ACL) orders and 1 Mandatory Minimum Penalty (MMP). The ACLs were based on exceedances of the limits for flow, total ammonia, and total coliform:

1. ACL Order R5-2020-0561 in 2020 for one effluent violation, non-serious violation for exceeding seasonal average flow. The MMPs were assessed to be a total of \$3,000. The Discharger settled the ACL through payment.
2. ACL Order R5-2019-0529 in 2019 for two effluent violations for total ammonia, one Group I Serious violation, and total coliform, one non-serious violation. Exceedances for daily maximum total ammonia and 7-day median total coliform were observed in 2019. The MMPs were assessed to be a total of \$6,000. The Discharger settled the ACL through payment.
3. MMP Order R5-2018-0535 in 2018 for one effluent violation, Group I Serious violation for exceeding average weekly total ammonia. The MMPs were assessed to be a total of \$3,000. The Discharger settled the MMPs through payment.

#### **E. Planned Changes**

The Discharger plans to construct an 8-million-gallon concrete-lined flow equalization and sludge storage basin to allow for temporarily holding peak wet weather flows and sludge storage. This basin will be constructed with waterstops installed at each joint. During the dry months sludge will be spread out in the basin at a height of 12 to 18 inches for drying. During wet months the sludge will be removed to allow the basin to provide the plant with emergency storage of raw or primary treated influent. The new basin will be located within the current Facility footprint adjacent to the two existing sludge lagoons (sludge lagoon No.1 and No.2). It will be bifurcated by a concrete berm with one decant structure located in the

southern half of the basin. This project is began in 2021 and will approximately be completed within a year.

The Discharger is also evaluating the need for additional grit removal to accommodate high influent grit loading during high-flow storm events. Storm flows in 2019 resulted in a surge of grit entering the WWTP that damaged the primary sludge pump, pipelines, and inundated the primary clarifier influent channel and primary sludge collection system. A grit removal study was conducted to inform this treatment process improvement.

These changes are associated with increases in the design capacity of the Facility from 5.0 MGD to 6.7 MGD to accommodate regionalization of flows from the City of Marysville and future growth.

### **III. APPLICABLE PLANS, POLICIES, AND REGULATIONS**

The requirements contained in this Order are based on the requirements and authorities described in this section.

#### **A. Legal Authorities**

This Order serves as WDRs pursuant to article 4, chapter 4, division 7 of the California Water Code (commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. EPA and chapter 5.5, division 7 of the Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this Facility to surface waters.

#### **B. California Environmental Quality Act (CEQA)**

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA, (commencing with section 21100) of Division 13 of the Public Resources Code.

#### **C. State and Federal Laws, Regulations, Policies, and Plans**

1. **Water Quality Control Plan.** Requirements of this Order specifically implement the applicable Water Quality Control Plans.

- a. **Basin Plan.** The Central Valley Water Board adopted a Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fifth Edition, May 2018 OR Tulare Lake Basin, Third Edition, May 2018 (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan. In addition, the Basin Plan implements State Water Board Resolution 88-63, which established state policy that all waters, with certain exceptions, should be

considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to the Feather River are as follows:

**Table F-4 Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Use(s)
001 and 002	Feather River	<u>Existing:</u> Municipal and domestic supply (MUN); agricultural supply, including irrigation and stock watering (AGR); water contact recreation, including canoeing and rafting (REC-1); non-contact water recreation (REC-2); warm freshwater habitat (WARM); cold freshwater habitat (COLD); warm and cold migration of aquatic organisms (MIGR); warm and cold spawning, reproduction, and/or early development (SPWN); and wildlife habitat (WILD).
002	Groundwater	<u>Existing:</u> Municipal and domestic supply (MUN); agricultural supply (AGR); industrial service supply (IND); and industrial process supply (PROC).

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** U.S. EPA adopted the NTR on 22 December 1992, and later amended it on 4 May 1995 and 9 November 1999. About forty criteria in the NTR applied in California. On 18 May 2000, U.S. EPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on 13 February 2001. These rules contain federal water quality criteria for priority pollutants.
3. **State Implementation Policy.** On 2 March 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on 28 April 2000, with respect to the priority pollutant criteria promulgated for California by the U.S. EPA through the NTR and to the priority pollutant objectives established by the Central Valley Water Board in the Basin Plan. The SIP became effective on 18 May 2000, with respect to the priority pollutant criteria promulgated by the U.S. EPA through the CTR. The State Water Board adopted amendments to the SIP on 24 February 2005, that became effective on 13 July 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.

4. **Antidegradation Policy.** Federal regulation 40 C.F.R. section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16 ("Statement of Policy with Respect to Maintaining High Quality of Waters in California") (State Anti-Degradation Policy). The State Anti-Degradation Policy is deemed to incorporate the federal antidegradation policy where the federal policy applies under federal law. The State Anti-Degradation Policy requires that existing water quality be maintained unless degradation is justified based on specific findings. The Central Valley Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of 40 C.F.R. section 131.12 and the State Anti-Degradation Policy. The Board finds this order is consistent with the Federal and State Water Board antidegradation regulations and policy.
5. **Anti-Backsliding Requirements.** Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 C.F.R. section 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
6. **Domestic Water Quality.** In compliance with Water Code section 106.3, it is the policy of the State of California that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This Order promotes that policy by requiring discharges to meet maximum contaminant levels (MCLs) designed to protect human health and ensure that water is safe for domestic use.
7. **Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code, sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
8. **Emergency Planning and Community Right to Know Act.** Section 13263.6(a) of the Water Code, requires that "the Regional Water Board shall prescribe effluent limitations as part of the waste discharge requirements of a POTW for all substances that the most recent toxic chemical release data reported to the state emergency response commission pursuant to section 313 of the Emergency Planning and Community Right to Know Act of 1986 (42 U.S.C. Sec. 11023) (EPCRA) indicate as discharged into the POTW, for which the State Water Board

or the Regional Water Board has established numeric water quality objectives, and has determined that the discharge is or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to, an excursion above any numeric water quality objective”.

The most recent toxic chemical data report does not indicate any reportable off-site releases or discharges to the collection system for this Facility. Therefore, a reasonable potential analysis based on information from EPCRA cannot be conducted. Based on information from EPCRA, there is no reasonable potential to cause or contribute to an excursion above any numeric water quality objectives included within the Basin Plan or in any State Water Board plan, so no effluent limitations are included in this permit pursuant to Water Code section 13263.6(a).

However, as detailed elsewhere in this Order, available effluent data indicate that there are constituents present in the effluent that have a reasonable potential to cause or contribute to exceedances of water quality standards and require inclusion of effluent limitations based on federal and state laws and regulations.

9. **Storm Water Requirements.** U.S. EPA promulgated federal regulations for storm water on 16 November 1990 in 40 C.F.R. parts 122, 123, and 124. The NPDES Industrial Storm Water Program regulates storm water discharges from wastewater treatment facilities. Wastewater treatment plants are applicable industries under the storm water program and are obligated to comply with the federal regulations. The Discharger conducted a Facility upgrade project in 2016, which included modifications to how storm water is collected. Storm water is now collected on site and diverted to six detention basins. The basins are interconnected, and the lowest basin can be emptied directly to the headworks if there is a concern about the basins overtopping. Therefore, the Discharger terminated their coverage under the State Water Board’s Industrial Storm Water General Order because the Facility is designed to no longer allow storm water to leave the site. This Order does not authorize discharges of storm water to waters of the United States. Storm water is regulated in this Order under Waste Discharge Requirements section VI.C.4.d.

#### **D. Impaired Water Bodies on CWA 303(d) List**

1. Under section 303(d) of the 1972 CWA, states, territories, and authorized tribes are required to develop lists of water quality limited segments. The waters on these lists do not meet water quality standards, even after point sources of pollution have installed the minimum required levels of pollution control technology. On 6 April 2018 U.S. EPA gave final approval to California's 2014 – 2016 section 303(d) List of Water Quality Limited Segments. The Basin Plan references this list of Water Quality Limited Segments (WQLSs), which are defined as “...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality

standards even after the application of appropriate limitations for point sources (40 C.F.R. part 130, et seq.).” The Basin Plan also states, “Additional treatment beyond minimum federal standards will be imposed on dischargers to [WQLSs]. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment.” The listing for the Lower Feather River (Lake Oroville Dam to the confluence with the Sacramento River) includes chlorpyrifos, group A pesticides, mercury, polychlorinated biphenyls (PCB’s), and unknown toxicity.

2. **Total Maximum Daily Loads (TMDLs).** Table F-5, below, identifies the 303(d) listings and any applicable TMDLs. This permit includes WQBELs that are consistent with the applicable waste load allocation (WLA) in the Basin Plan Amendment for the Control of Diazinon and Chlorpyrifos Runoff into the Sacramento and Feather Rivers (see this Fact Sheet section IV.C.3.c).

**Table F-5 303 (d) List for the Lower Feather River**

<b>Pollutant</b>	<b>Potential Sources</b>	<b>TMDL Status</b>
Chlorpyrifos	Source Unknown	Planned for Completion
Group A Pesticides	Source Unknown	Planned for Completion
Mercury	Source Unknown	Planned for Completion
PCB’s	Source Unknown	Planned for Completion
Unknown Toxicity	Source Unknown	Planned for Completion

3. The 303(d) listings and TMDLs have been considered in the development of the Order.

**E. Other Plans, Polices and Regulations**

1. **Title 27.** The discharge authorized herein, and the treatment and storage facilities associated with the discharge of treated municipal wastewater, except for discharges of residual sludge and solid waste, are exempt from the requirements of Title 27, CCR, section 20005 et seq (hereafter Title 27). The exemption, pursuant to Title 27 CCR section 20090(a), is based on the following:
  - a. The waste consists primarily of domestic sewage and treated effluent;
  - b. The waste discharge requirements are consistent with water quality objectives; and
  - c. The treatment and storage facilities described herein are associated with a municipal wastewater treatment plant.

The Facility receives influent primarily from domestic sources and the Discharger is currently permitted to discharge up to 5.0 MGD of tertiary treated wastewater to either a series of five unlined percolation ponds within the Feather River floodplain or to the existing side bank outfall to the Feather River. The permitted flow will increase to 6.7 MGD upon the Discharger’s compliance with section VI.C.1.g of this Order.

In order to qualify for an exemption from Title 27 under section 20090(b), the Discharger, which is subject to WDRs and is prohibited from discharging wastewater that needs to be managed as “hazardous waste” under Title 22, chapter 11, division 4.5, must demonstrate compliance with the Basin Plan, which requires that constituent concentrations in the groundwater do not exceed either the Basin Plan’s groundwater water quality objectives or background groundwater concentrations, whichever is greater. The Discharger has a groundwater monitoring network that consists of three monitoring wells (MW-1 through MW-3). According to the Discharger’s 4 May 2011 *Linda County Water District Wastewater Treatment Plant Hydrogeologic Assessment Report* (Kennedy/Jenks Consultants), monitoring well MW-1 is up gradient of the ponds and monitoring wells MW-2 and MW-3 are down gradient of the ponds, as shown in Attachment C-2.

In existing Order R5-2017-0094, the Central Valley Water Board found that considering all data, the groundwater did not exceed water quality objectives; therefore, the Discharger was in compliance with the Basin Plan.

**Table F-6 pH Groundwater Monitoring Data (standard units)**

<b>Date</b>	<b>MW-1 (Up Gradient)</b>	<b>MW-2 (Down Gradient)</b>	<b>MW-3 (Down Gradient)</b>
13 December 2017	7.3	7.5	7.3
16 May 2018	7.2	7.0	6.2
11 July 2018	7.2	6.7	6.6
17 April 2019	7.1	6.5	6.4
17 July 2019	7.2	6.5	6.5
5 February 2020	7.3	7.2	7.0
15 July 2020	6.5	7.2	6.5
5 May 2021	6.9	6.8	6.6
14 July 2021	7.3	7.5	7.1

**Table F-7 Electrical Conductivity Groundwater Monitoring Data (µmhos/cm)**

<b>Date</b>	<b>MW-1 (Up Gradient)</b>	<b>MW-2 (Down Gradient)</b>	<b>MW-3 (Down Gradient)</b>
13 December 2017	581	563	631
16 May 2018	226	499	769
11 July 2018	331	559	780
17 April 2019	210	465	873
17 July 2019	210	572	535
5 February 2020	482	532	492
15 July 2020	762	635	609
5 May 2021	232	796	639
14 July 2021	221	726	686

**Table F-8 Fecal Coliform Groundwater Monitoring Data (MPN/100 mL)**

<b>Date</b>	<b>MW-1 (Up Gradient)</b>	<b>MW-2 (Down Gradient)</b>	<b>MW-3 (Down Gradient)</b>
13 December 2017	< 1.8	< 1.8	1.8
16 May 2018	< 1.8	< 1.8	1.8
11 July 2018	13	< 1.8	< 1.8
17 April 2019	< 210	< 1.8	< 1.8
17 July 2019	< 1.8	< 1.8	< 1.8
5 February 2020	< 1.8	< 1.8	< 1.8
15 July 2020	2	< 1.8	< 1.8
5 May 2021	< 1.8	< 1.8	< 1.8
14 July 2021	< 1.8	< 1.8	< 1.8

**Table F-9 Total Nitrogen (as N) Groundwater Monitoring Data (mg/L)**

<b>Date</b>	<b>MW-1 (Up Gradient)</b>	<b>MW-2 (Down Gradient)</b>	<b>MW-3 (Down Gradient)</b>
13 December 2017	0.2	3.8	45
16 May 2018	0.76	5.3	32
11 July 2018	1.1	0.8	24
17 April 2019	7.7	1.3	19
5 February 2020	8.8	1.8	7.1
15 July 2020	5.1	2.8	6.3
5 May 2021	4.2	11	4.4
14 July 2021	3.4	4	6.3

Based on the analysis of the data collected during the previous permit term, discharge to the percolation ponds is not contributing to the degradation of groundwater quality with respect to pH, fecal coliform, or total nitrogen. Over the past five years, downgradient well (MW-3) had elevated concentrations of nitrogen, which was at its maximum of 48 mg/L following the Oroville Dam spillway collapse in 2017. Subsequent nitrogen samples were lower each time until they stabilized below 10 mg/L since 2020, demonstrating that if there was a source of nitrogen prior to 2017 that it appears to be mitigated.

Electrical conductivity appears to be elevated in downgradient wells versus the upgradient well based on average concentrations, but the average concentrations between April 2019 and July 2021 are less than 700 µmhos/cm for all three wells. The elevated concentrations in the downgradient wells are to be expected considering the WWTP effluent concentrations typically ranged from 524 to 831 µmhos/cm and the average over the same date range is 786 µmhos/cm. The comparison of effluent to groundwater EC concentrations demonstrate that concentrations are very similar in downgradient wells as compared to the effluent.

The Discharger selected to participate in the Prioritization and Optimization Study for the Salt Control Program. To help ensure that the Discharger continues to implement salinity reduction measures, this Order includes a trigger of 1000

µmhos/cm for electrical conductivity to update the Salinity Evaluation and Minimization Plan. Furthermore, this Order requires the Discharger to comply with the new Salinity Control Program (i.e., to participate in the P&O Study). To continue to determine the influence the pond discharge has on groundwater, more frequent electrical conductivity monitoring, along with specific constituents like chloride and sodium have been added to the groundwater monitoring and reporting program in this Order.

The data discussed above demonstrates that discharges from the percolation ponds to the groundwater are in compliance with the Basin Plan. Therefore, the discharges meet the pre-conditions for an exemption to the requirements of Title 27 pursuant to Title 27 CCR section 20090(b). This Order requires the Discharger to continue groundwater monitoring including more robust and more frequent monitoring to evaluate impacts to groundwater and assure protection of beneficial uses.

#### **IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: 40 C.F.R. section 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 C.F.R. section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

##### **A. Discharge Prohibitions**

- 1. Prohibition III.A (No discharge or application of waste other than that described in this Order).** This prohibition is based on Water Code section 13260 that requires filing of a ROWD before discharges can occur. The Discharger submitted a ROWD for the discharges described in this Order; therefore, discharges not described in this Order are prohibited.
- 2. Prohibition III.B (No bypasses or overflow of untreated wastewater, except under the conditions at CFR section 122.41(m)(4)).** As stated in section I.G of Attachment D, Standard Provisions, this Order prohibits bypass from any portion of the treatment facility. Federal regulations, 40 C.F.R. section 122.41(m), define “bypass” as the intentional diversion of waste streams from any portion of a treatment facility. This section of the federal regulations, 40 C.F.R. section 122.41(m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Regional Water Board’s prohibition of bypasses, the State Water Board adopted a precedential decision, Order No. WQO 2002-0015, which cites the federal regulations, 40 C.F.R. section 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation.

3. **Prohibition III.C (No controllable condition shall create a nuisance).** This prohibition is based on Water Code section 13050 that requires water quality objectives established for the prevention of nuisance within a specific area. The Basin Plan prohibits conditions that create a nuisance
4. **Prohibition III.D (No discharge of hazardous waste).** This prohibition is based on CCR, title 22, section 66261.1 et seq, that prohibits discharge of hazardous waste.
5. **Prohibition III.E (Average Dry Weather Flow).** The Discharger submitted the Final Percolation Pond Hydraulic/Capacity Study (Engineering Study), dated 17 August 2018, prepared by Kennedy/Jenks Consultants, in accordance with the reopener provision in section VI.C.1.g of Order R5-2017-0094. The Engineering Study demonstrated that the percolation ponds are not limiting the treatment and discharge capacity of the Facility and therefore, the specific 1.8 MGD effluent limit for the percolation ponds was removed from Order R5-2017-0094. Order R5-2017-0094 included flow as an effluent limit based on the Facility design flow. The existing Facility has a design treatment capacity of 5.0 MGD. Upon completion of the expansion project and upon compliance with Special Provision VI.C.1.i of this Order, the Facility design treatment capacity will be 6.7 MGD. This prohibition is based on the design average dry weather flow treatment capacity rating for the Facility and ensures the Facility is operated within its treatment capacity.

## **B. Technology-Based Effluent Limitations**

### **1. Scope and Authority**

Section 301(b) of the CWA and implementing U.S. EPA permit regulations at 40 C.F.R. section 122.44 require that permits include conditions meeting applicable technology- based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 C.F.R. part 133.

Regulations promulgated in 40 C.F.R. section 125.3(a)(1) require technology-based effluent limitations for municipal Dischargers to be placed in NPDES permits based on Secondary Treatment Standards or Equivalent to Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the U.S. EPA Administrator.

Based on this statutory requirement, U.S. EPA developed secondary treatment regulations, which are specified in 40 C.F.R. part 133. These technology-based regulations apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of BOD<sub>5</sub>, TSS, and pH.

**2. Applicable Technology-Based Effluent Limitations**

- a. **BOD<sub>5</sub> and TSS.** Federal regulations at 40 C.F.R. part 133, establish the minimum weekly and monthly average level of effluent quality attainable by secondary treatment for BOD<sub>5</sub> and TSS. A daily maximum effluent limitation for BOD<sub>5</sub> and TSS is also included in the Order to ensure that the treatment works are not organically overloaded and operate in accordance with design capabilities. In addition, 40 C.F.R. section 133.102, in describing the minimum level of effluent quality attainable by secondary treatment, states that the 30-day average percent removal shall not be less than 85 percent. This Order contains a limitation requiring an average of 85 percent removal of BOD<sub>5</sub> and TSS over each calendar month. This Order requires Water Quality Based Effluent Limitations (WQBELs) that are equal to or more stringent than the secondary technology-based treatment described in 40 CFR part 133 (See section IV.C.3. of the Fact Sheet for a discussion on Pathogens which includes WQBELs for BOD<sub>5</sub> and TSS.)
- b. **pH.** The secondary treatment regulations at 40 C.F.R. part 133 also require that pH be maintained between 6.0 and 9.0 standard units. This Order, however, requires more stringent WQBELs for pH to comply with the Basin Plan’s water quality objectives for pH.

**Summary of Technology-based Effluent Limitations  
 Discharge Points 001 and 002**

**Table F-10 Summary of Technology-based Effluent Limitations**

Parameter	Units	Effluent Limitations
Biochemical Oxygen Demand (5- day @ 20°C)	mg/L	AMEL 30 AWEL 45 MDEL --
Biochemical Oxygen Demand (5- day @ 20°C)	% Removal	AMEL 85 AWEL -- MDEL --
pH	Standard Units	Instantaneous Minimum 6.0 Instantaneous Maximum 9.0

Parameter	Units	Effluent Limitations
Total Suspended Solids	mg/L	AMEL 30 AWEL 45 MDEL --
Total Suspended Solids	% Removal	AMEL 85 AWEL -- MDEL --

**Table F-10 Notes:**

- Note that more stringent WQBELs for BOD<sub>5</sub>, pH, and TSS are applicable and are established as final effluent limitations in this Order (see section IV.C.3. of this Fact Sheet).

**C. Water Quality-Based Effluent Limitations (WQBELs)**

**1. Scope and Authority**

CWA section 301(b) and 40 C.F.R. section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The rationale for these requirements, which consist of tertiary treatment or equivalent requirements or other provisions, is discussed in section IV.C.3 of this Fact Sheet.

Section 122.44(d)(1)(i) of 40 C.F.R. requires that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using: (1) U.S. EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state’s narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated beneficial uses of the receiving water as specified in the Basin Plan and achieve applicable water

quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

Finally, 40 C.F.R. section 122(d)(1)(vii) requires effluent limits to be developed consistent with any available WLAs developed and approved for the discharge.

## 2. **Applicable Beneficial Uses and Water Quality Criteria and Objectives**

The Basin Plan designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Board Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply.

The Basin Plan on page 2-1 states: "Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning..." and with respect to disposal of wastewaters states that "...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses."

The federal CWA section 101(a)(2), states: "it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983." Federal Regulations, developed to implement the requirements of the CWA, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR sections 131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water supply, protection and propagation of fish, shellfish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. 40 C.F.R. section 131.3(e) defines existing beneficial uses as those uses actually attained after 28 November 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 C.F.R. section 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

- a. **Receiving Water and Beneficial Uses.** Refer to III.C.1. above for a complete description of the receiving water and beneficial uses.
- b. **Effluent and Ambient Background Data.** The reasonable potential analysis (RPA), as described in section IV.C.3 of this Fact Sheet, was based on data from February 2018 through January 2022, which includes effluent and ambient background data submitted in SMRs.

The Discharger documented that the 15 July 2020 sample analyzed for cyanide was collected as a composite sample instead of a grab sample as allowed by Order R5-2017-0094. The Discharger has documented as part of their Cyanide Study that the presence of NaOH preservative, chlorine, and nitrate plus nitrite resulted in chemical reactions that produce interferences that appear as the presence of cyanide in the analysis. The extended reaction time allowed by the composite sample on 15 July 2020 allowed for an additional 24 hours of chemical reactions to occur. The 15 July 2020 sample result was 5.4 µg/L, where all the other monthly grab samples were 3.6 µg/L or less between February 2018 and January 2022. Furthermore, since the Discharger started treating the samples to remove sources of interference beginning in September 2021, up until the most recent reported sample in July 2022, cyanide has not been detected. For these reasons the sample collected on 15 July 2020 is not representative of the discharge and has been removed from the dataset used to conduct the RPA for cyanide.

c. **Assimilative Capacity/Mixing Zone**

i. The CWA directs the states to adopt water quality standards to protect the quality of its waters. U.S. EPA's current water quality standards regulation authorizes states to adopt general policies, such as mixing zones, to implement state water quality standards (40 CFR sections 122.44 and 122.45). The U.S. EPA allows states to have broad flexibility in designing its mixing zone policies. Primary policy and guidance on determining mixing zone and dilution credits is provided by the SIP and the Basin Plan. If no procedure applies in the SIP or the Basin Plan, then the Central Valley Water Board may use the U.S. EPA Technical Support Document for Water Quality-Based Toxics Control (EPA/505/2-90-001) (TSD).

For non-Priority Pollutant constituents, the allowance of mixing zones by the Central Valley Water Board is discussed in the Basin Plan, Policy for Application of Water Quality Objectives, which states the following, in part: *"In conjunction with the issuance of NPDES and storm water permits, the Regional Board may designate mixing zones within which water quality objectives will not apply provided the discharger has demonstrated to the satisfaction of the Regional Board that the mixing zone will not adversely impact beneficial uses. If allowed, different mixing zones may be designated for different types of objectives, including, but not limited to, acute aquatic life objectives, chronic aquatic life objectives, human health objectives, and acute and chronic whole effluent toxicity objectives, depending in part on the averaging period over which the objectives apply. In determining the size of such mixing zones, the Regional Board will consider the applicable procedures and guidelines in the EPA's Water Quality Standards Handbook and the [TSD]. Pursuant to EPA guidelines,*

*mixing zones designated for acute aquatic life objectives will generally be limited to a small zone of initial dilution in the immediate vicinity of the discharge.”*

For Priority Pollutants, the SIP supersedes the Basin Plan mixing zone provisions. Section 1.4.2 of the SIP states, in part, “...with the exception of effluent limitations derived from TMDLs, in establishing and determining compliance with effluent limitations for applicable human health, acute aquatic life, or chronic aquatic life priority pollutant criteria/objectives or the toxicity objective for aquatic life protection in a basin plan, the Regional Board may grant mixing zones and dilution credits to dischargers...The applicable priority pollutant criteria and objectives are to be met through a water body except within any mixing zone granted by the Regional Board. **The allowance of mixing zones is discretionary and shall be determined on a discharge-by-discharge basis.** The Regional Board may consider allowing mixing zones and dilution credits only for discharges with a physically identifiable point of discharge that is regulated through an NPDES permit issued by the Regional Board.” [emphasis added]

For incompletely mixed discharges, the Discharger must complete an independent mixing zone study to demonstrate to the Central Valley Water Board that a dilution credit is appropriate. In granting a mixing zone, section 1.4.2.2 of the SIP requires the following to be met:

***“A mixing zone shall be as small as practicable. The following conditions must be met in allowing a mixing zone:***

A mixing zone shall not:

1. *compromise the integrity of the entire water body;*
2. *cause acutely toxic conditions to aquatic life passing thorough the mixing zone;*
3. *restrict the passage of aquatic life;*
4. *adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or State endangered species laws;*
5. *produce undesirable or nuisance aquatic life;*
6. *result in floating debris, oil, or scum;*
7. *produce objectionable color, odor, taste, or turbidity;*
8. *cause objectionable bottom deposits;*
9. *cause nuisance;*

10. *dominate the receiving water body or overlap a mixing zone from different outfalls; or*
11. *be allowed at or near any drinking water intake. A mixing zone is not a source of drinking water. To the extent of any conflict between this determination and the Sources of Drinking Water Policy (Resolution No. 88-63), this SIP supersedes the provisions of that policy.”*

Section 1.4.2.1 of the SIP establishes the authority for the Central Valley Water Board to consider dilution credits based on the mixing zone conditions in a receiving water. Section 1.4.2.1 in part states:

*“The dilution credit, D, is a numerical value associated with the mixing zone that accounts for the receiving water entrained into the discharge. The dilution credit is a value used in the calculation of effluent limitations (described in section 1.4). **Dilution credits may be limited or denied on a pollutant-by-pollutant basis, which may result in a dilution credit for all, some, or no priority pollutants in the discharge.**”*

ii. Dilution/Mixing Zone Study Results.

Existing Order R5-2017-0094 recognized a full dilution credit of 331:1 for human health constituents based on the Feather River harmonic mean flow of 3,600 cfs and a discharge flow of 6.7 MGD. Flow in the Feather River at the point of discharge from the Facility is affected by upstream flow in the Feather River, as well as flow in the Yuba River. The Feather River and Yuba River are operated to maintain minimum flow rates regardless of flow diversions. The flow in the Feather River is operated in accordance with a 26 August 1983 agreement between the Department of Water Resources (DWR) and Department of Fish and Wildlife (DFW) entitled *Concerning the Operation of the Oroville Division of the State Water Project for Management of Fish and Wildlife*. This agreement states that a minimum flow of 1,000 cubic feet per second (cfs) must be maintained by releases from the Oroville Reservoir (Thermalito Diversion Dam) along all stretches of the Feather River from the Thermalito Afterbay to the mouth of the Feather River at Verona. Releases from the reservoir are limited to prevent water elevations in the reservoir to fall below 733 feet. When releases are limited, the Feather River flow could be as low as 750 cfs. The flow in the Yuba River is controlled under the 1 March 2001 State Water Board Decision 1644, which requires flows in the Yuba River to be maintained at 250 cfs, except under hydrologic critical years, where the flow at Marysville will be 100 cfs.

A field investigation, using electrical conductivity as the water constituent tracer, was conducted within the reach of the Feather and Yuba rivers confluence down to just below Shanghai Falls (18 March 2003 *Yuba City*

*WRP Complete Mix Investigation, Larry Walker Associates*). Samples obtained from both Feather River and Yuba River upstream of the rivers' confluence revealed a 13% difference in electrical conductivity measurements. Electrical conductivity transects were mapped along reaches of the Feather River approximately halfway and three-quarters way downstream of the rivers' confluence, and just below the falls. The field investigation demonstrates that water from the Yuba River remains on the east bank of the Feather River while water from the Feather River remains on the west bank of the Feather River downstream of their confluence, and complete mixing occurs at Shanghai Falls. The side-bank effluent discharge is located on the east bank of the Feather River, and therefore, the mixing zone is expected to remain on the east bank as demonstrated through the field investigation.

The Central Valley Water Board adopted Order R5-2013-0094 that permits the City of Yuba City WWTP to discharge to the Feather River through a diffuser when greater than 6,500 cfs of river flow occurs across the diffuser. The diffuser is located at a distance ranging from 160 feet to 320 feet upstream of Shanghai Falls, and approximately 3,400 feet downstream of the Discharger's side-bank effluent discharge. The diffuser is situated 200 feet from the west bank of the Feather River, where the river is 588 feet wide. As demonstrated in the field investigation previously discussed, the City of Yuba City wastewater discharge is expected to remain on the west bank until complete mixing occurs approximately 250 feet downstream at Shanghai Falls.

The Discharger conducted further study involving CORMIX modeling of the discharge mixing in the Feather River to evaluate the chronic whole effluent toxicity testing mixing zone and to determine an IWC. The analysis was submitted to the Central Valley Water Board on 29 September 2021, as part of the ROWD and additional information was provided on 30 September 2022. Model inputs were a 7Q10 receiving water flow of 1,265 cfs and a maximum 4-day average discharge flow rate of 5.83 MGD (9.0 cfs) based on the monitoring term for permit R5-2017-0094. The model results indicated a dilution ratio for chronic whole effluent toxicity of 11:1 (receiving water to effluent) and support the Discharger's request for a mixing zone for chronic whole effluent toxicity testing that extends 100 feet downstream of the WWTP outfall, with a corresponding IWC of 8.3%.

**iii. Evaluation of Available Dilution for Human Carcinogen Criteria.**

The Discharger requested a 3,700 foot mixing zone that extends from the side-bank discharge to the point of complete mixing, the end of the mixing zone, and a dilution credit of 331:1 for human-health constituents. However, the Central Valley Water Board did not grant

the full extent of the requested mixing zone based on a constituent-by-constituent analysis. Dilution credits allowed for in this Order are in accordance with Section 1.4.2.1 of the SIP. The allowance of a mixing zone and dilution credits are a discretionary act by the Central Valley Water Board. The Central Valley Water Board has determined that the maximum dilution credits on a constituent-by-constituent basis needed for this discharge are shown in the following table (also discussed further in section IV.C.3.c).

**Table F-11 Mixing Zones and Dilution Credits**

Parameter	Mixing Zone Type	Allowed Dilution Credit	Mixing Zone Size (feet)
Chlorodibromomethane	Human Health	63	100
Dichlorobromomethane	Human Health	73	100

The SIP requires a mixing zone must be as small as practicable and comply with eleven (11) mixing zone prohibitions under section 1.4.2.2.A. Based on Central Valley Water Board staff evaluation, the mixing zone extends up to 3700 feet downstream of the Facility’s outfall and a maximum available dilution credit of 331:1 meets the eleven prohibitions of the SIP as follows:

- (1) Shall not compromise the integrity of the entire water body – The TSD states that, *“If the total area affected by elevated concentrations within all mixing zones combined is small compared to the total area of a water body (such as a river segment), then mixing zones are likely to have little effect on the integrity of the water body as a whole, provided that the mixing zone does not impinge on unique or critical habitats.”* The mixing zone is not applicable to aquatic life criteria. The mixing zone does not compromise the integrity of the entire water body.
- (2) Shall not cause acutely toxic conditions to aquatic life passing through the mixing zone – The mixing zone is not applicable to aquatic life criteria. Therefore, acutely toxic conditions will not occur in the mixing zone.
- (3) Shall not restrict the passage of aquatic life – The human health mixing zone is not applicable to aquatic life criteria. Therefore, the mixing zone will not restrict the passage of aquatic life.
- (4) Shall not adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or State endangered species laws – The mixing zone is not

applicable to aquatic life criteria. The mixing zone will not impact biologically sensitive or critical habitats.

(5-9) Shall not produce undesirable or nuisance aquatic life; result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits; cause nuisance – The allowance of the mixing zone will not produce undesirable or nuisance aquatic life, result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits; or cause nuisance. Therefore, the allowance of the mixing zone will not produce undesirable or nuisance aquatic life, result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits, or cause nuisance.

(10) Shall not dominate the receiving water body or overlap a mixing zone from different outfalls – The mixing zone is small relative to the water body, so it will not dominate the water body. Furthermore, the mixing zone does not overlap mixing zones from other outfalls. There are no outfalls or mixing zones in the vicinity of the discharge.

(11) Shall not be allowed at or near any drinking water intake – The mixing zone is not near a drinking water intake.

Central Valley Water Board has determined that allowing dilution factors that exceed those proposed by this Order would not comply with the State Anti-degradation Policy for receiving waters outside the allowable mixing zone for chlorodibromomethane and dichlorobromomethane. The State Water Board established California's antidegradation policy in the State Anti-Degradation Policy. The State Anti-Degradation Policy incorporates the federal antidegradation policy and requires that existing quality of waters be maintained unless degradation is justified based on specific findings. Item 2 of the State Anti-Degradation Policy states:

*“Any activity which produces or may produce a waste or increased volume or concentration of waste and which dischargers or proposed to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained.”*

The effluent limitations established in the Order for chlorodibromomethane and dichlorobromomethane that have been adjusted for dilution credits provided in Table F-8 were developed based on performance of the Discharger's current wastewater

treatment capabilities. Therefore, the Central Valley Water Board determined the effluent limitations required by this Order will result in the Discharger implementing best practicable treatment or control of the discharge necessary to assure that pollution or nuisance will not occur and the highest water quality consistent with maximum benefit to the people of the State will be maintained. The Central Valley Water Board also determined the Discharger will be in immediate compliance with the effluent limitations,

The Central Valley Water Board also determined establishing effluent limitations for chlorodibromomethane and dichlorobromomethane that have been adjusted for dilution credits provided in Table F-8 is consistent with Section 1.4.2.2B of the SIP that requires the Central Valley Water Board to shall deny or significantly limit a mixing zone and dilution credits as necessary to comply with other regulatory requirements.

Therefore, the Central Valley Water Board has determined the effluent limitations established in the Order for chlorodibromomethane and dichlorobromomethane that have been adjusted for dilution credits provided in Table F-8 are appropriate and necessary to comply with the Basin Plan, SIP, Federal anti-degradation regulations and the State Anti-Degradation Policy.

The Central Valley Water Board has determined that granting dilution credits significantly below the available dilution is appropriate for this discharge. In order to maintain the current Facility performance, this Order includes triggers for chlorodibromomethane and dichlorobromomethane. If the concentration for any of these constituents exceeds the trigger listed in Table F-9 below over a 12-month period beginning on the 1st of the calendar year and the exceedances demonstrate a consistent increasing trend, the Discharger shall perform a study to determine the cause of the increase in the effluent concentration of the constituent(s). In the case where uncontrollable factors are documented as responsible for the increasing trend, a study is not required. For example, the quality of the influent waste stream once Marysville’s waste stream is connected causes an increasing trend in the concentration of chlorine disinfection byproducts; this is an uncontrollable factor that would not require a study by the Discharger.

**Table F-12 Triggers Associated with Performance-Based Effluent Limitations**

Parameter	Units	AMEL	MDEL	Trigger
Chlorodibromomethane	µg/L	18	36	12
Dichlorobromomethane	µg/L	38	70	35

Dilution credits are significantly below the available dilution and the

performance-based triggers in Table F-9 above for chlorodibromomethane and dichlorobromomethane are included to maintain current Facility performance.

iv. **Evaluation of Available Dilution for Chronic Whole Effluent Toxicity (WET)**

The chronic WET mixing zone is sized to protect the waterbody as a whole. A mixing zone for chronic WET has been allowed in this Order for the purpose of conducting chronic whole effluent toxicity testing at the IWC. The chronic WET mixing zone is approximately 50 feet wide and extends 100 feet downstream of the LCWD outfall to the Feather River. The chronic WET mixing zone meets the requirements of the SIP as follows:

- (1) Shall not compromise the integrity of the entire waterbody – The TSD states that, *“If the total area affected by elevated concentrations within all mixing zones combined is small compared to the total area of a waterbody (such as a river segment), then mixing zones are likely to have little effect on the integrity of the waterbody as a whole, provided that the mixing zone does not impinge on unique or critical habitats.”* The Feather River is approximately 300 feet wide at the surface. The chronic WET mixing zone is approximately 50 feet wide by 100 feet long, located adjacent to the east bank of the river. The Feather River is a large waterbody and the mixing zone is small (100 feet) relative to the size of the receiving water (approximately 71 miles for the Feather River). For the pollutants for which a mixing zone was requested, the chronic WET mixing zone would not compromise the integrity of the entire waterbody.
- (2) Shall not cause acutely toxic conditions to aquatic life passing through the mixing zone – The chronic WET mixing zone does not allow acute aquatic life criteria to be exceeded and this Order requires acute bioassays to be conducted using 100 percent effluent when discharging to the Feather River. Compliance with these requirements ensures that acutely toxic conditions to aquatic life passing through the chronic WET mixing zone do not occur.
- (3) Shall not restrict the passage of aquatic life – The mixing zone would allow adequate zones of passage. The Discharger developed a discharge mixing model to evaluate the near-field effects of the discharge. The model was used to evaluate the zone of passage around the mixing zone where water quality objectives are met. The model indicates there is a zone of passage for aquatic life, which is consistent with the Discharger’s field study findings. The surface of the river is approximately 300 feet across and the zone of passage of 250 feet occurs adjacent to the west bank

downstream of the outfall diffuser. Thus, at least 83% of the river cross-section would be unaffected by the mixing zone.

- (4) Shall not adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or state endangered species laws – The chronic WET mixing zone will not cause acutely toxic conditions, allows adequate zones of passage, and is sized appropriately to ensure that there would be no adverse impacts to biologically sensitive or critical habitats.
- (5-9) Shall not produce undesirable or nuisance aquatic life; result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits; cause nuisance – The current discharge has not been shown to result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits; or cause nuisance. This Order requires the discharge meets Title 22 (or equivalent) tertiary filtration, which will ensure continued compliance with these mixing zone requirements. With these requirements, the chronic WET mixing zone will not produce undesirable or nuisance aquatic life, result in floating debris, oil, or scum; produce objectionable color, odor, taste, or turbidity; cause objectionable bottom deposits; or cause nuisance.
- (10) Shall not dominate the receiving water body or overlap a mixing zone from different outfalls – The chronic WET mixing zone is small relative to the water body, so it will not dominate the waterbody. Furthermore, the mixing zone does not overlap mixing zones from other outfalls. There are no outfalls or mixing zones in the vicinity of the discharge.
- (11) Shall not be allowed at or near any drinking water intake – There is no drinking water intake within 100 feet of the LCWD WWTP outfall.

The mixing zone used to calculate the IWC for chronic WET therefore complies with the SIP. The mixing zone also complies with the Basin Plan, which requires that the mixing zone not adversely impact beneficial uses. Beneficial uses will not be adversely affected for the same reasons discussed above. In determining the size of the mixing zone, the Central Valley Water Board considered the procedures and guidelines in U.S. EPA's Water Quality Standards Handbook, 2nd Edition (updated July 2007), section 5.1, and section 2.2.2 of the TSD. The SIP incorporates the same guidelines.

- d. **Conversion Factors.** The CTR contains aquatic life criteria for arsenic, cadmium, chromium III, chromium VI, copper, lead, nickel, silver, and zinc which are presented in dissolved concentrations. U.S. EPA recommends conversion factors to translate dissolved concentrations to total

concentrations. The default U.S. EPA conversion factors contained in Appendix 3 of the SIP were used to convert the applicable dissolved criteria to total recoverable criteria.

- e. **Hardness-Dependent CTR Metals Criteria.** The CTR and the NTR contain water quality criteria for seven metals that vary as a function of hardness. The lower the hardness the lower the water quality criteria. The metals with hardness-dependent criteria include cadmium, copper, chromium III, lead, nickel, silver, and zinc. This Order has established the criteria for hardness-dependent metals based on the hardness of the receiving water (actual ambient hardness) as required by the SIP and the CTR.

The ambient hardness for the Feather River ranges from 25 mg/L to 41 mg/L based on collected ambient data from February 2018 through January 2022. Given the high variability in ambient hardness values, there is no single hardness value that describes the ambient receiving water for all possible scenarios (e.g., minimum, maximum). Because of this variability, staff has determined that based on the ambient hardness concentrations measured in the receiving water, the Central Valley Water Board has discretion to select ambient hardness values within the range of 25 mg/L (minimum) up to 41 mg/L (maximum).

The Central Valley Water Board finds that the use of the ambient hardness values and associated acute and chronic criteria shown in Table F-13 to conduct the reasonable potential analysis (RPA) and calculate WQBELs, protect beneficial uses under all ambient receiving water conditions and comply with the SIP, CTR, and Basin Plan.

**Table F-13. Summary of Criteria for CTR Hardness-dependent Metals**

<b>CTR Metals</b>	<b>Ambient Hardness (mg/L)</b>	<b>Acute Criteria (µg/L, total)</b>	<b>Chronic Criteria (µg/L, total)</b>
Copper	92	13	8.7
Chromium III	92	1600	190
Cadmium	92 (acute) 92 (chronic)	4.1	2.3
Lead	92	73	2.9
Nickel	92	440	49
Silver	92	3.5	--
Zinc	92	112	112

**Table F-13 Notes:**

1. **Criteria (µg/L total).** Acute and chronic criteria were rounded to two significant figures in accordance with the CTR (40 C.F.R. section 131.38(b)(2)).

2. **Ambient hardness (mg/L).** Values in Table F-13 represent actual observed receiving water hardness measurements.

3. **Determining the Need for WQBELs**

Clean Water Act section 301(b)(1)(C) requires effluent limitations necessary to meet water quality standards, and 40 C.F.R. section 122.44(d) requires NPDES permits to include conditions that are necessary to achieve water quality standards established under section 303 of the CWA, including State narrative criteria for water quality. Federal regulations at 40 C.F.R 122.44(d)(1)(i) state, "Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level that will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality." Additionally, 40 C.F.R. section 122(d)(1)(vii) requires effluent limits to be developed consistent with any available WLAs developed and approved for the discharge. The process to determine whether a WQBEL is required as described in 40 C.F.R. section 122.44(d)(1)(i) is referred to as a reasonable potential analysis or RPA. Central Valley Water Board staff conducted RPAs for nearly 200 constituents, including the 126 U.S. EPA priority toxic pollutants. This section includes details of the RPAs for constituents of concern for the Facility. The entire RPA is included in the administrative record and a summary of the constituents of concern is provided in Attachment G.

For priority pollutants, the SIP dictates the procedures for conducting the RPA. For non-priority pollutants the Central Valley Water Board is not restricted to one particular RPA method; therefore, the RPAs have been conducted based on U.S. EPA guidance considering multiple lines of evidence and the site-specific conditions of the discharge. Ammonia, chlorine residual, nitrate plus nitrite, pH, pathogens, and temperature are not priority pollutants. Due to the site-specific conditions of the discharge, the Central Valley Water Board has used professional judgment in determining the appropriate method for conducting the RPA for these non-priority pollutant parameters based on a qualitative assessment as recommended by U.S. EPA guidance. U.S. EPA's September 2010 NPDES Permit Writer's Manual, page 6-30, states, "State implementation procedures might allow, or even require, a permit writer to determine reasonable potential through a qualitative assessment process without using available facility-specific effluent monitoring data or when such data are not available...A permitting authority might also determine that WQBELs are required for specific pollutants for all facilities that exhibit certain operational or discharge characteristics (e.g., WQBELs for pathogens in all permits for POTWs discharging to contact recreational waters)." U.S. EPA's TSD also recommends that factors other than effluent data should be considered in the RPA, "When determining whether or not a discharge causes, has the reasonable potential to cause, or contributes to an excursion of a numeric or narrative water quality criterion for individual toxicants or for toxicity,

the regulatory authority can use a variety of factors and information where facility-specific effluent monitoring data are unavailable. These factors also should be considered with available effluent monitoring data.” With regard to POTWs, U.S. EPA recommends that, “POTWs should also be characterized for the possibility of chlorine and ammonia problems.” (TSD, p. 50)

a. **Constituents with Total Maximum Daily Load (TMDL).**

40 C.F.R. section 122.44(d)(1)(vii) provides: “When developing water quality-based effluent limits under [section 122.44(d)(1)], the permitting authority shall ensure that: (A) The level of water quality to be achieved by limits on point sources established under this paragraph is derived from, and complies with all applicable water quality standards; and (B) Effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available WLA for the discharge prepared by the State and approved by U.S. EPA pursuant to [Total Maximum Daily Loads regulations].” U.S. EPA construes 40 C.F.R. section 122.44(d)(1)(vii)(B) to mean that “when WLAs are available, they must be used to translate water quality standards into NPDES permit limits.” 54 Fed. Reg. 23868, 23879 (June 2, 1989).

The Feather Rivers is subject to TMDLs for Diazinon and Chlorpyrifos and the Central Valley Water Board developed WQBELs for these pollutants pursuant to 40 C.F.R. section 122.44(d)(1)(vii), which does not require or contemplate a reasonable potential analysis.

- (a) **WQO.** The Central Valley Water Board completed a TMDL for diazinon and chlorpyrifos in the Sacramento and Feather Rivers and amended the Basin Plan to include diazinon and chlorpyrifos waste load allocations and water quality objectives. The Basin Plan Amendment for the Control of Diazinon and Chlorpyrifos Runoff into the Sacramento and Feather Rivers was adopted by the Central Valley Water Board on 3 May 2007 and became effective on 11 August 2008.

The amendment modified Basin Plan Chapter 3 (Water Quality Objectives) to establish site-specific numeric objectives for diazinon and chlorpyrifos in the Sacramento River from the Colusa Basin Drain to I Street Bridge and the Feather River from Fish Barrier Dam to the Sacramento River, and identified the requirements to meet the additive formula already in Basin Plan Chapter 4 (Implementation) for the additive toxicity of diazinon and chlorpyrifos.

The amendment states that the waste load allocations for all NPDES-permitted dischargers shall not exceed the sum (S) of one (1) as defined below:

$$S = Cd/WQOd + Cc/WQOc \leq 1.0$$

Where:

Cd = diazinon concentration in µg/L of point source discharge

Cc = chlorpyrifos concentration in µg/L of point source discharge

WQOd = acute or chronic diazinon water quality objective in µg/L

WQOc = acute or chronic chlorpyrifos water quality objective in µg/L

Available samples collected within the applicable averaging period for the water quality objective will be used to determine compliance with the allocations and loading capacity. For purposes of calculating the sum (S) above, analytical results that are reported as 'non-detectable' concentrations are considered to be zero.

- a. **Constituents with No Reasonable Potential.** Central Valley Water Board staff conducted reasonable potential analyses for nearly 200 constituents, including the 126 U.S. EPA priority toxic pollutants. All reasonable potential analyses are included in the administrative record and a summary of the constituents of concern is provided in Attachment G. WQBELs are not included in this Order for constituents that do not demonstrate reasonable potential to cause or contribute to an instream excursion of an applicable water quality objective; however, monitoring for those pollutants is established in this Order as required by the SIP. If the results of effluent monitoring demonstrate reasonable potential, this Order may be reopened and modified by adding an appropriate effluent limitation.

Most constituents with no reasonable potential are not discussed in this Order. This section only provides the rationale for the reasonable potential analyses for the following constituents of concern that were found to have no reasonable potential after assessment of the data:

i. **Bis (2-ethylhexyl) phthalate**

- (a) **WQO.** The CTR includes a criterion of 1.8 µg/L for bis (2-ethylhexyl) phthalate for the protection of human health for waters from which both water and organisms are consumed.
- (b) **RPA Results.** Based on samples from February 2018 to January 2022, the MEC for bis (2-ethylhexyl) phthalate was

non-detect and the maximum ambient background antimony concentration was non-detect. Therefore, bis (2-ethylhexyl) phthalate does not demonstrate reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.

ii. **Salinity**

- (a) **WQO.** The Basin Plan contains a chemical constituent objective that incorporates state MCLs, contains a narrative objective, and contains numeric water quality objectives for certain specified water bodies for electrical conductivity, total dissolved solids, sulfate, and chloride. The U.S. EPA Ambient Water Quality Criteria for Chloride recommends acute and chronic criteria for the protection of aquatic life. There are no U.S. EPA water quality criteria for the protection of aquatic life for electrical conductivity, total dissolved solids, and sulfate. Additionally, there are no U.S. EPA numeric water quality criteria for the protection of agricultural, livestock, and industrial uses. Numeric values for the protection of these uses are typically based on site specific conditions and evaluations to determine the appropriate constituent threshold necessary to interpret the narrative chemical constituent Basin Plan objective. The Central Valley Water Board must determine the applicable numeric limit to implement the narrative objective for the protection of agricultural supply. Table F-14, below, contains various recommended levels for EC or TDS, sulfate, and chloride.

**Table F-14 Salinity Water Quality Criteria/Objectives**

Parameters	Secondary MCL Recommended Level.	Secondary MCL Upper Level	Secondary MCL Short-term Maximum	U.S. EPA NAWQC	Maximum Calendar Annual Average Effluent Concentration	Maximum Daily Effluent Concentration
EC (µmhos/cm) or TDS (mg/L)	EC 900 or TDS 500	EC 1,600 or TDS 1,000	EC 2,200 or TDS 1,500	N/A	EC: 786 TDS: 500	EC: 831 TDS: 580
Sulfate (mg/L)	250	500	600	N/A	22	24
Chloride (mg/L)	250	500	600	860 1-hour / 230 4-day	98	100

**Table F-14 Notes:**

1. **Agricultural Water Quality Objectives.** Applicable agricultural water quality objectives vary. Procedures for establishing the applicable numeric limitation to implement the narrative chemical constituent objective can be found in the Policy for Application of Water Quality Objectives, section 4.2.2.1.9 of the Basin Plan. However, the Basin Plan does not require improvement over naturally occurring background concentrations. In cases where the natural background concentration of a particular constituent exceeds an applicable water quality objective, the natural background concentration will be considered to comply with the objective.
2. **Secondary MCLs.** Secondary MCLs are for protection of public welfare and are stated as a recommended level, upper level, and a short-term maximum level.
3. **Chloride.** The Secondary MCL for chloride is 250 mg/L, as a recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum.
4. **Electrical Conductivity or Total Dissolved Solids.** The Secondary MCL for EC is 900 µmhos/cm as a recommended level, 1600 µmhos/cm as an upper level, and 2200 µmhos/cm as a short-term maximum, or when expressed as TDS is 500 mg/L as a recommended level, 1000 mg/L as an upper level, and 1500 mg/L as a short-term maximum. The Basin Plan includes a water quality objective that electrical conductivity (at 25°C) “[s]hall not exceed 150 micromhos/cm (90 percentile) in well-mixed waters of the Feather River.” The Basin Plan objective for electrical conductivity is applied as a 10-year rolling average.
5. **Sulfate.** The Secondary MCL for sulfate is 250 mg/L as a recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum.

(b) **RPA Results.**

- (1) **Chloride.** Chloride concentrations in the effluent ranged from 97 mg/L to 100 mg/L, with an average of 98 mg/L. These levels do not exceed the Secondary MCL. Background concentrations in the Feather River were observed with a maximum calendar year annual average of 1.1 mg/L, based on four samples collected between February 2018 and January 2022.
- (2) **Electrical Conductivity or Total Dissolved Solids.** A review of the Discharger’s monitoring reports shows an average effluent EC of 786 µmhos/cm, with a range from 524 µmhos/cm to 821 µmhos/cm. These levels do not exceed the Secondary MCL and the Basin Plan objective for electrical conductivity applied as a 10-year rolling average. The background receiving water EC averaged 75 µmhos/cm. The average TDS effluent concentration was 500 mg/L with concentrations ranging from 150 mg/L to

580 mg/L. These levels do not exceed the Secondary MCL. The background receiving water TDS averaged 68 mg/L.

- (3) **Sulfate.** Sulfate concentrations in the effluent ranged from 20 mg/L to 24 mg/L, with an average of 22 mg/L. These levels do not exceed the Secondary MCL. Background concentrations in the Feather River averaged 3 mg/L.

(c) **WQBELs.**

As discussed above, the discharge does not have reasonable potential to cause or contribute to an in-stream excursion of water quality objectives for salinity. On 17 January 2020, certain amendments to the Basin Plan incorporating a Program to Control and Permit Salt Discharges to Surface and Groundwater (Salt Control Program) became effective. Other amendments became effective on 2 November 2020 when approved by the U.S. EPA. The Salt Control Program is a three-phased program, with each phase lasting 10 to 15 years. The Basin Plan requires all salt dischargers to comply with the provisions of the program. Two compliance pathways are available for salt dischargers during Phase 1.

The Phase 1 Compliance pathways are: 1) Conservative Salinity Permitting Approach, which utilizes the existing regulatory structure and focuses on source control, conservative salinity limits on the discharge, and limits the use of assimilative capacity and compliance time schedules; and, 2) Alternative Salinity Permitting Approach, which is an alternative approach to compliance through implementation of specific requirements such as participating in the Salinity Prioritization and Optimization Study (P&O) rather than the application of conservative discharge limits.

The Discharger submitted a Notice of Intent for the Salinity Control Program on 21 July 2021 indicating its intent to meet the Alternative Salinity Permitting Approach. This Order requires implementation of a Salinity Evaluation and Minimization Plan, participation in the Salinity P&O Study, and includes a performance-based trigger for EC consistent with the Alternative Salinity Permitting Approach. This performance-based trigger is based on the maximum annual average effluent EC concentration for a calendar year using data from February 2018 through January 2022, adjusted to account for possible drought, water conservation, and water recycling efforts.

iii. **Mercury**

- (a) **WQO.** The State Water Board adopted Resolution 2017-0027 on 2 May 2017, which approved Part 2 of the Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California, Tribal and Subsistence Fishing Beneficial Uses and Mercury Provisions (Statewide Mercury Provisions). The Statewide Mercury Provisions establish a Sport Fish Water Quality Objective of an average 0.2 mg/kg methylmercury fish tissue concentration within a calendar year for waters with the beneficial uses of commercial and sport fishing (COMM), tribal tradition and culture (CUL), wildlife habitat (WILD), and marine habitat (MAR). This fish tissue objective corresponds to a water column concentration of <12 ng/L of total mercury for flowing water bodies. As shown in Table F-3, the beneficial uses of the Feather River include WILD; therefore, the Sport Fish Water Quality Objective is applicable and is the most stringent objective.
- (b) **RPA Results.** The Statewide Mercury Provisions specify that the RPA shall be conducted using the maximum annual average effluent and background mercury concentrations for comparison with the Sport Fish Water Quality Objective. The maximum observed effluent mercury concentration was 4.3 ng/L, with a maximum annual average of 4.3 ng/L, based on thirty-eight samples collected from February 2018 to January 2022. The maximum annual average background concentration for mercury was 2.1 ng/L based on three samples collected from February 2018 to January 2022.

This Order contains a performance-based mass effluent limitation of 0.46 lbs/year for mercury for the effluent discharged to the receiving water. This limitation is based on maintaining the mercury loading at the current level until a TMDL can be established. The performance-based mercury effluent mass limit was derived using current, representative data.

- (d) **Plant Performance and Attainability.** The effluent limitations for Mercury are based on Facility performance. The Central Valley Water Board concludes, therefore, that immediate compliance with these effluent limitations is feasible.
- b. **Constituents with Reasonable Potential.** The Central Valley Water Board finds that the discharge has a reasonable potential to cause or contribute to an instream excursion above a water quality standard for ammonia, chlorine residual, chlorodibromomethane, dichlorobromomethane, mercury, nitrate plus nitrite, pH, and total coliform organisms. WQBELs for these constituents are included in this Order. A

summary of the RPA is provided in Attachment G, and a detailed discussion of the RPA for each constituent is provided below.

i. **Ammonia**

- (a) **WQO.** The 2013 U.S. EPA National Ambient Water Quality Criteria (NAWQC) for the protection of freshwater aquatic life for total ammonia (2013 Criteria), recommends acute (1-hour average; criteria maximum concentration or CMC) and chronic (30-day average; criteria continuous concentration or CCC) standards based on pH and temperature. U.S. EPA also recommends that no 4-day average concentration should exceed 2.5 times the 30-day CCC. The 2013 Criteria reflects the latest scientific knowledge on the toxicity of ammonia to certain freshwater aquatic life, including toxicity data on sensitive freshwater unionid mussels, non-pulmonary snails, and other freshwater organisms.

The Central Valley Clean Water Association (CVCWA) organized a coordinated effort for POTWs within the Central Valley Region, the Freshwater Mussel Collaborative Study for Wastewater Treatment Plants, to determine how the latest scientific knowledge on the toxicity of ammonia reflected in the 2013 Criteria could be implemented in the Central Valley Region. Through this effort a Criteria Recalculation Report was developed in January 2020 using toxicity studies for the freshwater mussel species present in Central Valley Region waters.

The Criteria Recalculation Report implemented U.S. EPA's Recalculation Procedure utilizing toxicity bioassays conducted on resident mussel species to replace the toxicity data for the eastern mussel species in the national dataset to develop site-specific ammonia criteria for waters within the Central Valley Region, including all surface waters in the Sacramento River, San Joaquin River, and Tulare Lake Basin Plans.

U.S. EPA Office of Science and Technology reviewed and approved the Criteria Recalculation Report with a more conservative approach for utilizing the acute-to-chronic ratio procedure for developing the site-specific chronic criterion. The Central Valley Water Board finds that the site-specific ammonia criteria provided in the January 2020 Criteria Recalculation Report implements the Basin Plan's narrative toxicity objective to protect aquatic life beneficial uses of the receiving water.

**Site-specific Criteria for the Feather River.** The recalculated site-specific criteria developed in the Criteria Recalculation Report for the acute and chronic criteria are presented based on equations that vary according to pH and temperature for situations where freshwater mussels are present and where they are absent. In this case, for the Feather River freshwater mussels have been assumed to be present. In addition, the recalculated criteria include equations that provide enhanced protection for important salmonid species in the genus *Oncorhynchus*, that can be implemented for receiving waters where salmonid species are present. Because the Feather River has a beneficial use of cold freshwater habitat and the presence of salmonids in the Feather River is well-documented, the criteria equations for waters where salmonids are present were used.

The acute (1-hour average) criterion or CMC was calculated using paired effluent pH and temperature data, collected during the period from February 2018 through January 2022. The most stringent CMC of 6.1 mg/L (ammonia as N) calculated has been implemented in this Order.

The chronic (30-day average) criterion or CCC was calculated using paired downstream receiving water pH and temperature data, collected during the period from February 2018 through January 2022. The most stringent 30-day rolling average CCC of 3.4 mg/L (ammonia as N) has been implemented in this Order.

The chronic (4-day average) concentration is derived in accordance with the U.S. EPA criterion as 2.5 times the 30-day CCC. Based on the 30-day CCC of 3.4 mg/L (ammonia as N), the 4-day average concentration that should not be exceeded is 8.5 mg/L (ammonia as N).

- (b) **RPA Results.** The Facility is a POTW that treats domestic wastewater. Untreated domestic wastewater contains ammonia in concentrations that is harmful to aquatic life and exceed the Basin Plan narrative toxicity objective. The Discharger currently uses a biological nutrient removal treatment system to remove ammonia from the waste stream. Inadequate or incomplete treatment may result in the discharge of ammonia to the receiving stream, which creates the basis for the discharge to have a reasonable potential to cause or contribute to an instream excursion above the site-specific acute and chronic criteria for ammonia provided by the January 2020 Criteria

Recalculation Report. Therefore, the Central Valley Water Board finds the discharge has reasonable potential for ammonia and WQBELs are required.

- (c) **WQBELs.** The Central Valley Water Board calculates WQBELs in accordance with SIP procedures for non-CTR constituents, and ammonia is a non-CTR constituent. The SIP procedure assumes a 4-day averaging period for calculating the long-term average discharge condition (LTA). However, U.S. EPA recommends modifying the procedure for calculating permit limits for ammonia using a 30-day averaging period for the calculation of the LTA corresponding to the 30-day CCC. Therefore, while the LTAs corresponding to the acute and 4-day chronic criteria were calculated according to SIP procedures, the LTA corresponding to the 30-day CCC was calculated assuming a 30-day averaging period. This Order contains a final average monthly effluent limitation (AMEL) and average weekly effluent limitation (AWEL) for ammonia of 2.9 mg/L and 5.2 mg/L, respectively, based on the site-specific ammonia criteria for the Feather River.
- (d) **Plant Performance and Attainability.** Based on the available effluent data, the Central Valley Water Board concludes that immediate compliance with these effluent limitations is feasible.

ii. **Chlorine Residual**

- (a) **WQO.** U.S. EPA developed NAWQC for protection of freshwater aquatic life for chlorine residual. The recommended 4-day average (chronic) and 1-hour average (acute) criteria for chlorine residual are 0.011 mg/L and 0.019 mg/L, respectively. These criteria are protective of the Basin Plan's narrative toxicity objective.
- (b) **RPA Results.** The concentrations of chlorine used to disinfect wastewater are high enough to harm aquatic life and violate the Basin Plan narrative toxicity objective if discharged to the receiving water. Reasonable potential therefore does exist and effluent limits are required.

The Discharger uses chlorine for disinfection, which is extremely toxic to aquatic organisms. Although the Discharger uses a sulfur dioxide process to dechlorinate the effluent prior to discharge to the Feather River, the existing chlorine use and the potential for chlorine to be discharged provides the basis for the discharge to have a reasonable potential to cause or contribute to an instream excursion above the NAWQC.

- (c) **WQBELs.** The U.S. EPA's TSD for Water Quality-Based Toxics Control [EPA/505/2-90-001] contains statistical methods for converting chronic (4-day) and acute (1-hour) aquatic life criteria to average monthly and maximum daily effluent limitations based on the variability of the existing data and the expected frequency of monitoring. However, because chlorine is an acutely toxic constituent that can and will be monitored continuously, an average 1-hour limitation is considered more appropriate than an average daily limitation. This Order contains a 4-day average effluent limitation and 1-hour average effluent limitation for chlorine residual of 0.011 mg/L and 0.019 mg/L, respectively, based on U.S. EPA's NAWQC, which implements the Basin Plan's narrative toxicity objective for protection of aquatic life.
- (d) **Plant Performance and Attainability.** The Discharger uses sulfur dioxide to dechlorinate the effluent prior to discharges to the Feather River at Discharge Point 001. The Central Valley Water Board concludes, therefore, that immediate compliance with these effluent limitations is feasible.

iii. **Chlorodibromomethane**

- (a) **WQO.** The CTR includes a criterion of 0.41 µg/L for chlorodibromomethane for the protection of human health for waters from which both water and organisms are consumed.
- (b) **RPA Results.** The MEC for chlorodibromomethane was 6.2 µg/L based on thirty-nine samples collected between February 2018 and January 2022. The maximum background receiving water concentration for chlorodibromomethane was <0.13 µg/L based on four samples collected between 2018 and January 2022. Therefore, chlorodibromomethane in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.
- (c) **WQBELs.** The receiving water contains assimilative capacity for chlorodibromomethane; therefore, as discussed in section IV.C.2.c of this Fact Sheet, a dilution credit of 331:1 may be allowed in the development of the WQBEL's for chlorodibromomethane. However, the Central Valley Water Board finds that granting of this dilution credit would allocate an unnecessarily large portion of the receiving water's assimilative capacity for chlorodibromomethane and could violate the Antidegradation Policy. Therefore, this Order includes effluent limitations based on treatment plant performance and calculated far below the receiving water's assimilative capacity. The 99

percent occurrence probability multiplier contained in Table 5-2 of the TSD was used to determine an AMEL. The performance-based AMEL was calculated by multiplying the maximum observed effluent concentration by a multiplier of 3.11 (TSD, Table 5-2), resulting in an AMEL of 18 µg/L. The MDEL was calculated by multiplying the AMEL by the MDEL/AMEL multiplier of 2.01 from Table 2 of the SIP, resulting in an MDEL of 36 µg/L.

- (d) **Plant Performance and Attainability.** The effluent limitations for chlorodibromomethane are based on Facility performance. The Central Valley Water Board concludes, therefore, that immediate compliance with these effluent limitations is feasible.

#### iv. Dichlorobromomethane

- (a) **WQO.** The CTR includes a criterion of 0.56 µg/L for dichlorobromomethane for the protection of human health for waters from which both water and organisms are consumed.
- (b) **RPA Results.** The MEC for dichlorobromomethane was 27 µg/L based on seventy-three samples collected between February 2018 and January 2022. The maximum background receiving water concentration for dichlorobromomethane was <0.14 µg/L based on four samples collected between 2018 and January 2022. Therefore, dichlorobromomethane in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for the protection of human health.
- (c) **WQBELs.** The receiving water contains assimilative capacity for dichlorobromomethane; therefore, as discussed in section IV.C.2.c of this Fact Sheet, a dilution credit of 331:1 may be allowed in the development of the WQBEL's for dichlorobromomethane. However, the Central Valley Water Board finds that granting of this dilution credit would allocate an unnecessarily large portion of the receiving water's assimilative capacity for dichlorobromomethane and could violate the Antidegradation Policy. Therefore, this Order includes effluent limitations based on treatment plant performance and calculated far below the receiving water's assimilative capacity. In developing the performance-based AMEL, where there are 10 sampling data points or more, sampling and laboratory variability is accounted for by establishing interim limits that are based on normally distributed data where 99.9% of the data points will lie within 3.3 standard deviations of the mean (Basic Statistical Methods for Engineers and Scientists, Kennedy and Neville, Harper and Row). Therefore, the performance-based

AMEL for dichlorobromomethane was established as the mean plus 3.3 standard deviations of the available data, resulting in an AMEL of 38 µg/L. The MDEL was calculated by multiplying the AMEL by the MDEL/AMEL multiplier of 1.84 from Table 2 of the SIP, resulting in an MDEL of 70 µg/L.

- (d) **Plant Performance and Attainability.** The effluent limitations for dichlorobromomethane are based on Facility performance. The Central Valley Water Board concludes, therefore, that immediate compliance with these effluent limitations is feasible.

v. **Nitrate and Nitrite**

- (a) **WQO.** DDW has adopted Primary MCLs for the protection of human health for nitrite and nitrate that are equal to 1 mg/L and 10 mg/L (measured as nitrogen), respectively. DDW has also adopted a Primary MCL of 10 mg/L for the sum of nitrate and nitrite, measured as nitrogen.

U.S. EPA has developed a primary MCL and an MCL goal of 1 mg/L for nitrite (as nitrogen). For nitrate, U.S. EPA has developed Drinking Water Standards (10 mg/L as Primary MCL) and NAWQC for protection of human health (10 mg/L for non-cancer health effects).

- (b) **RPA Results.** The Facility is a POTW that treats domestic wastewater. Untreated domestic wastewater contains ammonia in concentrations that is harmful to aquatic life and exceed the Basin Plan's narrative toxicity objective. The Discharger currently uses a two-step biological nutrient removal treatment process to first convert the ammonia to nitrate, then remove the nitrate from the waste stream. Inadequate or incomplete treatment may result in the discharge of nitrate and/or nitrite to the receiving stream in concentrations that may exceed the Primary MCL and would violate the Basin Plan's narrative chemical constituents' objective. Therefore, the Central Valley Water Board finds the discharge has a reasonable potential to cause or contribute to an instream excursion above the Primary MCL and WQBELs are required for nitrate plus nitrite.
- (c) **WQBELs.** This Order contains an average monthly effluent limitation (AMEL) and average weekly effluent limitation (AWEL) for nitrate plus nitrite of 10 µg/L and 17 µg/L, respectively, based on the Basin Plan's narrative chemical constituents objective for protection of the MUN beneficial use. These effluent limitations are included in this Order to assure the treatment process adequately nitrifies and denitrifies the waste

stream to protect the beneficial use of municipal and domestic supply.

- (d) **Plant Performance and Attainability.** Based on the available effluent data, the Central Valley Water Board concludes that immediate compliance with these effluent limitations is feasible.

vi. **Pathogens**

- (a) **WQO.** DDW has developed reclamation criteria, CCR, Division 4, Chapter 3 (Title 22), for the reuse of wastewater. Title 22 requires that for spray irrigation of food crops, parks, playgrounds, schoolyards, and other areas of similar public access, wastewater be adequately disinfected, oxidized, coagulated, clarified, and filtered, and that the effluent total coliform levels not exceed 2.2 MPN/100 mL as a 7-day median; 23 MPN/100 mL, not to be exceeded more than once in a 30-day period; and 240 MPN/100 mL, at any time. Title 22 is not directly applicable to surface waters; however, the Central Valley Water Board finds the stringent disinfection criteria are appropriate since the undiluted effluent may be used for the irrigation of food crops and/or for body-contact water recreation. Coliform organisms are intended as an indicator of the effectiveness of the entire treatment train and the effectiveness of removing other pathogens.
- (b) **RPA Results.** Raw domestic wastewater inherently contains human pathogens that threaten human health and life, and constitute a threatened pollution and nuisance under CWC section 13050 if discharged untreated to the receiving water. The beneficial uses of Lower Feather River include municipal and domestic supply, water contact recreation, and agricultural irrigation supply. To protect these beneficial uses, the Central Valley Water Board finds that the wastewater must be disinfected and adequately treated to prevent disease. Although the Discharger provides disinfection, inadequate or incomplete disinfection creates the potential for pathogens to be discharged. Therefore, the Central Valley Water Board finds the discharge has reasonable potential for pathogens and WQBELs are required.
- (c) **WQBELs.** Special Provisions VI.C.6.a of this Order requires, "Wastewater shall be oxidized, coagulated, filtered, and adequately disinfected pursuant to the State Water Board, DDW reclamation criteria, CCR, Title 22, division 4, chapter 3, (Title 22), or equivalent." In accordance with the requirements of Title 22, this Order includes effluent limitations for total coliform organisms of 2.2 MPN/100 mL as a 7-day median; 23 MPN/100

mL, not to be exceeded more than once in a 30-day period; and 240 MPN/100 mL as an instantaneous maximum.

The tertiary treatment process, or equivalent, is capable of reliably treating wastewater to a turbidity level of 2 nephelometric turbidity units (NTU) as a daily average. Failure of the filtration system such that virus removal is impaired would normally result in increased particles in the effluent, which result in higher effluent turbidity. Turbidity has a major advantage for monitoring filter performance. Coliform testing, by comparison, is not conducted continuously and requires several hours, to days, to identify high coliform concentrations. Therefore, in addition to total coliform organisms effluent limitations, this Order includes operational specifications for turbidity of 2 NTU as a daily average; 5 NTU, not to be exceeded more than 5 percent of the time within a 24-hour period; and 10 NTU as an instantaneous maximum.

This Order contains effluent limitations for BOD<sub>5</sub>, total coliform organisms, and TSS and requires a tertiary level of treatment, or equivalent, necessary to protect the beneficial uses of the receiving water. The Central Valley Water Board has previously considered the factors in Water Code section 13241 in establishing these requirements.

Final WQBELs for BOD<sub>5</sub> and TSS are also required based on the technical capability of the tertiary process. The tertiary treatment standards for BOD<sub>5</sub> and TSS are indicators of the effectiveness of the tertiary treatment process. The principal design parameter for wastewater treatment plants is the daily BOD<sub>5</sub> and TSS loading rates and the corresponding removal rate of the system. The application of tertiary treatment processes results in the ability to achieve lower levels for BOD<sub>5</sub> and TSS than the technology-based secondary standards. Therefore, this Order requires AMELs for BOD<sub>5</sub> and TSS of 10 mg/L, which is technically based on the capability of a tertiary system.

- (d) **Plant Performance and Attainability.** The Facility includes tertiary treatment facilities that enable the Discharger to comply with the WQBELs. The Central Valley Water Board concludes that immediate compliance with these effluent limitations is feasible.

vii. **pH**

- (a) **WQO.** The Basin Plan includes a water quality objective for surface waters (except for Goose Lake) that the “pH shall not be depressed below 6.5 nor raised above 8.5.”
- (b) **RPA Results.** Raw domestic wastewater inherently has variable pH. Additionally, some wastewater treatment processes can increase or decrease wastewater pH which if not properly controlled, would violate the Basin Plan’s numeric objective for pH in the receiving water. Therefore, reasonable potential exists for pH and WQBELs are required.
- (c) **WQBELs.** Effluent limitations for pH of 6.5 as an instantaneous minimum and 8.5 as an instantaneous maximum are included in this Order based on protection of the Basin Plan objectives for pH.

This Order includes an instantaneous minimum effluent limitation for pH of 6.5 for discharges to the Feather River at Discharge Point 001, based on the Basin Plan objective. However, consistent with Order R5-2017-0094, this Order includes an instantaneous minimum effluent limitation of 6.0 for discharges to the percolation ponds at Discharge Point 002. The soil beneath the percolation ponds will buffer the lower pH prior to discharge to the Feather River. The reduction in pH will also be minimized by the retention time in the ponds which can increase the pH by the change in temperature, etc.

- (d) **Plant Performance and Attainability.** Based on the available effluent data, the Central Valley Water Board concludes that immediate compliance with these effluent limitations is feasible.

**4. WQBEL Calculations**

- a. This Order includes WQBELs for ammonia, BOD<sub>5</sub>, chlorine residual, chlorodibromomethane, dichlorobromomethane, nitrate plus nitrite, pH, total coliform organisms, and TSS. The general methodology for calculating WQBELs based on the different criteria/objectives is described in subsections IV.C.5.b through e, below. See Attachment H for the WQBEL calculations.
- b. **Effluent Concentration Allowance.** For each water quality criterion/objective, the ECA is calculated using the following steady-state mass balance equation from section 1.4 of the SIP:

$$\begin{aligned} \text{ECA} &= C + D(C - B) \text{ where } C > B, \text{ and} \\ \text{ECA} &= C \text{ where } C \leq B \end{aligned}$$

where:

ECA = effluent concentration allowance

D = dilution credit

C= the priority pollutant criterion/objective

B= the ambient background concentration.

According to the SIP, the ambient background concentration (B) in the equation above shall be the observed maximum with the exception that an ECA calculated from a priority pollutant criterion/objective that is intended to protect human health from carcinogenic effects shall use the arithmetic mean concentration of the ambient background samples.

- c. **Primary and Secondary MCLs.** For non-priority pollutants with primary MCLs to protect human health (e.g., nitrate plus nitrite), the AMEL is set equal to the primary MCL and the AWEL is calculated using the AWEL/AMEL multiplier, where the AWEL multiplier is based on a 98<sup>th</sup> percentile occurrence probability and the AMEL multiplier is from Table 2 of the SIP.

For non-priority pollutants with secondary MCLs that protect public welfare (e.g., taste, odor, and staining), WQBELs were calculated by setting the LTA equal to the secondary MCL and using the AMEL multiplier to set the AMEL. The AWEL was calculated using the MDEL/AMEL multiplier from Table 2 of the SIP.

- d. **Aquatic Toxicity Criteria.** For priority pollutants with acute and chronic aquatic toxicity criteria, the WQBELs are calculated in accordance with section 1.4 of the SIP. The ECAs are converted to equivalent long-term averages (i.e. LTA<sub>acute</sub> and LTA<sub>chronic</sub>) using statistical multipliers and the lowest LTA is used to calculate the AMEL and MDEL using additional statistical multipliers. For non-priority pollutants, WQBELs are calculated using similar procedures, except that an AWEL is determined utilizing multipliers based on a 98<sup>th</sup> percentile occurrence probability.
- e. **Human Health Criteria.** For priority pollutants with human health criteria, the WQBELs are calculated in accordance with section 1.4 of the SIP. The AMEL is set equal to the ECA and the MDEL is calculated using the MDEL/AMEL multiplier from Table 2 of the SIP. For non-priority pollutants with human health criteria, WQBELs are calculated using similar procedures, except that an AWEL is established using the MDEL/AMEL multiplier from Table 2 of the SIP.

$$AMEL = mult_{AMEL} \left[ \min \left( \overbrace{M_A ECA_{acute}, M_C ECA_{chronic}}^{LTA_{acute}} \right) \right]$$

$$MDEL = mult_{MDEL} \left[ \min \left( \underbrace{M_A ECA_{acute}, M_C ECA_{chronic}}^{LTA_{chronic}} \right) \right]$$

$$MDEL_{HH} = \left( \frac{mult_{MDEL}}{mult_{AMEL}} \right) AMEL_{HH}$$

where:

- mult<sub>AMEL</sub> = statistical multiplier converting minimum LTA to AMEL
- mult<sub>MDEL</sub> = statistical multiplier converting minimum LTA to MDEL
- M<sub>A</sub> = statistical multiplier converting acute ECA to LTA<sub>acute</sub>
- M<sub>C</sub> = statistical multiplier converting chronic ECA to LTA<sub>chronic</sub>

**Summary of Water Quality-Based Effluent Limitations  
Discharge Point Discharge Points 001 and 002**

**Table F-15 Summary of Water Quality-Based Effluent Limitations**

Parameter	Units	Average Monthly Effluent Limitations	Average Weekly Effluent Limitations	Maximum Daily Effluent Limitations
Biochemical Oxygen Demand, 5-day @ 20°Celsius (BOD <sub>5</sub> )	milligrams per liter (mg/L)	10	15	--
Total Suspended Solids (TSS)	mg/L	10	15	--
pH	standard units	(see table note 1. below)	--	--
Chlorodibromomethane	µg/L	18	--	36
Dichlorobromomethane	µg/L	38	--	70
Ammonia Nitrogen, Total (as N)	mg/L	2.9	5.2	--
Nitrate Plus Nitrite (as N)	mg/L	10	17	--
Mercury, Total Recoverable	lbs/year	(see table note 2. below)	--	--
Chlorine, Total Residual	mg/L	--	0.011 (see	0.019 (see

Parameter	Units	Average Monthly Effluent Limitations	Average Weekly Effluent Limitations	Maximum Daily Effluent Limitations
			table note 3. below)	table note 4. below)
Diazinon and Chlorpyrifos	µg/L	(see table note 5. below)	(see table note 6. below)	--
Nitrate Plus Nitrite (as N)	mg/L	10	17	--
Total Coliform Organisms	MPN/100 mL	23 (see table note 7. below)	2.2 (see table note 8. below)	--

**Table F-15 Notes:**

1. Instantaneous Minimum of 6.5 at Discharge Point 001, 6.0 at Discharge Point 002 and Instantaneous Maximum of 8.0
2. The total annual mass discharge of total mercury shall not exceed 0.46 pounds/year
3. Applied as a 4-day average effluent limitation. Applicable at Discharge Point 001 only.
4. Applied as a 1-Hour average effluent limitation. Applicable at Discharge Point 001 only.
5. Average Monthly Effluent Limit:  

$$\text{SAMEL} = \text{CD M-avg}/0.079 + \text{CC M-avg}/0.012 \leq 1.0$$

CD M-AVG = average monthly diazinon effluent concentration in µg/L.  
 CC M-AVG = average monthly chlorpyrifos effluent concentration in µg/L
6. Average Weekly Effluent Limit:  

$$\text{SAWEL} = \text{CD W-avg}/0.14 + \text{CC W-avg}/0.021 \leq 1.0$$

CD W-AVG = average weekly diazinon effluent concentration in µg/L.  
 CC W-AVG = average weekly chlorpyrifos effluent concentration in µg/L.
7. Not to be exceeded more than once in any 30-day period.
8. Applied as a 7-day median effluent limitation.

**5. Whole Effluent Toxicity (WET)**

For compliance with the Basin Plan’s narrative toxicity objective, this Order requires the Discharger to conduct whole effluent toxicity testing for acute and chronic toxicity, as specified in the Monitoring and Reporting Program (Attachment E section V). This Order also contains effluent limitations for acute

toxicity and requires the Discharger to implement best management practices to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity.

- a. **Acute Toxicity.** The Basin Plan contains a narrative toxicity objective that states, "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life." (Basin Plan at page III-8.00.) The Basin Plan also states that, "...effluent limits based upon acute biotoxicity tests of effluents will be prescribed where appropriate...".

For priority pollutants, the SIP dictates the procedures for conducting the RPA. Acute toxicity is not a priority pollutant. Therefore, the Central Valley Water Board is not restricted to one particular RPA method. Acute whole effluent toxicity is not a priority pollutant. Therefore, due to the site-specific conditions of the discharge, the Central Valley Water Board has used professional judgment in determining the appropriate method for conducting the RPA. USEPA's September 2010 NPDES Permit Writer's Manual, page 6-30, states, "*State implementation procedures might allow, or even require, a permit writer to determine reasonable potential through a qualitative assessment process without using available facility-specific effluent monitoring data or when such data are not available...A permitting authority might also determine that WQBEL's are required for specific pollutants for all facilities that exhibit certain operational or discharge characteristics (e.g., WQBEL's for pathogens in all permits for POTW's discharging to contact recreational waters).*" Acute toxicity effluent limits are required to ensure compliance with the Basin Plan's narrative toxicity objective.

USEPA Region 9 provided guidance for the development of acute toxicity effluent limitations in the absence of numeric water quality objectives for toxicity in its document titled "Guidance for NPDES Permit Issuance", dated February 1994.

Section B.2. "Toxicity Requirements" (pgs. 14-15) states that, "In the absence of specific numeric water quality objectives for acute and chronic toxicity, the narrative criterion 'no toxics in toxic amounts' applies. Achievement of the narrative criterion, as applied herein, means that ambient waters shall not demonstrate for acute toxicity: 1) less than 90% survival, 50% of the time, based on the monthly median, or 2) less than 70% survival, 10% of the time, based on any monthly median. For chronic toxicity, ambient waters shall not demonstrate a test result of greater than 1 TUc." Accordingly, effluent limitations for acute toxicity have been included in this Order as follows:

**Acute Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

Minimum for any one bioassay.....	70%
Median for any three consecutive bioassays.....	90%

- b. **Chronic Toxicity.** The Basin Plan contains a narrative toxicity objective that states, “All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” (Basin Plan at page III-8.00.) Adequate chronic WET data is not available to determine if the discharge has reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan’s narrative toxicity objective.

A dilution ratio of 11:1 (receiving water to effluent) is available for chronic whole effluent toxicity at Discharge Points 001 and 002. The Monitoring and Reporting Program of this Order requires chronic WET monitoring once during the permit term for demonstration of compliance with the narrative toxicity objective. In addition to WET monitoring, the Special Provision in section VI.C.2.a of the Order requires the Discharger to submit to the Central Valley Water Board an Initial Investigative TRE Workplan for approval by the Executive Officer, to ensure the Discharger has a plan to immediately move forward with the initial tiers of a TRE, in the event effluent toxicity is encountered in the future. The provision also includes a numeric toxicity monitoring trigger, requirements for accelerated monitoring, and requirements for TRE initiation if toxicity is demonstrated.

Numeric chronic WET effluent limitations have not been included in this Order. The SIP contains implementation gaps regarding the appropriate form and implementation of chronic toxicity limits. This has resulted in the petitioning of a NPDES permit in the Los Angeles Region (In the Matter of the Review of Own Motion of Waste Discharge Requirements Orders R4-2002-0121 [NPDES No. CA0054011] and R4-2002-0123 [NPDES No. CA0055119] and Time Schedule Orders R4-2002-0122 and R4-2002-0124 for Los Coyotes and Long Beach Wastewater Reclamation Plants Issued by the California Regional Water Quality Control Board, Los Angeles Region SWRCB/OCC FILES A-1496 AND 1496(a)) that contained numeric chronic toxicity effluent limitations. To address the petition, the State Water Board adopted WQO 2003-012 directing its staff to revise the toxicity control provisions in the SIP. The State Water Board states the following in WQO 2003-012, “In reviewing this petition and receiving comments from numerous interested persons on the propriety of including numeric effluent limitations for chronic toxicity in NPDES permits for publicly-owned treatment works that discharge to inland waters, we have determined that this issue should be considered in a regulatory setting, in order to allow for full public discussion and deliberation. We

intend to modify the SIP to specifically address the issue. We anticipate that review will occur within the next year. We therefore decline to make a determination here regarding the propriety of the final numeric effluent limitations for chronic toxicity contained in these permits.” The process to revise the SIP is currently underway. Proposed changes include clarifying the appropriate form of effluent toxicity limits in NPDES permits and general expansion and standardization of toxicity control implementation related to the NPDES permitting process. Since the toxicity control provisions in the SIP are under revision it is infeasible to develop numeric effluent limitations for chronic toxicity. Therefore, this Order requires that the Discharger meet best management practices for compliance with the Basin Plan’s narrative toxicity objective, as allowed under 40 CFR 122.44(k).

To ensure compliance with the Basin Plan’s narrative toxicity objective, the Discharger is required to conduct chronic WET testing, as specified in the Monitoring and Reporting Program (Attachment E section V.). Furthermore, the Special Provision contained at VI.C.2.a. of this Order requires the Discharger to investigate the causes of, and identify and implement corrective actions to reduce or eliminate effluent toxicity. If the discharge demonstrates toxicity exceeding the numeric toxicity monitoring trigger, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE) in accordance with an approved TRE workplan. The numeric toxicity monitoring trigger is not an effluent limitation; it is the toxicity threshold at which the Discharger is required to perform accelerated chronic toxicity monitoring, as well as, the threshold to initiate a TRE if effluent toxicity has been demonstrated.

**D. Final Effluent Limitation Considerations**

**1. Mass Based Effluent Limitations – Not Applicable**

**2. Averaging Periods for Effluent Limitations**

40 C.F.R. section 122.45 (d) requires average weekly and average monthly discharge limitations for POTWs unless impracticable. For ammonia, BOD<sub>5</sub>, and TSS, maximum daily effluent limitations have been replaced with average weekly effluent limitations in accordance with section 1.4 of the SIP.

Furthermore for ammonia, BOD<sub>5</sub>, and TSS, maximum daily effluent limitations have been replaced or supplemented with effluent limitations utilizing shorter averaging periods. The rationale for using shorter averaging periods for these constituents is discussed in section IV.C.3 of this Fact Sheet.

**3. Satisfaction of Anti-Backsliding Requirements**

The CWA specifies that a revised permit may not include effluent limitations that are less stringent than the previous permit unless a less stringent limitation

is justified based on exceptions to the anti-backsliding provisions contained in CWA sections 402(o) or 303(d)(4), or, where applicable, 40 C.F.R. section 122.44(l).

All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order, with the exception of effluent limitations for bis (2-ethylhexyl) phthalate, maximum daily effluent limitations and mass-based effluent limitations for BOD<sub>5</sub> and TSS, mass-based effluent limitation for ammonia, and the maximum instantaneous limit for pH. The effluent limitations for these pollutants are less stringent than those in Order R5-2017-0094. This relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

- a. **CWA section 402(o)(1) and 303(d)(4).** CWA section 402(o)(1) prohibits the establishment of less stringent water quality-based effluent limits “except in compliance with Section 303(d)(4).” CWA section 303(d)(4) has two parts: paragraph (A) which applies to nonattainment waters and paragraph (B) which applies to attainment waters.
  - i. For waters where standards are not attained, CWA section 303(d)(4)(A) specifies that any effluent limit based on a TMDL or other WLA may be revised only if the cumulative effect of all such revised effluent limits based on such TMDLs or WLAs will assure the attainment of such water quality standards.
  - ii. For attainment waters, CWA section 303(d)(4)(B) specifies that a limitation based on a water quality standard may be relaxed where the action is consistent with the antidegradation policy.

The Feather River is considered an attainment water for ammonia, bis (2-ethylhexyl) phthalate, BOD<sub>5</sub>, TSS, and pH because the receiving water is not listed as impaired on the 303(d) list for this constituent. The exceptions in section 303(d)(4) address both waters in attainment with water quality standards and those not in attainment, i.e. waters on the section 303(d) impaired waters list. As discussed in section IV.D.4, below, relaxation or removal of the effluent limits complies with federal and state antidegradation requirements. Thus, relaxation of effluent limitations for ammonia, BOD<sub>5</sub>, TSS and pH and removal of the effluent limitations for bis (2-ethylhexyl) phthalate from Order R5-2017-0094 meets the exception in CWA section 303(d)(4)(B).

- b. **CWA section 402(o)(2).** CWA section 402(o)(2) provides several exceptions to the anti-backsliding regulations. CWA 402(o)(2)(B)(i) allows a renewed, reissued, or modified permit to contain a less stringent effluent limitation for a pollutant if information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or

test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.

As described further in section IV.C.3.b of this Fact Sheet, updated information that was not available at the time Order R5-2017-0094 was issued indicates that bis (2-ethylhexyl) phthalate do not exhibit reasonable potential to cause or contribute to an exceedance of water quality objectives in the receiving water. Additionally, updated information that was not available at the time Order R5-2017-0094 was issued indicates that less stringent effluent limitations for ammonia, BOD<sub>5</sub>, TSS, and pH based on available dilution credits satisfy requirements in CWA section 402(o)(2). The updated information that supports the relaxation of effluent limitations for these constituents includes the following:

- i. **Bis (2-ethylhexyl) Phthalate.** Effluent and receiving water monitoring data collected from February 2018 through January 2022 for bis (2-ethylhexyl) phthalate indicates that the discharge does not exhibit reasonable potential to cause or contribute to an exceedance of the CTR human health criteria.
- c. **Flow.** Order R5-2017-0094 included an average dry weather discharge flow effluent limitation at Discharge Point 001 based on the Facility design flow. Compliance with the flow limit was calculated using the average daily flow over three consecutive dry weather months. Flow is not a pollutant and therefore has been changed from an effluent limit to a discharge prohibition in this Order, which is an equivalent level of regulation. This Order is not less stringent because compliance with flow as a discharge prohibition will be calculated the same way as the previous Order. Flow as a discharge prohibition adequately regulates the Facility, does not allow for an increase in the discharge of pollutants, and does not constitute backsliding.

#### 4. Antidegradation Policies

- a. **2011 Antidegradation Analysis.** As discussed in section II.E of this Fact Sheet, the Discharger is implementing a regionalization project that would increase the design capacity of the Facility from 5.0 MGD to 6.7 MGD. Order R5-2012-0034 provided antidegradation findings and authorized an increase in the permitted flow to 6.7 MGD from the regionalized Facility, which was reauthorized in Order R5-2017-0094. This Order did not provide for an increase in flow or mass of pollutants to the receiving water beyond the levels authorized in Order R5-2012-0034. Therefore, a complete antidegradation analysis is not necessary. A summary of the complete antidegradation analysis approved by the Central Valley Water Board in 2012 and updated information since adoption of Order R5-2012-0034 is included below:

The Discharger requested in its May 2011 ROWD to discharge up to an average dry weather flow of 6.7 MGD as part of a regionalization project with the City of Marysville WWTP. WDR Order No. 5-01-071 authorized the City of Marysville WWTP to discharge up to 1.7 MGD of secondary treated wastewater to a series of percolation ponds located at the confluence of the Yuba River and the Feather River within the Feather River levee system approximately 2 miles upstream of the Facility. These percolation ponds are protected by levees from only a 10-year flood event. WDR Order No. 5-01-071 prohibited the City of Marysville WWTP from discharging waste to surface waters, including the Feather River, and required the City of Marysville to design, construct, operate, and maintain the facility such that inundation or washout due to flooding from a storm with a 100-year annual return period does not occur. Although discharges to the Feather River from the City of Marysville WWTP were not authorized, during flood events that inundate the percolation ponds, secondary treated wastewater in the percolation ponds is discharged to the Feather River. Additionally, wastewater in the ponds percolates to groundwater, which has been shown to seep into the Feather River. Therefore, the Central Valley Water Board issued Cease and Desist Order (CDO) No. R5-2004-0072 on 4 June 2004, which provided the City of Marysville with a time schedule to make facility improvements and prepare a Feasibility Study and Master Plan Report describing how the wastewater storage and disposal area will be protected from flooding caused by storm events with a 100-year annual return period. The City of Marysville submitted a 27 June 2007 City of Marysville Feasibility Study and Master Plan Results Report (Kennedy/Jenks Consultants) which determined that regionalization with the Facility is the preferred alternative. The Central Valley Water Board subsequently adopted CDO No. R5-2008-0110 on 31 July 2008, which provided the City of Marysville with a time schedule to implement the preferred alternative (i.e., regionalization), which was later extended by CDO No. R5-2009-0014.

The Discharger developed a May 2011 Antidegradation Analysis of Proposed Discharge Modification for the Linda County Water District Wastewater Treatment Plant (Larry Walker Associates), that provided an antidegradation analysis following the guidance provided by State Water Board Administrative Procedures Update (APU) 90-004. Pursuant to the guidelines, the Antidegradation Analysis evaluated whether changes in water quality resulting from the proposed increase in discharge to the Feather River (from 5.0 MGD to 6.7 MGD of tertiary treated wastewater) are consistent with the maximum benefit to the people of the State, will not unreasonably affect beneficial uses, will not cause water quality to be less than water quality objectives, and that the discharge provides protection for existing in-stream uses and water quality necessary to protect those uses. Findings from the Antidegradation Analysis are summarized below.

- i. Water quality parameters and beneficial uses which will be affected by the proposed expansion and the extent of the impact. Compliance with this Order will not adversely impact beneficial uses of the receiving water or downstream receiving waters. All beneficial uses will be maintained and protected. 40 C.F.R. section 131.12 defines the following tier designations to describe water quality in the receiving water body.

*Tier 1 Designation: Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected. (40 C.F.R. § 131.12)*

*Tier 2 Designation: Where the quality of waters exceed levels necessary to support propagation of fish, shellfish, and wildlife and recreation in and on the water, that quality shall be maintained and protected unless the State finds, after full satisfaction of the intergovernmental coordination and public participation provisions of the State's continuing planning process, that allowing lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In allowing such degradation or lower water quality, the State shall assure water quality adequate to protect existing uses fully. Further, the State shall assure that there shall be achieved the highest statutory and regulatory requirements for all new and existing point sources and all cost-effective and reasonable best management practices for nonpoint source control. (40 C.F.R. § 131.12)*

The tier designation is assigned on a pollutant-by-pollutant basis. The Antidegradation Analysis did not delineate the tier designation for pollutants, but instead conducted an analysis of the potential impact of each constituent and its use of assimilative capacity. The Feather River is listed on the 303(d) list as impaired by only one of the constituents that was evaluated in the Antidegradation Analysis, mercury. Therefore, the Feather River is considered a Tier 1 receiving water for mercury. The Feather River was not listed as impaired by the remaining constituents assessed, and therefore, the Feather River was considered a Tier 2 receiving water for these pollutants.

Based on the Discharger's 2011 Antidegradation Analysis, the proposed discharge would result in an increase in mass loading, compared with the current condition (i.e., separate discharges of 5.0 MGD of tertiary treated wastewater from the Facility and 1.7 MGD of secondary treated wastewater from the City of Marysville WWTP) for dichlorobromomethane (18 percent), manganese (17 percent), and salinity (4 percent). For all other constituents, the proposed discharge

was expected to result in a reduction in mass loading to the Feather River compared to the current condition.

Based on updated monitoring data collected between August 2013 and July 2016, the discharge no longer exhibited reasonable potential to cause or contribute to an in-stream excursion above the Secondary MCL for manganese, and effluent limitations for manganese were not retained in Order R5-2017-0094. Removal of effluent limitations and increase in Facility discharge is not expected to result in an increase in pollutant concentration or loading, a decrease in the level of treatment or control, or a reduction of water quality.

Based on updated monitoring data collected between August 2013 and July 2016, the Facility cannot consistently comply with the existing performance-based effluent limitations, and the Feather River has sufficient dilution and assimilative capacity available for dichlorobromomethane. Therefore, Order R5-2017-0094 included less stringent effluent limitations for dichlorobromomethane, allowing for an increased use of assimilative capacity as compared to that projected in the 2011 Antidegradation Analysis.

Based on updated monitoring data collected between August 2013 and July 2016, Order R5-2017-0094 discontinued effluent limitations for electrical conductivity. Although the effluent limitations were discontinued, the removal of effluent limitations and increase in Facility discharge was not expected to result in an increase in pollutant concentration or loading, a decrease in the level of treatment or control, or a reduction of water quality.

As discussed below, the antidegradation analysis evaluated whether allowance of an increase in dichlorobromomethane concentrations was in the best interest of the people of the State.

- ii. **Scientific Rationale for Determining Potential Lowering of Water Quality.** The rationale used in the Antidegradation Analysis is based on 40 C.F.R. section 131.12, U.S. EPA memorandum Regarding Tier 2 Antidegradation Reviews and Significance Thresholds (U.S. EPA 2005), U.S. EPA Region 9 Guidance on Implementing the Antidegradation Provisions of 40 C.F.R. 131.12 (U.S. EPA 1987), the State Anti-Degradation Policy, a State Water Board 1987 policy memorandum to the Regional Water Boards, and an Administrative Procedures Update (APU 90-004) issued by the State Water Board to the Regional Water Boards.

The scientific rationale used in the Antidegradation Analysis to determine if Order R5-2017-0094 allows a lowering of water quality was based on a comparison of the mass loadings to the Feather River

with loadings from the proposed regionalized Facility. The Antidegradation Analysis analyzed each pollutant detected in the effluent from the Facility and the City of Marysville WWTP to determine if the proposed increase in discharge from 5.0 MGD to 6.7 MGD authorized by this Order potentially allows significant increase of the amount of pollutants present in the upstream and downstream receiving water influenced by the proposed discharge. Pollutants that significantly increase concentration or mass downstream require an alternatives analysis to determine whether implementation of alternatives to the proposed action is in the best socioeconomic interest of the people of the region, and to the maximum benefit of the people of the State.

The Central Valley Water Board concurred with this scientific approach.

- iii. **Alternative Control Measures Considered.** The State Anti-Degradation Policy requires that degradation of water quality be consistent with maximum benefit to the people of the State. APU 90-004 identifies factors to be considered for regulatory actions “that, in the Regional Board’s judgement [sic], will result in a significant increase in pollutant loadings” (i.e., when a complete antidegradation analysis is required) when determining whether the discharge is necessary to accommodate social or economic development and is consistent with maximum public benefit. The Central Valley Water Board exercised its judgment to require a complete antidegradation analysis and implementation of feasible alternative control measures which might reduce, eliminate, or compensate for negative impacts.
  - a. **Alternative Control Measures.** The City of Marysville prepared a 27 June 2007 City of Marysville Feasibility Study and Master Plan Results Report (Kennedy/Jenks Consultants; hereinafter Feasibility Analysis) that considered several alternatives that would reduce or eliminate the lowering of water quality resulting from the proposed increase in discharge from 5.0 MGD to 6.7 MGD. A number of effluent disposal alternatives were assessed to determine if any alternative would substantially reduce or eliminate the lowering of water quality as a result of the proposed increase in discharge from 5.0 MGD to 6.7 MGD. These alternatives are summarized below.
    - (1) Year-round discharge to surface water from the City of Marysville WWTP – This alternative would require the City of Marysville to obtain an NPDES permit and comply with stringent water quality standards for the effluent discharge. The discharge would be directly to the Feather River or

through the hydrological connection of the City of Marysville's percolation ponds to the Feather River.

- (2) Seasonal (wet-weather) direct discharge to surface water and seasonal (dry-weather) land disposal and/or reclamation of tertiary treated effluent from the City of Marysville WWTP – This alternative would require the City of Marysville to obtain an NPDES permit and comply with stringent water quality standards for the wet-weather discharges to the Feather River. This would also require the City of Marysville to acquire new land, construct pumping and transmission facilities, perform groundwater studies to evaluate water quality impacts, and obtain a WDR order. If a hydrological connection is found between the ponds and the Feather River, compliance with an NPDES permit would be required year-round. Reclamation of tertiary treated wastewater would require compliance with title 17 and 22 of the Water Code and would require an upgrade of the City of Marysville WWTP.
- (3) Year-round discharge to the City of Marysville's current percolation ponds – This alternative would require the City of Marysville to obtain an NPDES permit and comply with stringent water quality standards for the effluent discharge. The City of Marysville would be required to explore the nature of the hydrological connection between the ponds and the Feather River and prepare an antidegradation analysis for discharges to groundwater and/or the Feather River.
- (4) Land disposal using relocated percolation ponds outside the 100-year floodplain – This alternative would require the City of Marysville to acquire new land, construct pumping and transmission facilities, perform groundwater studies to evaluate water quality impacts, and obtain a WDR order. If a hydrological connection is found between the ponds and the Feather River, compliance with an NPDES permit would be required year-round.
- (5) Regionalization – This alternative would include the City of Marysville sending its raw, screened wastewater to the Facility for treatment and disposal or reuse. The Facility would become a regional wastewater treatment facility.

As discussed further in the Feasibility Analysis, the City of Marysville did not consider Alternatives (2) and (3) to be viable options, and thus

did not consider these alternatives further. The City of Marysville evaluated both economic and non-economic factors for the remaining alternatives in detail in the Feasibility Analysis and submitted a summary of costs associated with each alternative, as shown in the following table. Based on comparison of economic and non-economic factors, the City of Marysville concluded that regionalization with the Facility was the preferred alternative.

- a. Additional Information Considered by the Central Valley Water Board. The Central Valley Water Board adopted Resolution No. R5-2009-0028 in Support of Regionalization, Reclamation, Recycling, and Conservation for Wastewater Treatment Plants on 23 April 2009, which requires the Central Valley Water Board to facilitate opportunities for regionalization and consider innovative permitting options when existing NPDES permit requirements, WDRs, and/or enforcement orders inhibit the ability to implement regionalization. Resolution No. R5-2009-0028 identified a number of potential benefits to regionalization including the following:

“The costs of constructing, expanding, upgrading and maintaining wastewater collection and treatment systems are large, and can be a severe impact on small communities and small economically disadvantaged communities. Increased rates on most communities, but especially for the small communities in particular, result in the likelihood of a successful Proposition 218 challenge to rate increases, which may make compliance with regulations and improvements in water quality difficult or impossible for some communities. While the capital investment for regionalization of wastewater collection and treatment systems may result in a higher initial cost of upgrading an existing facility to meet current regulatory requirements, costs associated with meeting future regulatory requirements and system upgrades can be spread over a larger population and will ultimately reduce the per capita costs of wastewater treatment and disposal. Regionalization will also increase the technical and economical feasibility of a higher level of wastewater treatment, allowing the treated water to be a ‘resource’ and not merely a ‘waste’.”

Based on the capital, operation and maintenance, and other (e.g., regulatory) costs, the City of Marysville determined that regionalization with the Facility was the preferred alternative.

Furthermore, Resolution No. R5-2009-0028 made several findings including:

- “Coordinated management of water supplies and wastewaters on a regional basis must be promoted to achieve efficient utilization of water.”
  - “Evaluating regionalization, reclamation, recycling and/or conservation opportunities requires a balancing of these and many other considerations, including impacts to water quality, costs, authority to implement and other factors necessary to determine if regionalization, reclamation, recycling and/or conservation are feasible and practicable for the specific facility(ies).”
  - “Focused, long-range planning is necessary to identify and implement regionalization, reclamation, recycling and/or conservation opportunities. This is a continuing process in that certain projects may not be technically or fiscally feasible at this time, but may become feasible as the community grows, treatment systems are upgraded, or other factors change with time.”
- iv. **Socioeconomic Evaluation.** The objective of the socioeconomic analysis was to determine if the lowering of water quality in the Feather River is in the maximum interest of the people of the State. For the socioeconomic evaluation, the Central Valley Water Board considered:
- (a) The social benefits and costs based on the ability to accommodate socioeconomic development in the City of Marysville Feasibility Study and Master Plan Results Report.
  - (b) The magnitude of the change in water quality from existing conditions, the water quality impacts, and expected effects on beneficial uses of the Feather River.
  - (c) The feasibility and effectiveness of reducing the lowering of water quality by implementing alternatives to lowering of Feather River water quality.
  - (d) The economic costs for alternatives and assessed alternative costs against the current project regionalization cost estimate of \$101 million.
- v. **Justification for Allowing Degradation.** The Antidegradation Analysis provided the following rationale to justify the proposed increase in discharge to the receiving water:
- (a) The proposed regionalization project and associated increase in permitted discharge is necessary as a means to improve wastewater treatment for the City of Marysville, and to remove the potential threat that the City of Marysville’s existing percolation ponds pose to downstream water quality and

beneficial uses should the ponds overtop during or after a storm event. Failure to approve the increase to allow regionalization, or alternatively requiring the City of Marysville to implement additional control measures beyond the high level of treatment for the regionalized system that would maintain or improve existing water quality and mass emissions in the Feather River, likely would have significant adverse economic and social impacts on the citizens and businesses of Yuba and Sutter counties.

- (b) The increase in the Facility flow rate will not adversely affect existing or probable beneficial uses of the Feather River, nor will it cause water quality to fall below applicable water quality objectives. There is minimal effect because the regionalization effectively combines two current discharges and provides increased treatment compared with the existing City of Marysville WWTP.
- (c) Although the increased discharge may produce small increases in mass loadings of dichlorobromomethane and mercury, the proposed regionalization project and associated increase in permitted discharge will result in slight to significant reductions in the mass loadings of pollutants as compared to those that would occur if the Facility, which will provide tertiary treatment, and the City of Marysville WWTP, which provides secondary treatment, were operated as separate discharges. The small decrease in water quality with respect to the constituents considered in the analysis is unlikely to affect beneficial uses of the Feather River or downstream receiving water.
  - (1) **Dichlorobromomethane.** For dichlorobromomethane, the Antidegradation Analysis estimated an 18 percent increase in loading. As discussed further in sections IV.C.2.c and IV.C.3.c of the Fact Sheet in Order R5-2017-0094, although assimilative capacity for dichlorobromomethane and a dilution credit of 331 was available, Order R5-2017-0094 included more stringent performance-based effluent limitations that correspond to a dilution credit of 73:1. The Order included a reopener to adjust the performance-based effluent limitations if monitoring data from the regionalized Facility indicates that the Facility can comply with a more stringent effluent limitation.
  - (2) **Mercury.** Although the discharge does not exhibit reasonable potential to cause or contribute to an exceedance of the CTR criteria for mercury, as discussed in section IV.C.3.c of the Fact Sheet of Order R5-2017-0094, the Order retained the performance-based effluent

limitation for mercury from previous Orders. The proposed increase in discharge will not significantly lower water quality for mercury in the Feather River relative to the current condition (i.e., separate discharges of 5.0 MGD of tertiary treated wastewater from the Facility and 1.7 MGD of secondary treated wastewater from the City of Marysville WWTP). The Antidegradation Analysis indicates that the enhanced filtration process of the regionalized Facility will result in a small reduction in the mass loading of total mercury to the Feather River through the removal of particulate mercury; therefore, additional mercury removal for the discharge from the City of Marysville may occur. The Antidegradation Analysis concluded that no additional mass of mercury is anticipated to be discharged from the regionalized Facility beyond the sum of the current mass loading from the upgraded and expanded Facility and the City of Marysville WWTP. Order R5-2017-0094 included a reopener to adjust the performance-based effluent limitations if monitoring data from the regionalized Facility indicates that the Facility can comply with a more stringent effluent limitation.

- (3) **Salinity.** For salinity, the Antidegradation Analysis converted EC concentrations to TDS concentrations to evaluate the mass loading of salinity. The Antidegradation Analysis estimated a 4 percent increase in TDS loading. The projected downstream electrical conductivity concentration for the upgraded and expanded Facility compared to that of the regionalized Facility results in a net increase of less than 1  $\mu\text{mhos/cm}$  in the downstream electrical conductivity concentration. Thus, the increase in discharge is not expected to significantly impact downstream water quality with respect to salinity. Order R5-2017-0094 required the Discharger to continue to implement a Salinity Evaluation and Minimization Plan to identify and address sources of salinity discharged from the Facility, and includes a trigger of 900  $\mu\text{mhos/cm}$  for updating the Salinity Evaluation and Minimization Plan.
- b. **BOD5, TSS, and Ammonia.** This Order removes MDELs and mass-based effluent limitations for BOD5 and TSS, and the mass-based effluent limitation for ammonia based on 40 CFR parts 122.45 (d) and (f). The removal of the MDELs and mass-based effluent limits for BOD5 and TSS, and the mass-based effluent limit for ammonia will not result in a decrease in the level of treatment or control or a reduction in water quality.

Furthermore, both concentration-based AMELs and AWELs remain for ammonia, BOD5 and TSS, as well as an average dry weather flow prohibition that limits the amount of flow that can be discharged to the receiving water during dry weather months. The combination of concentration-based effluent limits and a flow prohibition in this Order are equivalent to mass-based effluent limitations, which were redundant limits contained in previous Orders by multiplying the concentration-based effluent limits and permitted average dry weather flow by a conversion factor to determine the mass-based effluent limitations. The Central Valley Water Board finds that the removal of the MDELs and mass-based effluent limits for BOD5 and TSS, and the mass-based effluent limit for ammonia does not result in an allowed increase in pollutants or any additional degradation of the receiving water. Thus, the removal of the MDELs and mass-based effluent limits for BOD5 and TSS, and the mass-based limit for ammonia is consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and the State Antidegradation Policy.

- c. **Surface Water.** The permitted surface water discharge is consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and the State Anti-Degradation Policy. Compliance with these requirements will result in the use of BPTC of the discharge. The impact on existing water quality will be insignificant.
- d. **Groundwater.** The Discharger utilizes five unlined percolation ponds located in the Feather River floodplain for discharge of tertiary treated effluent. Domestic wastewater contains constituents such as total dissolved solids, specific conductivity, pathogens, nitrates, organics, metals, and oxygen demanding substances. Percolation from the percolation ponds may result in an increase in the concentration of these constituents in groundwater. The State Anti-Degradation Policy generally prohibits the Central Valley Water Board from authorizing activities that will result in the degradation of high-quality waters unless it has been shown that any change will be consistent with maximum benefit to the people of the State, will not unreasonably affect present and anticipated beneficial use of such water, and will not result in water quality less than that prescribed in applicable policies; and that any activity which produces or may produce a waste or increased volume or concentration of waste will implement the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained.

The Facility is designed and constructed to provide tertiary level treatment and disinfection to treat municipal domestic wastewater prior to discharge. This level of treatment may result in limited groundwater degradation not exceeding water quality objectives. Providing wastewater treatment to the

community is in the best interest of the people of the State. The Discharger's treatment constitutes best practicable treatment or control and complies with the State Anti-Degradation Policy.

This Order does not authorize an increase in flow or mass of pollutants to groundwater beyond the levels authorized in Order R5-2017-0094 as amended by Order R5-2019-0081. As discussed in section III.E.1 of the Fact Sheet, groundwater monitoring results do not indicate degradation of groundwater quality when compared to background, with the exception of electrical conductivity. However, electrical conductivity meets all applicable water quality objectives for salinity. The technology, energy, water recycling, and waste management advantages of municipal utility service far exceed any benefits derived from a community otherwise reliant on numerous concentrated individual wastewater systems, and the impacts on water quality will be substantially less. The degradation will not unreasonably affect present and anticipated beneficial uses of groundwater or result in water quality less than water quality objectives. The Discharger selected to participate in the Prioritization and Optimization Study for the Salt Control Program. To help ensure that the Discharger continues to implement salinity reduction measures, this Order includes an electrical conductivity trigger of 1,000  $\mu\text{mhos/cm}$  (annual average). Furthermore, this Order requires the Discharger to comply with the new Salinity Control Program (i.e., to participate in the P&O Study and implement the SEMP).

#### **5. Stringency of Requirements for Individual Pollutants**

This Order contains both technology-based effluent limitations and WQBEL's for individual pollutants. The technology-based effluent limitations consist of restrictions on concentration, mass, and percent removal requirements for BOD5 and TSS, and pH (for Discharge Point 002 only). Restrictions on these parameters are discussed in section IV.B.2 of this Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements that are necessary to meet water quality standards. For BOD5, pH, and TSS, both technology-based effluent limitations and WQBELs are applicable. The more stringent of these effluent limitations are implemented by this Order.

WQBELs have been derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 C.F.R. section 131.38. The procedures for calculating the individual WQBELs for priority pollutants are based on the CTR implemented by the SIP, which was approved

by U.S. EPA on 18 May 2000. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

**Summary of Final Effluent Limitations  
Discharge Points 001 and 002**

**Table F-16 Summary of Final Effluent Limitations**

<b>Parameter</b>	<b>Units</b>	<b>Effluent Limitations</b>	<b>Basis<sup>1</sup></b>
Biochemical Oxygen Demand (5-day @ 20°C)	mg/L	AMEL 10 AWEL 15	TTC
Biochemical Oxygen Demand (5-day @ 20°C)	% Removal	AMEL 85	CFR
pH	Standard Units	Instantaneous Minimum 6.5 at Discharge Point 001 6.0 at Discharge Point 002 Instantaneous Maximum 8.5	BP, PB
Total Suspended Solids	mg/L	AMEL 10 AWEL 15	TTC
Total Suspended Solids	% Removal	AMEL 85	CFR
Chlorodibromomethane	mg/L	AMEL 18 MDEL 36	CTR
Dichlorobromomethane	mg/L	AMEL 38 MDEL 70	CTR
Nitrate Plus Nitrite (as N)	mg/L	AMEL 10 AWEL 17	MCL
Mercury, Total Recoverable	lbs/year	AAEL 0.46 (see table note 1. below)	PB
Ammonia	mg/L	AMEL 2.9 AWEL 5.2	NAWQC
Total Coliform Organisms	MPN/100 ml	AMEL 23 (see table note 2. below) AWEL 2.2 (see table note 3. below)	Title 22

Parameter	Units	Effluent Limitations	Basis <sup>1</sup>
		MDEL 240 (see table note 4. below)	
Diazinon and Chlorpyrifos	µg/L	AMEL (see table note 5. below) MDEL (see table note 6. below)	TMDL
Chlorine, Total Residual	mg/L	AWEL 0.011 (see table note 7. below) MDEL 0.019 (see table note 8. below)	NAWQC

**Table F-16 Notes:**

**TTC** – Based on tertiary treatment capability. These effluent limitations reflect the capability of a properly operated tertiary treatment plant.

**CFR** – Based on secondary treatment standards contained in 40 CFR part 133.

**BP** – Based on water quality objectives contained in the Basin Plan.

**PB** – Based on Facility performance.

**CTR** – Based on water quality criteria contained in the California Toxics Rule and applied as specified in the SIP.

**NAWQC** – Based on U.S. EPA’s National Ambient Water Quality Criteria for the protection of freshwater aquatic life.

**TMDL** – Based on the TMDL for diazinon and chlorpyrifos in the lower San Joaquin River.

**MCL** – Based on the Primary Maximum Contaminant Level.

**Title 22** – Based on State Water Board Division of Drinking Water Reclamation Criteria, CCR, Division 4, Chapter 3 (Title 22).

1. The total annual mass discharge of total mercury shall not exceed 0.46 lbs.
2. Not to be exceeded more than once in any 30-day period.
3. Applied as a 7-day median effluent limitation.
4. Applied as an instantaneous maximum effluent limitation.
5. Average Monthly Effluent Limit:  

$$\text{SAMEL} = \text{CD M-avg}/0.079 + \text{CC M-avg}/0.012 \leq 1.0$$

CD M-AVG = average monthly diazinon effluent concentration in µg/L.  
 CC M-AVG = average monthly chlorpyrifos effluent concentration in µg/L
6. Average Weekly Effluent Limit:

$$\text{SAWEL} = \text{CD W-avg}/0.14 + \text{CC W-avg}/0.021 \leq 1.0$$

CD W-AVG = average weekly diazinon effluent concentration in µg/L.

CC W-AVG = average weekly chlorpyrifos effluent concentration in µg/L.

7. Applied as a 4-day average effluent limitation. Applicable at Discharge Point 001 only.
8. Applied as a 1-hour average effluent limitation. Applicable at Discharge Point 001 only.

**E. Interim Effluent Limitations – Not Applicable**

**F. Land Discharge Specifications – Not Applicable**

**G. Recycling Specifications – Not Applicable**

**V. RATIONALE FOR RECEIVING WATER LIMITATIONS**

**A. Surface Water**

1. CWA section 303(a-c), requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Central Valley Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional Water Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains receiving surface water limitations based on the Basin Plan numerical and narrative water quality objectives for bacteria, biostimulatory substances, color, chemical constituents, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, suspended sediment, settleable substances, suspended material, tastes and odors, temperature, toxicity, and turbidity.
  - a. **Bacteria.** On 7 August 2018 the State Water Board adopted Resolution No. 2018-0038 establishing Bacteria Provisions, which are specifically titled “Part 3 of the Water Quality Control Plan for Inland Surface Waters, Enclosed Bays, and Estuaries of California—Bacteria Provisions and a Water Quality Standards Variance Policy” and “Amendment to the Water Quality Control Plan for Ocean Waters of California—Bacteria Provisions and a Water Quality Standards Variance Policy.” The Bacteria Water Quality Objectives established in the Bacteria Provisions supersede any numeric water quality objective for bacteria for the REC-1 beneficial use contained in a water quality control plan before the effective date of the Bacteria Provisions.

The Bacteria Water Quality Objectives correspond with the risk protection level of 32 illnesses per 1,000 recreators and use *E. coli* as the indicator of pathogens in

freshwaters and enterococci as the indicator of pathogens in estuarine waters and ocean waters.

The Bacteria Provisions provide that where a permit, waste discharge requirement (WDR), or waiver of WDR includes an effluent limitation or discharge requirement that is derived from a water quality objective or other guidance to control bacteria (for any beneficial use) that is more stringent than the Bacteria Water Quality Objective, the Bacteria Water Quality Objective would not be implemented in the permit, WDR, or waiver of WDR. This Order includes effluent limitations and discharge requirements equivalent to the DDW Title 22 disinfected tertiary reclamation criteria that are more stringent than the Statewide Bacteria Objectives. Therefore, the Statewide Bacteria Objectives have not been implemented in this Order.

## **B. Groundwater**

1. The beneficial uses of the underlying groundwater are municipal and domestic supply, industrial service supply, industrial process supply, and agricultural supply.
2. Basin Plan water quality objectives include narrative objectives for chemical constituents, tastes and odors, and toxicity of groundwater. The toxicity objective requires that groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective states groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use. The tastes and odors objective prohibits taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan also establishes numerical water quality objectives for chemical constituents and radioactivity in groundwaters designated as municipal supply. These include, at a minimum, compliance with MCL's in Title 22 of the CCR. The bacteria objective prohibits coliform organisms at or above 2.2 MPN/100 mL. The Basin Plan requires the application of the most stringent objective necessary to ensure that waters do not contain chemical constituents, toxic substances, radionuclides, taste- or odor-producing substances, or bacteria in concentrations that adversely affect municipal or domestic supply, agricultural supply, industrial supply or some other beneficial use.
3. The Discharger currently discharges tertiary treated wastewater continuously to the percolation ponds. Groundwater monitoring results do not indicate a degradation in groundwater quality when compared to background. Consistent with Order R5-2017-0094, this Order retains groundwater limitations and specifies that release of waste constituents from any storage, treatment, or disposal component associated with the Facility shall not cause the underlying groundwater to contain waste constituents in concentrations greater than

background water quality or applicable water quality objectives, whichever is greater.

## VI. RATIONALE FOR PROVISIONS

### A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 C.F.R. section 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 C.F.R. section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Sections 122.41(a)(1) and (b) through (n) of 40 C.F.R. establish conditions that apply to all state issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) of 40 C.F.R. allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 C.F.R. section 123.25, this Order omits federal conditions that address enforcement authority specified in 40 C.F.R. sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

### B. Special Provisions

#### 1. Reopener Provisions

- a. **Mercury.** This provision allows the Central Valley Water Board to reopen this Order in the event mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted. In addition, this Order may be reopened if the Central Valley Water Board determines that a mercury offset program is feasible for dischargers subject to NPDES permits.
- b. **Central Valley Salinity Alternatives for Long-Term Sustainability (CV-SALTS).** On 17 January 2020, certain Basin Plan Amendments to incorporate new strategies for addressing ongoing salt and nitrate accumulation in the Central Valley became effective. Other provisions subject to U.S. EPA approval became effective on 2 November 2020, when approved by U.S. EPA. As the Central Valley Water Board moves forward to implement those provisions that are now in effect, this Order may be amended or modified to incorporate new or modified requirements necessary for implementation of the Basin Plan Amendments. More information regarding these Amendments can be found on the [Central Valley Salinity Alternatives for Long-Term Sustainability \(CV-SALTS\) web](#)

[page:](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/)

([https://www.waterboards.ca.gov/centralvalley/water\\_issues/salinity/](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/))

- c. **Water Effects Ratio (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating criteria for applicable inorganic constituents. In addition, default dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable. If the Discharger performs studies to determine site-specific WER's and/or site-specific dissolved-to- total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
  - d. **Whole Effluent Toxicity.** If after review of new data and information, it is determined that the discharge has reasonable potential to cause or contribute to an instream exceedance of the Statewide Toxicity Provisions numeric chronic aquatic toxicity objective and Basin Plan's narrative toxicity objective this Order may be reopened and effluent limitations added for acute and/or chronic toxicity.
  - e. **Facility Expansion to 6.7 MGD.** The Discharger may request an expansion of allowable flows to be discharged to the Feather River to accommodate flows associated with the regionalization project with the City of Marysville. If the following conditions are met, this Order may be reopened to revise the applicable average dry weather flow prohibition to 6.7 MGD:
    - i. **Effluent and Receiving Water Limitation Compliance.** The discharge shall demonstrate compliance with the effluent limitations and receiving water limitations contained in sections IV.A.2 and V.A, respectively, of this Order.
    - ii. **Facility Expansion.** The Discharger shall have completed construction of the expansion project, that results in a design treatment capacity of 6.7 MGD ADWF.
    - iii. **Request for Increase.** The Discharger shall submit to the Central Valley Water Board a request for an increase in the permitted discharge flow rate, which demonstrates compliance with items (a) and (b) of this provision.
- 2. Special Studies and Additional Monitoring Requirements**
- a. **Chronic Whole Effluent Toxicity Requirements.** The Basin Plan contains a narrative toxicity objective that states, "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at page III-8.00.) Adequate WET data is not available to

determine if the discharge has reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's narrative toxicity objective. Therefore, a numeric monitoring trigger of 1 chronic toxicity units (as 100/NOEC), toxicity reduction evaluation requirements, and routine monitoring have been required.

The Monitoring and Reporting Program of this Order requires chronic WET monitoring to compare with the numeric chronic toxicity trigger. In addition to WET monitoring, the Special Provision in section VI.C.2.a includes a numeric toxicity monitoring trigger, requirements for accelerated monitoring, and requirements for TRE initiation. If the discharge exceeds the chronic toxicity numeric trigger this provision requires the Discharger either participate in an approved Toxicity Evaluation Study (TES) or conduct a site-specific Toxicity Reduction Evaluation (TRE).

A TES may be conducted in lieu of a TRE if the percent effect at 100 percent effluent is less than or equal to 50 percent. Determining the cause of toxicity can be challenging when the toxicity signal is low. Several Central Valley facilities with similar treatment systems have been experiencing intermittent low-level toxicity. The dischargers have not been successful identifying the cause of the toxicity because of the low toxicity signal and the intermittent nature of the toxicity. Due to these challenges, the Central Valley Clean Water Association (CVCWA), in collaboration with staff from the Central Valley Water Board, has initiated a Special Study to Investigate Low Level Toxicity Indications (Group Toxicity Study). This Order allows the Discharger to participate in an approved TES, which may be conducted individually or as part of a coordinated group effort with other similar dischargers that are exhibiting toxicity. Although the current CVCWA Group Toxicity Study is related to low-level toxicity, participation in an approved TES is not limited to only low-level toxicity issues.


See the WET Monitoring Flow Chart (Figure F-1), below, for further clarification of the decision points for determining the need for TES/TRE initiation.

**TRE Guidance.** The Discharger is required to prepare a TRE Workplan in accordance with USEPA guidance.

- i. Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants, EPA/833-B-99/002, August 1999.
- ii. Generalized Methodology for Conducting Industrial Toxicity Reduction Evaluations (TREs), EPA/600/2-88/070, April 1989.

- iii. Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures, Second Edition, EPA 600/6-91/003, February 1991.
- iv. Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, EPA/600/6-91/005F, May 1992.
- v. Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity, Second Edition, EPA/600/R-92/080, September 1993.
- vi. Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity, Second Edition, EPA 600/R-92/081, September 1993.
- vii. Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, EPA-821-R-02-012, October 2002.
- viii. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA-821-R-02-013, October 2002.
- ix. Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991.

**Figure F-1. WET Accelerated Monitoring Flow Chart**



**Figure F-1 Notes:**

1. The Discharger may elect to take additional samples to determine the 3-sample median. The samples shall be collected at least one week apart and the final sample shall be within 6 weeks of the initial sample exhibiting toxicity.
  - b. **Pretreatment Program Submittal Requirements.** The Discharger shall develop and submit a POTW Pretreatment Program as specified in 40 C.F.R. 403 to the Central Valley Water Board for approval as directed in the Technical Reports Table of the MRP (Attachment E).
  - c. **Groundwater Monitoring Well Study.** The study is to assess the monitoring well network to determine if the network requires additional

wells or replacement wells that would better assess compliance with groundwater limitations and determining groundwater gradients.

**3. Best Management Practices and Pollution Prevention**

- a. Salinity Evaluation and Minimization Plan (SEMP).** The Basin Plan includes a Salt Control Program for discharges to groundwater and surface water. The Salt Control Program is a phased approach to address salinity in the Central Valley Region. During Phase I the focus will be on conducting a Prioritization and Optimization (P&O) Study to provide information for subsequent phases of the Salt Control Program. During Phase I, the Salt Control Program includes two compliance pathways for dischargers to choose; a Conservative Salinity Permitting Approach and an Alternative Salinity Permitting Approach.

The Discharger submitted a notice to intent for the Salt Control Program on 12 July 2021 indicating its intent to meet the Alternative Salinity Permitting Approach. Under the Alternative Permitting Approach, the Basin Plan requires dischargers implement salinity minimization measures to maintain existing salinity levels and participate in the P&O Study. The Discharger's NOI demonstrated adequate participation in the P&O and this Order requires continued participation to meeting the requirements of the Alternative Salinity Permitting Approach. This Order also requires continued implementation of the Discharger's SEMP and includes a performance-based salinity trigger to ensure salinity levels do not increase. In accordance with the Basin Plan, the salinity trigger was developed based on existing facility performance and considers possible temporary increases that may occur due to water conservation and/or drought.

- b. Facility Performance Triggers for Chlorodibromomethane and Dichlorobromomethane.** This Order retains the application of dilution credits and contains performance-based final effluent limitations for chlorodibromomethane and dichlorobromomethane. The dilution credits applied are significantly below the assimilative capacity of the receiving water however, the Discharger must maintain at least the current level of performance for the Facility. Therefore, this Order contains performance-based triggers for chlorodibromomethane and dichlorobromomethane (see section IV.C.2.c.iii.(l) of this Fact Sheet). If the concentration for any of these constituents exceeds the trigger listed in Table F-9 over a 12-month period beginning on the 1st of the calendar year and the exceedances demonstrate a consistent increasing trend, the Discharger shall perform a study to determine the cause of the increase in the effluent concentration of the constituent(s). In the case where uncontrollable factors are documented as responsible for the increasing trend, a study is not required.

#### 4. Construction, Operation, and Maintenance Specifications

- b. **Filtration System Operating Specifications.** Turbidity is included as an operational specification as an indicator of the effectiveness of the filtration system for providing adequate disinfection. The tertiary treatment process utilized at this Facility is capable of reliably meeting a turbidity limitation of 2 NTU as a daily average. Turbidity has a major advantage for monitoring filter performance, allowing immediate detection of filter failure and rapid corrective action. The operational specification requires that turbidity prior to disinfection shall not exceed 2 NTU as a daily average; 5 NTU, more than 5 percent of the time within a 24-hour period, and an instantaneous maximum of 10 NTU.
- b. Consistent with Order R5-2017-0094, this Order requires that the treatment, storage, and disposal facilities be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency except for ponds located within the Feather River levees.
- c. **Percolation Pond Operating Requirements.** The operation and maintenance specifications for the percolation ponds are necessary to protect the beneficial uses of the groundwater. In addition, reporting requirements related to use of the percolation ponds are required to monitor their use and the potential impact on groundwater.

#### 5. Special Provisions for POTWs

- a. **Pretreatment Requirements.**
  - i. The federal CWA section 307(b), and federal regulations, 40 C.F.R. part 403, require publicly owned treatment works to develop an acceptable industrial pretreatment program. A pretreatment program is required to prevent the introduction of pollutants, which will interfere with treatment plant operations or sludge disposal and prevent pass through of pollutants that exceed water quality objectives, standards or permit limitations. Pretreatment requirements are imposed pursuant to 40 C.F.R. part 403.
  - ii. The Discharger shall implement and enforce its approved pretreatment program and is an enforceable condition of this Order. If the Discharger fails to perform the pretreatment functions, the Central Valley Water Board, the State Water Board or U.S. EPA may take enforcement actions against the Discharger as authorized by the CWA.
- b. **Resource Recovery from Anaerobically Digestible Material (ADM).** Some POTWs choose to accept organic material such as food waste, fats, oils, and grease into their anaerobic digesters for co-digestion to increase production of methane and other biogases for energy production and to

prevent such materials from being discharged into the collection system, which could cause sanitary sewer overflows. The California Department of Resources Recycling and Recovery has proposed an exemption from requiring Process Facility/Transfer Station permits where this activity is regulated under waste discharge requirements or NPDES permits. The proposed exemption is restricted to ADM that has been prescreened, slurried, and processed/conveyed in a closed system to be co-digested with regular POTW sludge. The proposed exemption requires that a POTW develop Standard Operating Procedures (SOPs) for the proper handling, processing, tracking, and management of the ADM before it is received by the POTW.

SOPs are required for POTWs that accept hauled food waste, fats, oil, and grease for injection into anaerobic digesters. The development and implementation of SOPs for management of these materials is intended to allow the California Department of Resources Recycling and Recovery to exempt this activity from separate and redundant permitting programs. If the POTW does not accept food waste, fats, oil, or grease for resource recovery purposes, it is not required to develop and implement SOPs.

The Discharger currently does not accept hauled-in ADM for direct injection into its anaerobic digester for co-digestion. However, if the Discharger proposes to receive hauled-in ADM for injection into its anaerobic digester for co-digestion, this provision requires the Discharger to notify the Central Valley Water Board and develop and implement SOPs for this activity prior to initiation of the hauling. The requirements of the SOPs are discussed in section VI.C.5.

- c. **Sludge/Biosolids Treatment or Discharge Specifications.** Sludge in this Order means the solid, semisolid, and liquid residues removed during primary, secondary, or advanced wastewater treatment processes. Solid waste refers to grit and screening material generated during preliminary treatment. Residual sludge means sludge that will not be subject to further treatment at the wastewater treatment plant. Biosolids refer to sludge that has been treated and tested and shown to be capable of being beneficially and legally used pursuant to federal and state regulations as a soil amendment for agricultural, silvicultural, horticultural, and land reclamation activities as specified under 40 C.F.R. part 503. This Order does not regulate offsite use or disposal of biosolids, which are regulated instead under 40 C.F.R. part 503; administered by U.S. EPA. The Sludge/Biosolids Treatment or Discharge Specifications in this Order implement the California Water Code to ensure sludge/biosolids are properly handled onsite to prevent nuisance, protect public health, and protect groundwater quality.

## 6. Other Special Provisions

- a. **Disinfection Requirements.** Consistent with previous Order R5-2017-0094, this Order requires wastewater to be oxidized, coagulated, filtered, and adequately disinfected consistent with DDW reclamation criteria, CCR, Title 22, division 4, chapter 3 (Title 22), or equivalent. The disinfection requirements are discussed in detail above in Section IV.C.3, Determining the Need for WQBELs (see Pathogens).
- b. **Facility Expansion.** The Discharger is implementing a regionalization project with the City of Marysville. Upon completion of the regionalization project, the Facility will provide tertiary treatment for up to 6.7 MGD. Consistent with Order R5-2017-0094, this Order includes requirements that must be met prior to an allowable increase in the flow rate to 6.7 MGD.

## 7. Compliance Schedules – Not Applicable

## VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

CWA section 308 and 40 C.F.R. sections 122.41(h), (j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 authorize the Central Valley Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The Monitoring and Reporting Program (MRP), Attachment E of this Order establishes monitoring, reporting, and recordkeeping requirements that implement federal and state requirements. The burden, including costs, of these monitoring and reporting requirements bears a reasonable relationship to the need for the reports and the benefits to be obtained therefrom. The Discharger, as owner and operator of the Facility, is required to comply with these requirements, which are necessary to determine compliance with this Order. The following provides additional rationale for the monitoring and reporting requirements contained in the MRP for this facility.

Water Code section 13176, subdivision (a), states: “The analysis of any material required by [Water Code sections 13000-16104] shall be performed by a laboratory that has accreditation or certification pursuant to Article 3 (commencing with section 100825) of Chapter 4 of Part 1 of Division 101 of the Health and Safety Code.” The DDW accredits laboratories through its Environmental Laboratory Accreditation Program (ELAP).

Section 13176 cannot be interpreted in a manner that would violate federal holding time requirements that apply to NPDES permits pursuant to the CWA. (Wat. Code sections 13370, subd. (c), 13372, 13377.) Section 13176 is inapplicable to NPDES permits to the extent it is inconsistent with CWA requirements. (Wat. Code section 13372, subd. (a).) Lab accreditation is not required for field tests such as tests for color, odor, turbidity, pH, temperature, dissolved oxygen, electrical conductivity, and disinfectant residual. The Discharger maintains an ELAP accredited laboratory on-site and conducts analysis within the required hold times.

**A. Influent Monitoring**

1. Influent monitoring is required to collect data on the characteristics of the wastewater and to assess compliance with effluent limitations (e.g., BOD<sub>5</sub> and TSS reduction requirements). The monitoring frequencies and sample types have been retained from Order R5-2017-0094, except as noted in Table F-14, below.

**B. Effluent Monitoring**

1. Pursuant to the requirements of 40 C.F.R. section 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. Effluent monitoring is necessary to assess compliance with effluent limitations, assess the effectiveness of the treatment process, and to assess the impacts of the discharge on the receiving stream and groundwater.
2. Effluent monitoring frequencies and sample types have been retained from Order R5-2017-0094, except as noted in Table F-14, below.
3. **Pyrethroid Pesticides Monitoring.** A Basin Plan Amendment and TMDL for the Control of Pyrethroid Pesticide Discharges in the Sacramento and San Joaquin River basins (Resolution R5-2017-0057) was approved by the Central Valley Water Board on 8 June 2017 and is now effective. The Pyrethroids Control Program established by Resolution R5-2017-0057 requires monitoring by domestic and municipal wastewater dischargers discharging at least 1 MGD for the concentrations of pyrethroid pesticides, total and dissolved organic carbon in the water column, and water column toxicity testing. Monitoring is required to evaluate the potential impacts of discharges of pyrethroid pesticides to receiving waters.

**C. Receiving Water Monitoring**

**1. Surface Water**

- a. Receiving water monitoring is necessary to assess compliance with receiving water limitations and to assess the impacts of the discharge on the receiving stream. Receiving surface water monitoring frequencies and sample types have been retained from Order No. R5-2017-0094, except as noted in Table F-14, below.

**2. Groundwater**

- a. Water Code section 13267 states, in part, “(a) A Regional Water Board, in establishing waste discharge requirements may investigate the quality of any waters of the state within its region” and “(b)(1) In conducting an investigation, the Regional Water Board may require that any person who discharges waste that could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program

reports which the Regional Water Board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports.” In requiring those reports, a Regional Water Board shall provide the person with a written explanation with regard to the need for the reports and shall identify the evidence that supports requiring that person to provide the reports. The Monitoring and Reporting Program is issued pursuant to Water Code section 13267. The groundwater monitoring and reporting program required by this Order and the Monitoring and Reporting Program are necessary to assure compliance with these waste discharge requirements. The Discharger is responsible for the discharges of waste at the facility subject to this Order.

- b. Monitoring of the groundwater must be conducted to determine if the discharge has caused an increase in constituent concentrations, when compared to background. The monitoring must, at a minimum, require a complete assessment of groundwater impacts including the vertical and lateral extent of degradation, an assessment of all wastewater-related constituents which may have migrated to groundwater, an analysis of whether additional or different methods of treatment or control of the discharge are necessary to provide BPTC to comply with the State Anti-Degradation Policy. Economic analysis is only one of many factors considered in determining BPTC. If monitoring indicates that the discharge has incrementally increased constituent concentrations in groundwater above background, this permit may be reopened and modified. Until groundwater monitoring is sufficient, this Order contains Groundwater Limitations that allow groundwater quality to be degraded for certain constituents when compared to background groundwater quality, but not to exceed water quality objectives. If groundwater quality has been degraded by the discharge, the incremental change in pollutant concentration (when compared with background) may not be increased. If groundwater quality has been or may be degraded by the discharge, this Order may be reopened, and specific numeric limitations established consistent with the State Anti-Degradation Policy and the Basin Plan.
- c. **Groundwater Dilution Verification Study Results.** The Discharger was required by the previous Order to investigate the percolation ponds interaction with the underlying groundwater to verify that pond discharge to groundwater and ultimately surface water can continue to include dilution credits for the effluent discharge that ultimately reaches surface waters. Out of 17 samples for bis (2-ethylhexyl) phthalate from each well from May 2019 through September 2020, only one sample in each well had estimated value of 0.5 µg/L and all other samples were non-detect. This is below the MCL of 4 µg/L in groundwater for (2-ethylhexyl) phthalate. Out of 11 samples for total trihalomethanes from each well between September 2012 and July 2017, the maximum concentration of

total trihalomethanes was less than 4 µg/L, where the maximum effluent concentration during this time frame was 90 µg/L. Based on the results of the study, the discharge is not contributing to the degradation of groundwater quality between 2012 and 2017 for bis (2-ethylhexyl) phthalate and total trihalomethanes.

- d. **Groundwater Well Relocation Study and Groundwater Quality Study.** These were optional studies in the previous permit and the Discharger did not perform them.
- e. This Order requires the Discharger to continue groundwater monitoring and includes a regular schedule of groundwater monitoring in the attached Monitoring and Reporting Program. The groundwater monitoring reports are necessary to evaluate impacts to waters of the State to assure protection of beneficial uses and compliance with Central Valley Water Board plans and policies, including the State Anti-Degradation Policy. Evidence in the record includes effluent monitoring data that indicates the presence of constituents that may degrade groundwater and surface water.

Monitoring frequencies and parameters have been retained from Order No. R5-2017-0094, except as noted in Table F-17, below.

**Table F-17 Summary of Monitoring Changes**

Parameter, Units	Type of Monitoring	Prior Sample Frequency	Revised Sample Frequency	Reason for Change
Biochemical Oxygen Demand (5-day @ 20°C), % Removal	Effluent	--	1/Month	Necessary to assess compliance with effluent limitations.
Total Suspended Solids, % Removal	Effluent	--	1/Month	Necessary to assess compliance with effluent limitations.
Nitrate, mg/L	Effluent	--	2/Month	Necessary to assess compliance with effluent limitations.
Bis (2-ethylhexyl) phthalate, µg/L	Effluent	1/Month	--	No reasonable potential.
Mercury, Total	Effluent	1/Month	1/Quarter	No reasonable potential.
Hardness (as CaCO <sub>3</sub> ), mg/L	Effluent	1/Month	1/Quarter	Necessary to determine metals reasonable potential.
Cyanide, µg/L	Effluent	1/Month	Discontinue	No reasonable potential
Chlorpyrifos, µg/L	Effluent	1/Quarter	1/Year	Necessary to assess compliance with effluent limitations.
Diazinon, µg/L	Effluent	1/Quarter	1/Year	Necessary to assess compliance with effluent limitations.

Parameter, Units	Type of Monitoring	Prior Sample Frequency	Revised Sample Frequency	Reason for Change
Total Dissolved Solids, mg/L	Effluent	1/Month	--	Monitoring for electrical conductivity satisfies the assessment for determining reasonable potential for salinity.
Dissolved Oxygen, mg/L	Effluent	--	1/Week	Monitoring was required in Order 2017-0094 but not included.
Dissolved Organic Carbon, mg/L	Effluent	--	1/Quarter	Monitoring for dissolved organic carbon satisfies the assessment for determining reasonable potential for several constituents.
Electrical Conductivity @ 25°C, µmhos/cm	Receiving Water	1/Month	1/Quarter	Necessary to assess compliance with receiving water limitations.
Hardness (as CaCO <sub>3</sub> ), mg/L	Receiving Water	1/Month	1/Quarter	Necessary to assess compliance with receiving water limitations.
Fecal Coliform Organisms, MPN/100 mL	Receiving Water	1/Quarter	--	Not required for Title 22 equivalent facilities.
Bis (2-ethylhexyl) phthalate, µg/L	Receiving Water	1/Quarter	--	No reasonable potential.
Dibromochloromethane, µg/L	Receiving Water	1/Quarter	--	Monitoring not necessary for determining mixing zone.
Dichlorobromomethane, µg/L	Receiving Water	1/Quarter	--	Monitoring not necessary for determining mixing zone.
Depth to Groundwater, ±0.01 feet	Groundwater	2/Year	1/Quarter	Assess seasonal gradient fluctuations
Groundwater Elevation, ±0.01 feet	Groundwater	2/Year	1/Quarter	Assess seasonal gradient fluctuations
Gradient, feet/feet	Groundwater	2/Year	1/Quarter	Assess seasonal gradient fluctuations
Gradient Direction, degrees	Groundwater	2/Year	1/Quarter	Assess seasonal gradient fluctuations
Electrical Conductivity @ 25°C, µmhos/cm	Groundwater	2/Year	1/Quarter	Assess seasonal fluctuations
pH, standard units	Groundwater	2/Year	1/Quarter	Assess seasonal compliance with limitations.
Total Nitrogen as N, mg/L	Groundwater	2/Year	1/Quarter	Assess seasonal compliance with limitations.
Total Dissolved Solids, mg/L	Groundwater	--	1/Quarter	Assess seasonal fluctuations
Total Organic Carbon,	Groundwater	--	1/Quarter	Determine background and

Parameter, Units	Type of Monitoring	Prior Sample Frequency	Revised Sample Frequency	Reason for Change
mg/L				downgradient concentrations
Iron, Dissolved, µg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Manganese, Dissolved, µg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Arsenic, Dissolved, µg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Hardness, Total (as CaCO <sub>3</sub> ), mg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Alkalinity, Total (as CaCO <sub>3</sub> ), mg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Standard Minerals, µg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Total Trihalomethanes, µg/L	Groundwater	--	1/Quarter	Determine background and downgradient concentrations
Fecal Coliform Organisms, MPN/100 mL	Groundwater	2/Year	--	Not required for Title 22 equivalent facilities.

#### D. Other Monitoring Requirements

##### 1. Biosolids Monitoring

Biosolids monitoring is required to ensure compliance with the pretreatment requirements contained in 40 C.F.R. part 403 and implemented in section VI.C.5.b. of this Order. Biosolids monitoring is required per U.S. EPA guidance to evaluate the effectiveness of the pretreatment program. Biosolids monitoring for compliance with 40 C.F.R. part 503 regulations is not included in this Order since it is a program administered by U.S. EPA's part 503 Biosolids Program (<https://www.epa.gov/biosolids/compliance-and-annual-reporting-guidance-about-clean-water-act-laws>)

##### 2. Filtration System Monitoring

Filtration system monitoring and reporting is required to ensure that the filtration system is operated to adequately inactivate pathogens in the wastewater.

##### 3. Percolation Pond Monitoring

Pond monitoring is required to ensure proper operation of the percolation ponds. Weekly observations, measurement of freeboard, and monitoring of dissolved oxygen has been retained from Order R5-2017-0094.

#### 4. Pyrethroid Pesticides Monitoring

On 8 June 2017, the Central Valley Water Board adopted Resolution R5-2017-0057, which adopted the Basin Plan Amendment (BPA) for the Control of Pyrethroid Pesticide Discharges. Pyrethroid pesticides and toxicity monitoring has been included in this Order in accordance with the Pyrethroids Pesticides BPA, which is required for POTWs with design average dry weather flow greater than or equal to 1 million gallons per day.

#### 5. Discharge Monitoring Report-Quality Assurance (DMR-QA) Study Program

Under the authority of section 308 of the CWA (33 U.S.C. section 1318), U.S. EPA requires all dischargers under the NPDES Program to participate in the annual DMR-QA Study Program. The DMR-QA Study evaluates the analytical ability of laboratories that routinely perform or support self-monitoring analyses required by NPDES permits. There are two options to satisfy the requirements of the DMR-QA Study Program: (1) The Discharger can obtain and analyze a DMR-QA sample as part of the DMR-QA Study; or (2) Per the waiver issued by U.S. EPA to the State Water Board, the Discharger can submit the results of the most recent Water Pollution Performance Evaluation Study from their own laboratories or their contract laboratories. A Water Pollution Performance Evaluation Study is similar to the DMR-QA Study. Thus, it also evaluates a laboratory's ability to analyze wastewater samples to produce quality data that ensure the integrity of the NPDES Program. The Discharger shall submit annually the results of the DMR-QA Study or the results of the most recent Water Pollution Performance Evaluation Study to the State Water Board. The State Water Board's Quality Assurance Program Officer will send the DMR-QA Study results or the results of the most recent Water Pollution Performance Evaluation Study to U.S. EPA's DMR-QA Coordinator and Quality Assurance Manager.

### VIII. PUBLIC PARTICIPATION

The Central Valley Water Board has considered the issuance of WDRs that will serve as an NPDES permit for the Wastewater Treatment Plant. As a step in the WDR adoption process, the Central Valley Water Board staff has developed tentative WDRs and has encouraged public participation in the WDR adoption process.

#### A. Notification of Interested Persons

The Central Valley Water Board notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and provided an opportunity to submit written comments and recommendations. Notification was provided through posting on the Central Valley Water Board's website on **5 October 2022** and through posting by the Discharger at **Marysville City Hall** and the Facility entrance on **7 October 2022**.

The public had access to the agenda and any changes in dates and locations through the [Central Valley Water Board's website](http://www.waterboards.ca.gov/centralvalley/board_info/meetings/) ([http://www.waterboards.ca.gov/centralvalley/board\\_info/meetings/](http://www.waterboards.ca.gov/centralvalley/board_info/meetings/))

**B. Written Comments**

Interested persons were invited to submit written comments concerning tentative WDRs as provided through the notification process. Comments were due either in person or by mail to the Executive Office at the Central Valley Water Board at the address on the cover page of this Order.

To be fully responded to by staff and considered by the Central Valley Water Board, the written comments were due at the Central Valley Water Board office by 5:00 p.m. on **2 November 2022**.

**C. Public Hearing**

The Central Valley Water Board held a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: **8/9 December 2022**

Time: **8:30 a.m.**

Location: Online

**OR**

Regional Water Quality Control Board, Central Valley Region>  
11020 Sun Center Dr., Suite #200  
Rancho Cordova, CA 95670

Interested persons were invited to attend. At the public hearing, the Central Valley Water Board heard testimony pertinent to the discharge, WDRs, and permit. For accuracy of the record, important testimony was requested in writing.

**D. Reconsideration of Waste Discharge Requirements**

Any person aggrieved by this action of the Central Valley Water Board may petition the State Water board to review the action in accordance with Water Code section 13320 and CCR, title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., within 30 calendar days of the date of adoption of this Order at the following address, except that if the thirtieth day following the date of this Order falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day:

State Water Resources Control Board  
Office of Chief Counsel  
P.O. Box 100, 1001 I Street  
Sacramento, CA 95812-0100

Or by email at [waterqualitypetitions@waterboards.ca.gov](mailto:waterqualitypetitions@waterboards.ca.gov)

[Instructions on how to file a petition for review](http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instructions.shtml)

([http://www.waterboards.ca.gov/public\\_notices/petitions/water\\_quality/wqpetition\\_instructions.shtml](http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instructions.shtml)) are available on the Internet.

**E. Information and Copying**

The Report of Waste Discharge, other supporting documents, and comments received are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Central Valley Water Board by calling (916) 464-3291.

**F. Register of Interested Persons**

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Central Valley Water Board, reference this facility, and provide a name, address, and phone number.

**G. Additional Information**

Requests for additional information or questions regarding this order should be directed to Will Chen at (916) 464-4816, or [Will.Chen@waterboards.ca.gov](mailto:Will.Chen@waterboards.ca.gov).

**ATTACHMENT G – SUMMARY OF REASONABLE POTENTIAL ANALYSIS**

Constituent	Units	MEC	B	C	CMC	CCC	Water & Org	Org. Only	Basin Plan	MCL	Reasonable Potential
Ammonia	mg/L	0.8	<0.07	2.0	6.1	3.4	--	--	--	--	Yes
Chloride	mg/L	100	1.1	250	860	230	--	--	--	250	No
Chlorodibromo methane	µg/L	6.2	<0.13	0.41	--	--	0.41	34	--	80	Yes
Cyanide, Total (as CN)	µg/L	3.6	<0.0017	5.2	5.2	22	5.2	700	220,000	--	No
Dichlorobromo methane	µg/L	27	<0.14	0.56	--	--	0.56	46	--	80	Yes
Electrical Conductivity @ 25°C	µmhos/cm	790	91	900	--	--	--	--	150	900	No
Mercury, Total Recoverable	µg/L	<0.0002	0.0021	0.050	--	--	0.050	0.051	--	2	No
Nitrate Nitrogen, Total (as N)	mg/L	9.9	<0.024	10	--	--	--	--	--	10	Yes, Table Note 2
Nitrite Nitrogen, Total (as N)	mg/L	0.15	<0.01	1.0	--	--	--	--	--	1.0	Yes, Table Note 2
Nitrate Plus Nitrite (as N)	mg/L	9.9	<0.024	10	--	--	--	--	--	10	Yes, Table Note 2
Total Dissolved Solids	mg/L	580	68	500	--	--	--	--	--	500	No

**Attachment G Table Notes:**

1. All inorganic concentrations are given as a total concentration.
2. See section IV.C.3 of the Fact Sheet for a discussion of the RPA results.

**Abbreviations used in this table:**

MEC = Maximum Effluent Concentration

LINDA COUNTY WATER DISTRICT  
WASTEWATER TREATMENT PLANT

ORDER R5-2022-0070  
NPDES NO. CA0079651

- B = Maximum Receiving Water Concentration or lowest detection level, if non-detect
- C = Criterion used for Reasonable Potential Analysis
- CMC = Criterion Maximum Concentration (CTR or NTR)
- CCC = Criterion Continuous Concentration (CTR or NTR)
- Water & Org = Human Health Criterion for Consumption of Water & Organisms (CTR or NTR)
- Org Only = Human Health Criterion for Consumption of Organisms Only (CTR or NTR)
- Basin Plan = Numeric Site-Specific Basin Plan Water Quality Objective
- MCL = Drinking Water Standards Maximum Contaminant Level
- NA = Not Available
- ND = Non-detect

**ATTACHMENT H – CALCULATION OF WQBELS**  
**HUMAN HEALTH WQBELS CALCULATIONS**

Parameter	Units	Criteria	Mean Background Concentration	Effluent CV	Dilution Factor	MDEL/AMEL Multiplier	AMEL Multiplier	AMEL	MDEL	AWEL
Chlorodibromomethane	µg/L	0.41	<0.13	0.6	63	2.01	1.55	18	36	--
Dichlorobromomethane	µg/L	0.56	<0.14	0.6	73	1.84	1.50	38	70	--
Nitrate plus Nitrite (as N)	mg/L	10	<0.02	0.6	--	1.94	1.00	10	--	17

**Attachment H-1 Table Notes:**

- CV was established according to section 1.4 of the SIP.

**Abbreviations used in this table:**

CV = Coefficient of Variation  
MDEL = Maximum Daily Effluent Limitation  
AMEL = Average Monthly Effluent Limitation  
MDEL = Maximum Daily Effluent Limitation  
AWEL = Average Weekly Effluent Limitation

**ATTACHMENT H – CALCULATION OF WQBELS**

**AQUATIC LIFE WQBELS CALCULATIONS**

Parameter	Units	CMC Criteria	CCC Criteria	B	Effluent CV	CMC Dilution Factor	CCC Dilution Factor	ECA Multiplier <sub>acute</sub>	LTA <sub>acute</sub>	ECA Multiplier <sub>chronic</sub>	LTA <sub>chronic</sub>	AMEL Multiplier <sub>95</sub>	AWEL Multiplier	MDEL Multiplier <sub>99</sub>	AMEL	AWEL	MDEL
Ammonia Nitrogen, Total (as N)	mg/L	6.1	3.4	<0.07	2.3	--	--	0.11	0.66	0.43	1.4	3.0	6.5	9.3	2.9	5.2	--

**Attachment H-2 Table Notes:**

1. AMEL calculated according to section 1.4 of the SIP using a 95<sup>th</sup> percentile occurrence probability.
2. AWEL calculated according to section 1.4 of the SIP using a 98<sup>th</sup> percentile occurrence probability.
3. MDEL calculated according to section 1.4 of the SIP using a 99<sup>th</sup> percentile occurrence probability.

**Abbreviations used in this table:**

- B = Maximum Receiving Water Concentration or lowest detection level, if non-detect
- CMC = Criterion Maximum Concentration (CTR or NTR)
- CCC = Criterion Continuous Concentration (CTR or NTR)
- CV = Coefficient of Variation (established in accordance with section 1.4 of the SIP)
- ECA = Effluent Concentration Allowance
- LTA = Aquatic Life Calculations – Long-Term Average
- MDEL = Maximum Daily Effluent Limitation
- AMEL = Average Monthly Effluent Limitation
- MDEL = Maximum Daily Effluent Limitation
- AWEL = Average Weekly Effluent Limitation