



ATTACHMENT C




<p>Reference: Report of Waste Discharge</p>	<p align="center">PROCESS FLOW DIAGRAM</p> <p align="center">TEICHERT AGGREGATES ESPARTO AGGREGATE PLANT YOLO COUNTY</p> <p align="center">ORDER NO. R5-2004-0106</p>	<p>LEGEND</p> <p>————▶ Existing Flow to Continue</p> <p>////// Former Flow (Discontinued)</p> <p>- - - -▶ Proposed Flow</p>
---	--	--

ATTACHMENT D



LEGEND

- ⊕ MONITORING WELL
- WATER SUPPLY WELL
- 150 THALWEG ELEVATIONS (FEET MSL)



Reference: Report of Waste Discharge
Addendum, Luhdorff and Scalmanini
April 2004

WELL LOCATION MAP
TEICHERT AGGREGATES
ESPARTO AGGREGATES PLANT
YOLO COUNTY

ORDER NO. R5-2004-0106

ATTACHMENT E

ORDER NO. R5-2004-0106

REQUIREMENTS FOR MONITORING WELL INSTALLATION WORKPLAN
AND MONITORING WELL INSTALLATION REPORT
TEICHERT AGGREGATES
ESPARTO AGGREGATE PLANT
YOLO COUNTY

Prior to installation of groundwater monitoring wells, the Discharger shall submit a workplan containing, at a minimum, the information listed in Section 1, below. Wells may be installed after staff approve the workplan. Upon installation of the monitoring wells, the Discharger shall submit a well installation report which includes the information contained in Section 2, below. All workplans and reports must be prepared under the direction of, and signed by, a registered geologist or civil engineer licensed by the State of California.

**SECTION 1 - Monitoring Well Installation Workplan and
Groundwater Sampling and Analysis Plan**

The monitoring well installation workplan shall contain the following minimum information:

A. General Information:

- Purpose of the well installation project
- Brief description of local geologic and hydrogeologic conditions
- Proposed monitoring well locations and rationale for well locations
- Topographic map showing facility location, roads, and surface water bodies
- Large scaled site map showing all existing on-site wells, proposed wells, surface drainage courses, surface water bodies, buildings, waste handling facilities, utilities, and major physical and man-made features

B. Drilling Details:

- On-site supervision of drilling and well installation activities
- Description of drilling equipment and techniques
- Equipment decontamination procedures
- Soil sampling intervals (if appropriate) and logging methods

C. Monitoring Well Design (in narrative and/or graphic form):

- Diagram of proposed well construction details
 - Borehole diameter
 - Casing and screen material, diameter, and centralizer spacing (if needed)
 - Type of well caps (bottom cap either screw on or secured with stainless steel screws)
 - Anticipated depth of well, length of well casing, and length and position of perforated interval
 - Thickness, position and composition of surface seal, sanitary seal, and sand pack
 - Anticipated screen slot size and filter pack

D. Well Development (not to be performed until at least 48 hours after sanitary seal placement):

California Environmental Protection Agency

Method of development to be used (i.e., surge, bail, pump, etc.)
Parameters to be monitored during development and record keeping technique
Method of determining when development is complete
Disposal of development water

- E. Well Survey (precision of vertical survey data shall be at least 0.01 foot):
Identify the Licensed Land Surveyor or Civil Engineer that will perform the survey
Datum for survey measurements
List well features to be surveyed (i.e. top of casing, horizontal and vertical coordinates, etc.)

- F. Schedule for Completion of Work

G. **Appendix: Groundwater Sampling and Analysis Plan (SAP)**

The Groundwater SAP shall be included as an appendix to the workplan, and shall be utilized as a guidance document that is referred to by individuals responsible for conducting groundwater monitoring and sampling activities.

Provide a detailed written description of standard operating procedures for the following:

- Equipment to be used during sampling
- Equipment decontamination procedures
- Water level measurement procedures
- Well purging (include a discussion of procedures to follow if three casing volumes cannot be purged)
- Monitoring and record keeping during water level measurement and well purging (include copies of record keeping logs to be used)
- Purge water disposal
- Analytical methods and required reporting limits
- Sample containers and preservatives
- Sampling
 - General sampling techniques
 - Record keeping during sampling (include copies of record keeping logs to be used)
 - QA/QC samples
- Chain of Custody
- Sample handling and transport

SECTION 2 - Monitoring Well Installation Report

The monitoring well installation report must provide the information listed below. In addition, the report must also clearly identify, describe, and justify any deviations from the approved workplan.

- A. General Information:

ATTACHMENT E
REQUIREMENTS FOR MONITORING WELL INSTALLATION WORKPLAN AND
MONITORING WELL INSTALLATION REPORT
TEICHERT AGGREGATES
ESPARTO AGGREGATE PLANT
YOLO COUNTY

Purpose of the well installation project
Brief description of local geologic and hydrogeologic conditions encountered during installation of the wells
Number of monitoring wells installed and copies of County Well Construction Permits
Topographic map showing facility location, roads, surface water bodies
Scaled site map showing all previously existing wells, newly installed wells, surface water bodies, buildings, waste handling facilities, utilities, and other major physical and man-made features.

B. Drilling Details (in narrative and/or graphic form):

On-site supervision of drilling and well installation activities
Drilling contractor and driller's name
Description of drilling equipment and techniques
Equipment decontamination procedures
Soil sampling intervals and logging methods
Well boring log

- Well boring number and date drilled
- Borehole diameter and total depth
- Total depth of open hole (same as total depth drilled if no caving or back-grouting occurs)
- Depth to first encountered groundwater and stabilized groundwater depth
- Detailed description of soils encountered, using the Unified Soil Classification System

C. Well Construction Details (in narrative and/or graphic form):

Well construction diagram, including:

- Monitoring well number and date constructed
- Casing and screen material, diameter, and centralizer spacing (if needed)
- Length of well casing, and length and position of perforated interval
- Thickness, position and composition of surface seal, sanitary seal, and sand pack
- Type of well caps (bottom cap either screw on or secured with stainless steel screws)

E. Well Development:

Date(s) and method of development
How well development completion was determined
Volume of water purged from well and method of development water disposal
Field notes from well development should be included in report

F. Well Survey (survey the top rim of the well casing with the cap removed):

Identify the coordinate system and datum for survey measurements
Describe the measuring points (i.e. ground surface, top of casing, etc.)
Present the well survey report data in a table
Include the Registered Engineer or Licensed Surveyor's report and field notes in appendix

ATTACHMENT E
REQUIREMENTS FOR MONITORING WELL INSTALLATION WORKPLAN AND
MONITORING WELL INSTALLATION REPORT
TEICHERT AGGREGATES
ESPARTO AGGREGATE PLANT
YOLO COUNTY

Sacramento Non15 Unit: updated 3 March 2004