

**18 OCTOBER 2024 BOARD MEETING
UNCONTESTED AGENDA ITEM**

AGENDA ITEM: 14.a

SUBJECT:

The following is a proposed time schedule order for consideration of adoption. All agencies and dischargers concur or have offered no comments.

BOARD ACTION:

Consideration of Adoption of a Time Schedule Order.

BACKGROUND:

**CITY OF JACKSON, CITY OF JACKSON WASTEWATER TREATMENT PLANT,
AMADOR COUNTY**

The City of Jackson (Discharger) is the owner and operator of the City of Jackson Wastewater Treatment Plant (Facility), located at 39 N. Highway 49/88, Jackson, CA 95642. The Discharger provides sewerage service for the City of Jackson and serves a population of approximately 5,060. The design average dry weather flow capacity of the Facility is 0.71 million gallons per day. The Facility provides tertiary treatment to domestic wastewater and discharges disinfected tertiary effluent to Jackson Creek, a water of the United States.

Discharges from the Facility are currently regulated by Notice of Applicability R5-2023-0025-002 (NOA), authorizing coverage under the Municipal Wastewater Dischargers That Meet Objectives/Criteria at the Point of Discharge to Surface Water Order R5-2023-0025 (Municipal General Order), issued by the Executive Officer of the Central Valley Regional Water Quality Control Board on 27 November 2023. A Time Schedule Order (Order) is proposed to allow the Discharger time to comply with the final effluent limitations for cyanide contained in the NOA. The Discharger has submitted an infeasibility report detailing proposed compliance projects and control measures, including a proposed time schedule for compliance with the final effluent limitations for cyanide. No comments were received in response to the proposed Order.

RECOMMENDATION:

Adopt the Time Schedule Order.

REVIEWS:

Management Review:	AWL (email 9/23/2024)
Legal Review:	BTD

BOARD MEETING LOCATION:

Central Valley Regional Water Quality Control Board Meeting
11020 Sun Center Dr. #200
Rancho Cordova, CA 95670

AND VIA VIDEO AND TELECONFERENCE