

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 81-9

WASTE DISCHARGE REQUIREMENTS
FOR
SUNBEAM ROADSIDE REST
West of El Centro - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Caltrans - District 11 (hereinafter also referred to as the discharger), 2829 Juan Road, San Diego, CA 92110, submitted a Report of Waste Discharge dated October 20, 1980.
2. The discharger is discharging a total maximum of about 5,400 gallons-per-day of domestic sewage from both the eastbound and westbound comfort stations. The wastewater is discharged into septic tank/leach field disposal systems located near the center of Section 7, T16S, R13E, SBB&M.
3. The discharger is alternating leach fields or reserving areas of sufficient size for possible future 100 percent replacement of the leach fields.
4. There are no tile lines in the immediate vicinity of the discharge area.
5. The Water Quality Control Plan for the West Colorado River Basin was adopted on April 10, 1975. The Basin Plan contains water quality objectives for Imperial Hydrologic Unit.
6. Groundwaters at the discharge location are saline and are not beneficially used.
7. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
8. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
9. This wastewater disposal facility constitutes an ongoing project in accordance with the provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et seq.) and Title 23, California Administrative Code,

*3-13-91
Rescinded
Ord # 91-021*

Chapter 3, Subchapter 17, Section 2715, because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:


A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. There shall be no subsurface discharge of sewage within 200 feet of the high water line of Sunbeam Lake.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach fields until such time as this complex is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of any change in operation, or in control or ownership of land and/or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify this Board of such change; and
 - b. Notify the succeeding owner or operator by letter of the existence of this Order, a copy of which shall be filed with this Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on January 28, 1981.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 81-9
FOR
SUNBEAM ROADSIDE REST
West of El Centro - Imperial County

Location: Near the center of Section 7, T16S, R13E, SBB&M

MONITORING

This discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to the sewerage system for each station.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:


Arthur Surajian

Executive Officer

July 23, 1987

Date

IN IMPERIAL COUNTY, ABOUT 6.5 MILES WEST OF
EL CENTRO AT SUNBEAM ROADSIDE REST



SITE MAP
SUNBEAM ROADSIDE REST
West of El Centro - Imperial County
Near the center of Section 7, T16S, R13E, SBB&M