CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

ORDER NO. 89-082

WASTE DISCHARGE REQUIREMENTS FOR TWENTYNINE PALMS RV PARK Twentynine Palms - San Bernardino County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

- 1. Paolo Ficara (hereinafter also referred to as the discharger), 4949 Desert Knoll, Twentynine Palms, California 92277, submitted a completed Report of Waste Discharge dated October 6, 1989.
- 2. The discharger proposes to discharge a maximum of 30,000 gallons-perday of domestic sewage from a recreational vehicle park designed to have a total of 195 RV spaces, 4 restrooms and a laundry room. The park is to be constructed in two phases. The first phase would have 120 spaces. Wastewater would be discharged into septic tank/seepage pit disposal systems located in a portion of the SE% of Section 16, T1N, R9E, SBB&M.
- 3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
- 4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).
- 5. The discharger states that the sewage disposal systems are designed for connection to a municipal sewerage system when available.
- 6. The Water Quality Control Plan (Basin Plan) for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984.
- 7. The Basin Plan delineates the location of discharge to be in the Dale Hydrologic Unit, which has the following beneficial uses of ground water:
 - a. Municipal supply (MUN)

ć.

- b. Industrial supply (IND)
- c. Agricultural supply (AGR)
- 8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for

- 9. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
- 10. The San Bernardino County Environmental Assessment Division has approved Negative Declaration E.A. No. D741-48 (filing date January 24, 1985) for the proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.
- IT IS HEREBY ORDERED, the discharger shall comply with the following:
- A. Discharge Specifications

3

- 1. Neither the treatment nor the discharge of wastewater shall create pollution or nuisance as defined in Division 7 of the California Water Code.
- 2. No wastewater other than domestic sewage shall be discharged at this location.
- 3. Wastewater discharged subsurface shall be retained underground with no surfacing.
- 4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
- 5. Septic tank cleanings shall be discharged only by a duly authorized service.
- B. Provisions
 - 1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
 - 2. The discharger shall comply with the attached "Monitoring and Reporting Program No. 89-082", and future revision thereto, as specified by the Executive Officer.
 - 3. Prior to any modification in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

- 4. Prior to any change in ownership of this recreational vehicle park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on <u>November 29, 1989</u>.

ecutive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 89-082

FOR

TWENTYNINE PALMS RV PARK Twentynine Palms - San Bernardino County

Location of Discharge: Portion of the SE¼ of Section 16, T1N, R9E, SBB&M

MONITORING

Paolo Ficara (discharger) shall report to the Regional Board concerning the following:

- 1. Number of spaces presently connected to the sewerage system.
- 2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING


1. Annual reports shall be submitted to the Regional Board by January 15th of each year to:

California Regional Water Quality Control Board Colorado River Basin Region 73-271 Highway 111, Suite 21 Palm Desert, CA 92260

2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

ORDERED BY: Executive Officer November 29, 1989 Date


CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7




SITE MAP

TWENTYNINE PALMS RV PARK Twentynine Palms - San Bernardino County A portion of the SE4 of Section 16, T1N, R9E, SBB&M USGS Twentynine Palms 7.5 min. Topographic Map.

Board Order No. 89-082



PRELIMINARY SEWAGE DISPOSAL FACILITIES SKETCH NO. 1 TWENTYNINE PALMS R.V. PARK Twentynine Palms - San Bernardino County



PRELIMINARY SEWAGE DISPOSAL FACILITIES SKETCH NO. 2 TWENTYNINE PALMS R.V. PARK

Twentynine Palms - San Bernardino County