



Colorado River Basin Regional Water Quality Control Board

January 29, 2026

VIA EMAIL ONLY

Benjamin Martinez
City Manager
City of Calexico
608 Heber Avenue
Calexico, CA, 92231
bmartinez@calexico.ca.gov

SUBJECT: CONDITIONAL SETTLEMENT OFFER NO. R7-2026-0001: OFFER TO PARTICIPATE IN EXPEDITED PAYMENT PROGRAM RELATING TO ALLEGED VIOLATIONS OF ORDER NO. R7-2019-0004, NPDES NO. CA7000009

Dear Mr. Martinez:

This letter notifies the City of Calexico (Discharger), Owner/Operator of the Calexico Water Pollution Control Plant, of alleged violation(s) of effluent limitations and provides the Discharger the opportunity to settle the violation(s) through payment of **\$81,000** in mandatory minimum penalties pursuant to California Water Code (Water Code) sections 13385, subdivisions (h) and/or (i). Please reply by February 28, 2026.

NOTICE OF VIOLATION

The Assistant Executive Officer alleges that the Discharger has violated the above-referenced National Pollutant Discharge Elimination System (NPDES) permit as identified in Exhibit A, which is attached and incorporated by reference. The Discharger can resolve the alleged violations as discussed below.

STATUTORY LIABILITY

Water Code section 13385, subdivisions (h) and (i), require the assessment of a \$3,000 mandatory minimum penalty for specified serious and chronic effluent limitation violations. The Discharger is also subject to discretionary administrative civil liability of up to \$10,000 per day for each violation, plus \$10 for each gallon discharged but not cleaned up in excess of 1,000 gallons. The Colorado River Basin Regional Water Quality Control Board (Regional Water Board) may assess mandatory minimum penalties or discretionary administrative civil liability beginning with the date on which the violations first occurred. The formal enforcement action that the Regional Water Board uses to assess such liability is an administrative civil liability complaint. Alternatively, the Regional Water Board may refer the matter to the Attorney General's Office for prosecution in the Superior Court.

VIVIAN PEREZ, CHAIR | MICHAEL PLACENCIA, EXECUTIVE OFFICER

The Superior Court may assess up to \$25,000 per day for each violation, plus \$25 per gallon discharged but not cleaned up in excess of 1,000 gallons.

DISCHARGER'S OPTIONS:

PARTICIPATE IN EXPEDITED PAYMENT PROGRAM

The Discharger can avoid the issuance of a formal enforcement action and settle the alleged violation(s) identified in Exhibit A by participating in the Regional Water Board's Expedited Payment Program. The Discharger may accept this Conditional Settlement Offer, waive its right to a hearing, and pay the mandatory minimum penalty of **\$81,000** for the violation(s) described in Exhibit A. If the Discharger elects to do so, the Regional Water Board will execute the settlement offer subject to the conditions below. The Regional Water Board will accept the payment in settlement of any enforcement action that would otherwise arise out of the violation(s) identified in Exhibit A. Accordingly, the Regional Water Board will not issue a formal administrative civil liability complaint, will not refer the violation(s) to the Attorney General's Office, and will waive its right to seek additional discretionary civil liability for the violation(s) identified in Exhibit A.

This Conditional Settlement Offer does not address or resolve liability for any violation that is not specifically identified in Exhibit A.

To accept this Conditional Settlement Offer, the Discharger must complete, sign, and return the enclosed "Acceptance of Conditional Resolution and Waiver of Right to Hearing" (Acceptance and Waiver) on or before **February 28, 2026 (30 days)**. The Acceptance and Waiver is provided as Exhibit B (enclosed).

CONTEST THE ALLEGED VIOLATIONS

If the Discharger chooses to contest any of the violations alleged in Exhibit A, please identify the specific violation(s) and the basis for the challenge (factual error, affirmative defense, etc.) on or before the due date specified above. Regional Water Board staff will evaluate the contested violation and take one of two actions:

- 1) Determine that the violation warrants dismissal, dismiss the alleged violation(s) in the California Integrated Water Quality System (CIWQS) database, notify the Discharger of the dismissal, and take no further action against the Discharger for the alleged violation(s); or
- 2) Determine that the alleged violation(s) is/are meritorious and notify the Discharger of that determination. The Discharger will then have 30 days from the date of the notice of determination to accept settlement for the violation by submitting a complete Acceptance and Waiver. If the Discharger chooses not to accept or makes no reply to the determination within 30 days, the Discharger will be contacted by the Regional Water Board staff regarding a formal enforcement proceeding for the contested violation(s). Information received by Regional Water Board staff during any formal investigation and assessment of the violation(s), as well as staff costs associated with pursuing the enforcement, may increase the liability beyond that set forth in this Conditional Settlement Offer.

CONDITIONS FOR REGIONAL WATER BOARD ACCEPTANCE OF RESOLUTION

Federal regulations require the Regional Water Board to publish and allow the public at least 30 days to comment on any settlement of an enforcement action addressing NPDES permit violations (40 C.F.R. section 123.27(d)(2)(iii)). Upon receipt of the Discharger's Acceptance and Waiver, Regional Water Board staff will publish a notice of the proposed resolution of the violation(s).

If Regional Water Board staff do not receive comments within the 30-day comment period and no new material facts become available to the Regional Water Board, the Executive Officer will execute the Acceptance and Waiver as a stipulated order assessing the uncontested mandatory minimum penalty amount pursuant to Water Code section 13385, subdivisions (h) and/or (i).

If, however, significant comments are received in opposition to the Acceptance and Waiver, this Conditional Settlement Offer may be withdrawn. In that case, the Discharger's waiver pursuant to the Acceptance and Waiver will also be treated as withdrawn and the violation(s) will be addressed in a liability assessment proceeding. At the liability assessment hearing, the Discharger will be free to make arguments as to any of the alleged violations, and the Discharger's agreement to accept this Conditional Settlement Offer will not in any way be binding or used as evidence against the Discharger. The Discharger will be provided with further information on the liability assessment proceeding.

In the event the Executive Officer executes the Acceptance and Waiver, full payment of the assessed amount shall be due within 30 calendar days from the date of the Executive Officer's signature. Funds collected for violations under Water Code section 13385, subdivision (h) and (i), shall be deposited in the State Water Pollution Cleanup and Abatement Account. Accordingly, the **\$81,000** liability shall be paid by cashiers or certified check made payable to the "State Water Pollution Cleanup and Abatement Account". Failure to pay the full penalty within the required time may subject the Discharger to further liability.

Please send your reply to the attention of Maribel Schiavone, either by email or U.S. mail. If you want to discuss or have questions regarding this Conditional Settlement Offer, please contact Maribel Schiavone at (760) 776-8941 (Maribel.Schiavone@Waterboards.ca.gov).

Sincerely,

Original Signed by

Kai Dunn, PhD, PE
Assistant Executive Officer
Colorado River Basin
Regional Water Quality Control Board

Enclosure: Exhibit A – Notice of Violation
Exhibit B – Acceptance of Conditional Resolution and Waiver of Right to
Hearing

cc: Liliana Falomir, Public Works Manager – Administrative
falomirl@calexico.ca.gov

File: WDID No. 7A130101011, Calexico WPCP, R7-2019-0004

MANDATORY PENALTY ADMINISTRATIVE CIVIL LIABILITY

Calexico City

Calexico City WWTP

WQID No. 7A130101011 NPDES No. CA7000009

EXHIBIT 'A' - R7-2026-0001

Effluent Limitation Violations Requiring Mandatory Minimum Penalties

#	Violation Number	Violation Date	Constituent	Pollutant Group	Limitation Period	Limit	Result/Average	Units	% Over Limit	Date 180 Days Prior	Serious or Chronic Violation?	No. of Violations within 180 days	Water Code	Penalty
31	1098055	11/30/2021	Biochemical Oxygen	Group 1	30-Day Average	30	38.6	mg/L	29%	06/03/2021	N/A	1		\$ 0
32	1099789	12/31/2021	Biochemical Oxygen	Group 1	30-Day Average	30	36.5	mg/L	22%	07/04/2021	N/A	2		\$ 0
33	1101192	01/31/2022	Biochemical Oxygen	Group 1	30-Day Average	30	37	mg/L	23%	08/04/2021	N/A	3		\$ 0
34	1103605	03/24/2022	Biochemical Oxygen	Group 1	Weekly Average	45	55.8	mg/L	24%	09/25/2021	C	4	13385(I)	\$ 3,000
35	1103605	03/31/2022	Biochemical Oxygen	Group 1	30-Day Average	30	41.2	mg/L	37%	10/02/2021	C	5	13385(I)	\$ 3,000
36	1104541	04/01/2022	Biochemical Oxygen	Group 1	7-Day Average (Mean)	45	48	mg/L	7%	10/03/2021	C	6	13385(I)	\$ 3,000
37	1104542	04/30/2022	Biochemical Oxygen	Group 1	30-Day Average	30	30.6	mg/L	2%	11/01/2021	C	7	13385(I)	\$ 3,000
38	1106536	06/29/2022	Enterococci	Other	Instantaneous	100	240	MPN/100	N/A	12/31/2021	C	7	13385(I)	\$ 3,000
39	1109556	09/27/2022	Enterococci	Other	Instantaneous	100	920	MPN/100	N/A	03/31/2022	C	5	13385(I)	\$ 3,000
40	1113908	01/31/2023	Biochemical Oxygen	Group 1	30-Day Average	30	34	mg/L	13%	08/04/2022	N/A	2		\$ 0
41	1114984	02/09/2023	Biochemical Oxygen	Group 1	7-Day Average (Mean)	45	45.2	mg/L	0%	08/13/2022	N/A	3		\$ 0
42	1114982	02/14/2023	Enterococci	Other	Instantaneous	100	350	MPN/100	N/A	08/18/2022	C	4	13385(I)	\$ 3,000
43	1114983	02/28/2023	Biochemical Oxygen	Group 1	30-Day Average	30	35.5	mg/L	18%	09/01/2022	C	5	13385(I)	\$ 3,000
44	1115744	03/15/2023	Fecal Coliform	Other	Instantaneous	400	540	MPN/100	N/A	09/16/2022	C	6	13385(I)	\$ 3,000
45	1115743	03/22/2023	Enterococci	Other	Instantaneous	100	130	MPN/100	N/A	09/23/2022	C	7	13385(I)	\$ 3,000
46	1117328	04/25/2023	E.coli	Other	Instantaneous	400	540	MPN/100	N/A	10/27/2022	C	7	13385(I)	\$ 3,000
47	1117325	04/30/2023	Biochemical Oxygen	Group 1	30-Day Average	30	31.3	mg/L	4%	11/01/2022	C	8	13385(I)	\$ 3,000
48	1118014	05/24/2023	E.coli	Other	Instantaneous	400	920	MPN/100	N/A	11/25/2022	C	9	13385(I)	\$ 3,000
49	1118721	06/21/2023	E.coli	Other	Instantaneous	400	1600	MPN/100	N/A	12/23/2022	C	10	13385(I)	\$ 3,000
50	1118723	06/22/2023	Biochemical Oxygen	Group 1	Instantaneous	45	49	mg/L	9%	12/24/2022	C	11	13385(I)	\$ 3,000
51	1118726	06/27/2023	E.coli	Other	Instantaneous	400	1600	MPN/100	N/A	12/29/2022	C	12	13385(I)	\$ 3,000
52	1118717	06/30/2023	E.coli	Other	30-Day Average	126	177.3	MPN/100	N/A	01/01/2023	C	13	13385(I)	\$ 3,000
53	1118724	06/30/2023	Biochemical Oxygen	Group 1	30-Day Average	30	39.9	mg/L	33%	01/01/2023	C	14	13385(I)	\$ 3,000
54	1118725	06/30/2023	BOD5 @ 20 Deg. C,	Group 1	Percent Reduction	85	83	%	-2%	01/01/2023	C	15	13385(I)	\$ 3,000
55	1119723	07/19/2023	E.coli	Other	Instantaneous	400	1600	MPN/100	N/A	01/20/2023	C	16	13385(I)	\$ 3,000
56	1119715	07/25/2023	E.coli	Other	Instantaneous	400	1600	mi/L/hr	N/A	01/26/2023	C	17	13385(I)	\$ 3,000
57	1119724	07/26/2023	E.coli	Other	Instantaneous	400	1600	MPN/100	N/A	01/27/2023	C	18	13385(I)	\$ 3,000
58	1119713	07/31/2023	Enterococci	Other	30-Day Average	33	136.2	MPN/100	N/A	02/01/2023	C	18	13385(I)	\$ 3,000
59	1119714	07/31/2023	Fecal Coliform	Other	30-Day Average	400	403.4	MPN/100	N/A	02/01/2023	C	19	13385(I)	\$ 3,000
60	1119721	07/31/2023	E.coli	Other	30-Day Average	126	403.4	MPN/100	N/A	02/01/2023	C	20	13385(I)	\$ 3,000
61	1123742	12/20/2023	Enterococci	Other	Instantaneous	100	170	MPN/100	N/A	06/23/2023	C	11	13385(I)	\$ 3,000
62	1124545	01/04/2024	Biochemical Oxygen	Group 1	7-Day Average (Mean)	45	57.6	mg/L	28%	07/08/2023	C	8	13385(I)	\$ 3,000

\$ 81,000

- 1 - Violation occurs on sample date or last date of averaging period.
- 2 - For Group I pollutants, a violation is serious when the limit is exceeded by 40% or more
 - For Group II pollutants, a violation is serious when the limit is exceeded by 20% or more
- 3 - When a serious violation occurs on the same day as a chronic, the serious violation is only assessed an MMP once and is counted last for the day when determining the number of chronic violations to be assessed a

Violation period ending the last day of January 2024

Group I Violations Assessed MMP: 10
 Group II Violations Assessed MMP: 0
 Other Effluent Violations Assessed MMP: 17
 Violations Exempt from MMP: 5
 Total Violations Assessed MMP: 27

Mandatory Minimum Penalty = (0 Serious Violations + 27 Non-Serious Violations) x \$3,000 = \$81,000

EXHIBIT B
ACCEPTANCE OF CONDITIONAL RESOLUTION
AND WAIVER OF RIGHT TO HEARING

City Of Calexico, Owner/Operator
Calexico Water Pollution Control Plant
WDR Order No. R7-2019-0004 (NPDES No. CA7000009)

By signing below and returning this Acceptance of Conditional Resolution and Waiver of Right to Hearing (Acceptance and Waiver) to the California Regional Water Quality Control Board, Colorado River Basin Region (Regional Water Board), the City of Calexico (Discharger), owner/operator of the Calexico Water Pollution Control Plant, hereby accepts the conditional settlement offer to settle the alleged violations through payment of mandatory minimum penalties and waives the right to a hearing before the Regional Water Board to dispute the alleged violations. The alleged violations are attached to this Acceptance and Waiver as Exhibit A, which is incorporated herein by reference.

The Discharger agrees that Exhibit A shall serve as a Complaint pursuant to Article 2.5 of the California Water Code and that no separate Complaint is required for the Regional Water Board to assert jurisdiction over the alleged violations through its Assistant Executive Officer. The Discharger agrees to pay the penalties required by California Water Code section 13385 in the sum of **\$81,000** (Expedited Payment Amount), which shall be deemed payment in full of any civil liability pursuant to Water Code section 13385 that otherwise might be assessed for the violation(s) described in Exhibit A. The Discharger understands that this Acceptance and Waiver waives its right to contest the allegations in Exhibit A and the amount of civil liability assessed for the violations.

The Discharger understands that this Acceptance and Waiver does not address or resolve liability for any violation that is not specifically identified in Exhibit A.

Upon execution by the Discharger, the completed Acceptance and Waiver shall be returned to:

California Regional Water Quality Control Board, Colorado River Basin
Attention: Maribel Schiavone
73720 Fred Waring Drive, Suite 100
Palm Desert, CA 92260

The Discharger understands that federal regulations set forth at Code of Federal Regulations, title 40, section 123.27(d)(2)(iii) require the Regional Water Board to publish notice of and provide at least thirty (30) days for public comment on any proposed resolution of an enforcement action addressing NPDES permit violations. Accordingly, this Acceptance and Waiver will be published as required by law for public comment prior to the Executive Officer's execution.

The Discharger understands that if no comments are received within the public notice period that causes the Executive Officer to question the conditional settlement offer, the Executive Officer will execute this Acceptance and Waiver.

The Discharger understands that if significant comments are received in opposition to the conditional settlement offer, the offer may be withdrawn. In that circumstance, the Discharger will be advised of the withdrawal and an administrative civil liability complaint may be issued and the matter may be set for a hearing before the Regional Water Board. For such a liability hearing, the Discharger understands that its executed Acceptance and Waiver will be treated as a settlement communication and will not be used as evidence in that hearing.

The Discharger understands that once the Executive Officer executes this Acceptance and Waiver, the full payment required by the deadline set forth below is a condition of this Acceptance and Waiver.

The Discharger understands that funds collected for violations under Water Code section 13385 shall be deposited in the State Water Pollution Cleanup and Abatement Account. Accordingly, the liability shall be paid by a cashier's or certified check for **\$81,000** made out to the "State Water Pollution Cleanup and Abatement Account."

The Discharger understands that payment must be submitted to the State Water Resources Control Board no later than thirty (30) calendar days after the date on which the Executive Officer executes this Acceptance and Waiver.

The Discharger shall mail the check to:

State Water Resources Control Board
Division of Administrative Services, Accounting Branch
Attn: ACL Payment
PO Box 1888
Sacramento, CA 95812-1888

I hereby affirm that I am duly authorized to act on behalf of and to bind the Discharger in the making and giving of this Acceptance and Waiver.

City of Calexico

<i>Original Signed by</i>	<i>2/3/2026</i>
By: _____	_____
Signed Name	Date

<i>Benjamin A. Martinez</i>	<i>City Manager</i>
_____	_____
Printed or Typed Name	Title

Note: Please return the signed Acceptance and Waiver with Exhibit A, together.

IT IS SO ORDERED PURSUANT TO WATER CODE SECTION 13323 AND GOVERNMENT CODE SECTION 11415.60.

By: _____ Date _____
MICHAEL PLACENCIA
Executive Officer