

Approved backflow prevention assembly standards

All backflow prevention assemblies (BPAs) used for compliance with the CCCPH must meet both laboratory and field evaluation tests performed in accordance with at least one of the two following:

(1) Standards found in Chapter 10 of the *Manual of Cross-Connection Control, Tenth Edition*, published by the University of Southern California Foundation for Cross-Connection Control and Hydraulic Research. A list of the BPAs which meet USC Standards can be found at: <https://fccchr.usc.edu/list.html>

(2) certification requirements for backflow prevention assemblies in the Standards of American Society of Sanitary Engineering (ASSE) International current as of 2022 that include ASSE 1015-2021 for the DC, ASSE 1048-2021 for the DCDA & DCDA-II, ASSE 1013-2021 for the RP, and ASSE 1047-2021 for the RPDA & RPDA-II and must have the 1YT mark. A list of the BPAs which meet ASSE Standards can be found at:

<https://forms.iapmo.org/asse/listed/>