



Alan C. Lloyd, Ph.D.  
Agency Secretary

# California Regional Water Quality Control Board

## Los Angeles Region

320 W. 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013  
Phone (213) 576-6600 • Fax (213) 576-6640  
<http://www.waterboards.ca.gov>



Arnold Schwarzenegger  
Governor

**ORDER NO. R4-2005-0065**  
**NPDES NO. CA0059285**

The following Discharger is authorized to discharge in accordance with the conditions set forth in this Order:

<b>Discharger</b>	BP West Coast Products LLC (Owner) and BP Pipelines NA (Operator)
<b>Name of Facility</b>	Long Beach Marine Terminal 1, Berth 121
<b>Facility Address</b>	620 Pier T Avenue, Berth 121
	Long Beach, CA 90802
	Los Angeles County

The Discharger is authorized to discharge from the following discharge points as set forth below:

Discharge Point	Effluent Description	Discharge Latitude	Discharge Longitude	Receiving Water
001	Storm water, washwater, tank hydrotest water	33 ° 45' 30" N	118 ° 13' 15" W	Long Beach Inner Harbor

This Order was adopted by the Regional Water Board on:	October 6, 2005
This Order shall become effective on:	November 6, 2005
This Order shall expire on:	September 10, 2010
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Board have classified this discharge as a minor discharge.	
The Discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, not later than 180 days in advance of the Order expiration date as application for issuance of new waste discharge requirements.	

IT IS HEREBY ORDERED, that Order No. 00-089 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the California Water Code (CWC) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA), and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Jonathan S. Bishop, Executive Officer, do hereby certify the following is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on October 6, 2005.

**Jonathan S. Bishop**, Executive Officer

**Table F-10**  
**Summary of Final Effluent Limitations**  
**Wash Water Discharge Through Discharge Point 001**

Parameter	Units	Final Effluent Limitations				Basis <sup>1</sup>
		Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum	
Biochemical Oxygen Demand 5-day @ 20°C (BOD)	mg/L lbs/day <sup>2</sup>	---	30	---	---	E, BPJ
Oil and Grease	mg/L	---	15	---	---	E, BPJ
	lbs/day <sup>2</sup>	---	0.13	---	---	
pH	standard units	---	---	6.5	8.5	BP
Total Suspended Solids (TSS)	mg/L	---	75	---	---	E, BPJ
	lbs/day <sup>2</sup>	---	0.63	---	---	
Cadmium, Total Recoverable	µg/L	---	15	---	---	CTR
	lbs/day <sup>2</sup>	---	0.00013	---	---	
Chromium (VI)	µg/L	---	83	---	---	CTR
	lbs/day <sup>2</sup>	---	0.00069	---	---	
Lead, Total Recoverable	µg/L	---	14	---	---	CTR
	lbs/day <sup>2</sup>	---	0.00012	---	---	
Zinc, Total Recoverable	µg/L	---	95	---	---	CTR
	lbs/day <sup>2</sup>	---	0.0008	---	---	
Phenol	µg/L	---	5	---	---	E, BPJ
	lbs/day <sup>2</sup>	---	0.000042	---	---	
Flow	MGD	---	0.001	---	---	E, BPJ
Temperature	°F	---	86	---	---	BP, TP
Turbidity	NTU	---	75	---	---	E, BPJ

<sup>1</sup> BP = Basin Plan, BPJ = Best Professional Judgment, CTR = California Toxics Rule, E= Existing permit limitation, TP = Thermal Plan

<sup>2</sup> Based on a flow of 0.001 MGD