

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
8/1/2004	15	15							<6	3		
8/9/2004			0.6	0.6	1.2	<0.5	0.1	0.1				
8/9/2004												
8/10/2004											4.4	4.4
8/18/2004												
9/1/2004	8	8							<6	3		
9/13/2004			0.5	0.5	1.1		0.1	0.1				
9/13/2004												
9/14/2004											5.1	5.1
10/1/2004	32	32							<6	3		
10/4/2004			0.3	0.3	1.4		0.2	0.2				
10/4/2004												
10/5/2004											4.9	4.9
11/1/2004			0.3	0.3	1.3		0.2	0.2	3	3		
11/1/2004												
11/2/2004											4.4	4.4
12/1/2004	35	35							<6	3		
12/6/2004			0.3	0.3	1.3		1.1	1.1				
12/6/2004												
12/7/2004											<10	5
12/8/2004			<0.5	0.25	1.1	<0.5	0.2	0.2				
1/1/2005	<50	25							0.84	0.84		
1/3/2005			0.4	0.4	1.2		0.19	0.19				
1/3/2005												
1/4/2005											3.4	3.4
2/1/2005	<50	25							0.69	0.69		
2/7/2005			<0.5	0.25	0.8	<0.25	0.1	0.1				
2/7/2005												
2/8/2005											5.8	5.8
3/1/2005	40	40	0.3	0.3	2.1		0.09	0.09	0.69	0.69		
3/1/2005												
3/2/2005											3.4	3.4
3/30/2005												
4/1/2005	<50	25							0.73	0.73		
4/4/2005			0.3	0.3	1.2		0.09	0.09				
4/4/2005												
4/5/2005											3.6	3.6
4/28/2005												
5/1/2005	30	30							0.77	0.77		
5/2/2005			0.4	0.4	1.5	0.07	0.25	0.25				
5/2/2005												
5/3/2005											<10	5
5/25/2005												
6/1/2005	<50	25							0.58	0.58		
6/6/2005			0.5	0.5	1.5	0.03	<0.25	0.125				
6/6/2005												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L
6/7/2005											4.6	4.6
6/27/2005												
6/28/2005												
7/1/2005	30	30							0.38	0.38		
7/11/2005			<0.5	0.25	2.2	0.04	<0.25	0.125				
7/11/2005												
7/12/2005											5.2	5.2
7/26/2005												
8/1/2005	40	40							0.6	0.6		
8/2/2005			0.4	0.4	1.6	0.03	0.14	0.14				
8/3/2005											4	4
8/24/2005												
9/1/2005	<50	25							1.2	1.2		
9/6/2005			0.3	0.3	1.3	<0.25	<0.25	0.125				
9/7/2005											3.6	3.6
9/28/2005												
10/1/2005	<50	25							0.74	0.74		
10/11/2005			0.3	0.3	1.3	<0.25	<0.25	0.125				
10/12/2005											3.6	3.6
10/20/2005												
10/25/2005												
11/1/2005	<50	25							0.79	0.79		
11/7/2005			0.3	0.3	0.9	<0.25	<0.25	0.125				
11/8/2005											2.9	2.9
11/29/2005												
12/1/2005	<50	25							<0.6	0.3		
12/12/2005			<0.5	0.25	1.1	<0.5	<2.5	1.25				
12/13/2005											<10	5
12/28/2005												
1/1/2006	<50	25							1.1	1.1		
1/9/2006			<0.5	0.25	1.3	<0.25	<0.25	0.125				
1/10/2006											2	2
1/30/2006												
2/1/2006	<50	25							0.99	0.99		
2/13/2006			<0.5	0.25	1	<0.25	<0.25	0.125				
2/14/2006											1.5	1.5
3/1/2006	<50	25							0.9	0.9		
3/6/2006			0.4	0.4	0.9	<0.25	<0.25	0.125				
3/7/2006											3.4	3.4
3/30/2006												
4/1/2006	<50	25							1.03	1.03		
4/11/2006			<0.5	0.25	1.1	<0.25	0.81	0.81				
4/12/2006											3.6	3.6
4/26/2006												
5/1/2006	<50	25							0.9	0.9		
5/8/2006			0.4	0.4	1.1	<0.25	<0.25	0.125				
5/9/2006											0.8	0.8
5/31/2006												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
6/1/2006	<50	25							1.31	1.31		
6/12/2006			0.3	0.3	1	<0.25	<0.25	0.125				
6/13/2006											<10	5
6/26/2006												
7/1/2006	<50	25							0.94	0.94		
7/10/2006			<0.5	0.25	1	<0.25	0.06	0.06				
7/11/2006											1.5	1.5
7/26/2006												
8/1/2006	<50	25	0.48	0.48	1.22	<0.25	0.12	0.12	1	1		
8/2/2006											2.5	2.5
8/15/2006												
8/29/2006												
9/1/2006	<50	25							1.05	1.05		
9/5/2006			<0.5	0.25	1.67	<0.25	<0.25	0.125				
9/6/2006											3.7	3.7
9/21/2006												
9/27/2006												
10/1/2006	<50	25							0.92	0.92		
10/9/2006			0.45	0.45	1.08	<0.25	0.18	0.18				
10/10/2006											2.5	2.5
10/24/2006												
11/1/2006	<50	25							1.06	1.06		
11/7/2006												
11/13/2006			0.48	0.48	0.92	<0.25	0.21	0.21				
11/14/2006											2.9	2.9
11/21/2006												
12/1/2006	<50	25							1.21	1.21		
12/7/2006												
12/14/2006			0.27	0.27	1.04	<0.25	0.1	0.1			1.2	1.2
12/28/2006												
1/1/2007	<50	25										
1/8/2007			0.34	0.34	0.91		0.06	0.06				
1/9/2007									0.95	0.95	1	1
1/10/2007												
1/23/2007												
2/1/2007	<50	25							1.23	1.23		
2/8/2007												
2/12/2007			0.45	0.45	0.996	<0.25	0.04	0.04				
2/13/2007											1.5	1.5
2/27/2007												
3/1/2007	<50	25										
3/7/2007												
3/12/2007			0.35	0.35	0.99		0.06	0.06				
3/27/2007												
4/1/2007	<50	25							2.11	2.11		
4/3/2007												
4/9/2007			0.31	0.31	1.19		0.07	0.07				
4/10/2007											<10	5

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
4/25/2007												
5/1/2007	<50	25							1.3	1.3		
5/14/2007			0.28	0.28	1.3		0.06	0.06				
5/15/2007											2.2	2.2
5/21/2007												
5/30/2007			<0.5	0.25	1.19	<0.25	<0.25	0.125			3.9	3.9
5/30/2007												
6/1/2007	60	60							1.26	1.26		
6/4/2007			0.43	0.43	1.26		0.09	0.09				
6/5/2007											<10	5
6/22/2007												
6/26/2007												
7/1/2007	<50	25							1.16	1.16		
7/9/2007			0.4	0.4	1.08		0.15	0.15				
7/10/2007											1.5	1.5
7/30/2007												
8/1/2007	<50	25							0.93	0.93		
8/3/2007												
8/13/2007			0.42	0.42	1.52	<0.25	0.19	0.19				
8/14/2007											4.3	4.3
8/29/2007												
9/1/2007	<50	25							0.89	0.89		
9/10/2007			0.43	0.43	1.65		0.07	0.07				
9/11/2007											3.8	3.8
9/25/2007												
10/1/2007	<50	25							1.31	1.31		
10/4/2007												
10/9/2007			0.47	0.47	1.43		0.1	0.1				
10/10/2007											0.7	0.7
10/30/2007												
11/1/2007	<50	25							0.95	0.95		
11/13/2007			0.45	0.45	0.98		0.09	0.09				
11/14/2007											2.1	2.1
11/19/2007												
11/29/2007												
12/1/2007	<50	25							0.91	0.91		
12/4/2007												
12/10/2007			0.32	0.32	1.05		0.07	0.07				
12/11/2007											<10	5
12/21/2007												
1/7/2008												
1/10/2008												
1/14/2008			0.32	0.32	1.39		0.11	0.11				
1/14/2008												
1/15/2008	<50	25							0.84	0.84	3.1	3.1
2/1/2008									0.77	0.77		
2/4/2008			0.42	0.42	1.41	<0.25	0.09	0.09				
2/4/2008												
2/5/2008	<50	25									<10	5

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
2/12/2008												
3/1/2008									0.79	0.79		
3/5/2008												
3/10/2008			0.44	0.44	0.87		0.08	0.08				
3/10/2008												
3/11/2008	<80	40									<10	5
3/12/2008												
4/1/2008												
4/7/2008			0.41	0.41	1.11		0.05	0.05				
4/7/2008												
4/8/2008	<80	40									2.7	2.7
4/9/2008												
4/18/2008												
4/23/2008									0.71	0.71		
5/5/2008												
5/7/2008									0.63	0.63		
5/9/2008												
5/12/2008			0.45	0.45	1.17		0.04	0.04				
5/12/2008												
5/13/2008	<80	40									1	1
6/3/2008												
6/9/2008			0.54	0.54	1.16		0.07	0.07				
6/9/2008												
6/10/2008	<80	40									<10	5
6/19/2008												
6/27/2008									0.96	0.96		
7/2/2008												
7/9/2008			0.59	0.59	1.28		0.06	0.06				
7/9/2008												
7/10/2008	<80	40									0.7	0.7
7/17/2008												
8/11/2008			0.47	0.47	1.55	<0.25	0.11	0.11				
8/12/2008	32	32									5.3	5.3
8/13/2008												
8/21/2008									0.72	0.72		
9/2/2008			0.52	0.52	1.53		0.17	0.17				
9/3/2008	44	44									1.5	1.5
9/4/2008												
9/10/2008												
9/15/2008									0.73	0.73		
10/1/2008												
10/6/2008												
10/14/2008			0.42	0.42	1.44		0.07	0.07				
10/15/2008	27	27									2.7	2.7
10/27/2008									0.83	0.83		
11/10/2008												
11/13/2008	34	34	0.4	0.4	1.31		0.15	0.15	2.06	2.06	3	3
11/18/2008												
12/5/2008												
12/8/2008			0.4	0.4	1.68		0.18	0.18				

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR			1		2	3	4		5a		5b	5b
	Iron	1/2 Iron	Antimony	1/2 Antimony	Arsenic	Beryllium	Cadmium	1/2 Cadmium	Chromium III	1/2 Chromium III	Chromium VI	1/2 Chromium VI
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L
12/9/2008											2.3	2.3
MEC	60		0.6		2.2	0.07	1.1		3		5.8	
MAXIMUM	60		0.6		2.2	0.07	1.1		3		5.8	
MINIMUM	8		0.27		0.8	0.03	0.04		0.38		0.7	
DETECTS	13		45		54	4	42		45		43	
COUNT	51		55		54	28	55		50		53	
% NONDETECT	74.5098		18.18182		0	85.7	23.6		10		18.86792	
ST DEVIATION		8.08543		0.096257	0.282306	0.01893		0.22407		0.69887		1.480068
AVERAGE		28.4706		0.372909	1.252291	0.0425		0.16764		1.1552		3.354717
CV		0.28399		0.258125	0.225432	0.4454		1.33667		0.60498		0.44119
Default CV		0.3		0.3	0.2	0.6		1.3	0.6	0.6		0.4
ECA multipliers Table 1												
ECA Acute 99 multiplier		0.527		0.527	0.643	0.321		0.162	0.321	0.321		0.440
ECA Chronic99 multiplier		0.715		0.715	0.797	0.527		0.300	0.527	0.527		0.643
AMEL multiplier95		1.264		1.264	1.172	1.552		2.226	1.552	1.552		1.358
MDEL multiplier99		1.896		1.896	1.554	3.114		6.166	3.114	3.114		2.275
MDEL/AMEL Multiplier		1.500		1.500	1.326	2.006		2.770	2.006	2.006		1.675
Bold = Detect												
Blue = DNQ												
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present												

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	
8/1/2004												
8/9/2004		4	4	2	0.03	0.03	<20	10	0.3	0.3	<0.2	0.1
8/9/2004												
8/10/2004												
8/18/2004					0.0025	0.0025						
9/1/2004												
9/13/2004	<8		4	3	<0.04	0.02	<20	10	0.3	0.3	<0.2	0.1
9/13/2004												
9/14/2004												
10/1/2004												
10/4/2004		3	3	3	<0.04	0.02	<20	10	0.4	0.4	<0.2	0.1
10/4/2004												
10/5/2004												
11/1/2004	<8		4	3	<0.04	0.02	<20	10	0.4	0.4	<0.2	0.1
11/1/2004												
11/2/2004												
12/1/2004												
12/6/2004	<8		4	4	<0.04	0.02	<20	10	0.4	0.4	<0.2	0.1
12/6/2004												
12/7/2004												
12/8/2004	<8		4	6	<0.04	0.02	<20	10	0.4	0.4	<0.2	0.1
1/1/2005												
1/3/2005		6	6	1.8	<0.04	0.02	0.7	0.7	0.4	0.4	<0.2	0.1
1/3/2005												
1/4/2005												
2/1/2005												
2/7/2005		3.9	3.9	1.7	<0.04	0.02	1.7	1.7	0.6	0.6	0.03	0.03
2/7/2005												
2/8/2005												
3/1/2005		3.7	3.7	1.7	<0.04	0.02	1	1	0.7	0.7	0.03	0.03
3/1/2005												
3/2/2005												
3/30/2005					0.0046	0.0046						
4/1/2005												
4/4/2005		6	6	1.6	<0.04	0.02	1.1	1.1	0.6	0.6	0.05	0.05
4/4/2005												
4/5/2005												
4/28/2005					0.0041	0.0041						
5/1/2005												
5/2/2005		4.7	4.7	2	<0.04	0.02	0.9	0.9	0.6	0.6	0.06	0.06
5/2/2005												
5/3/2005												
5/25/2005					0.0015	0.0015						
6/1/2005												
6/6/2005		4	4	3.6	<0.04	0.02	0.3	0.3	0.5	0.5	<0.25	0.125
6/6/2005												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	
6/7/2005												
6/27/2005												
6/28/2005					0.0038	0.0038						
7/1/2005												
7/11/2005		4	4	1.6	<0.04	0.02	1	1	0.5	0.5	<0.25	0.125
7/11/2005												
7/12/2005												
7/26/2005					0.0042	0.0042						
8/1/2005												
8/2/2005		4.4	4.4	1.9	<0.04	0.02	2.8	2.8	0.5	0.5	<0.25	0.125
8/3/2005												
8/24/2005					0.0046	0.0046						
9/1/2005												
9/6/2005		5.7	5.7	1.9	<0.04	0.02	1.7	1.7	0.4	0.4	<0.25	0.125
9/7/2005												
9/28/2005					0.0049	0.0049						
10/1/2005												
10/11/2005		6.9	6.9	2.6	<0.04	0.02	1.5	1.5	0.4	0.4	<0.25	0.125
10/12/2005												
10/20/2005												
10/25/2005					0.0036	0.0036						
11/1/2005												
11/7/2005		4.6	4.6	3.4	<0.04	0.02	1.5	1.5	0.8	0.8	<0.25	0.125
11/8/2005												
11/29/2005					0.0067	0.0067						
12/1/2005												
12/12/2005		5.4	5.4	2.1	<0.04	0.02	<2	1	0.2	0.2	<2.5	1.25
12/13/2005												
12/28/2005					0.0052	0.0052						
1/1/2006												
1/9/2006		2.5	2.5	0.93	<0.04	0.02	<1	0.5	0.6	0.6	<0.25	0.125
1/10/2006												
1/30/2006					0.0019	0.0019						
2/1/2006												
2/13/2006		5.09	5.09	1.1	<0.04	0.02	1.59	1.59	0.5	0.5	<0.25	0.125
2/14/2006												
3/1/2006												
3/6/2006		3.67	3.67	1.07	<0.04	0.02	1.2	1.2	0.7	0.7	<0.25	0.125
3/7/2006					0.0046	0.0046						
3/30/2006					0.0014	0.0014						
4/1/2006												
4/11/2006		3.92	3.92	1.49	<0.04	0.02	1.53	1.53	0.7	0.7	<0.25	0.125
4/12/2006												
4/26/2006					0.00056	0.00056						
5/1/2006												
5/8/2006		3.58	3.58	0.94	<0.04	0.02	1.06	1.06	0.5	0.5	<0.25	0.125
5/9/2006												
5/31/2006												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L			µg/L	µg/L
6/1/2006												
6/12/2006		3.94	3.94	1.77	<0.04	0.02	1.43	1.43	0.4	0.4	<0.25	0.125
6/13/2006												
6/26/2006					0.0037	0.0037						
7/1/2006												
7/10/2006		4.35	4.35	0.96	<0.04	0.02	1.78	1.78	0.6	0.6	0.04	0.04
7/11/2006												
7/26/2006					0.00366	0.00366						
8/1/2006		5.37	5.37	1.62	<0.04	0.02	2.31	2.31	0.54	0.54	0.07	0.07
8/2/2006												
8/15/2006												
8/29/2006					0.00241	0.00241						
9/1/2006												
9/5/2006		4.24	4.24	1.18	<0.04	0.02	1.64	1.64	<1	0.5	<0.25	0.125
9/6/2006												
9/21/2006												
9/27/2006					0.0077	0.0077						
10/1/2006												
10/9/2006		3.8	3.8	1.58	<0.04	0.02	1.44	1.44	0.57	0.57	<0.25	0.125
10/10/2006												
10/24/2006					0.00295	0.00295						
11/1/2006												
11/7/2006												
11/13/2006		4.86	4.86	1.2	<0.04	0.02	1.15	1.15	0.45	0.45	<0.25	0.125
11/14/2006												
11/21/2006					0.00289	0.00289						
12/1/2006												
12/7/2006												
12/14/2006		6.1	6.1	0.98	<0.04	0.02	0.54	0.54	0.76	0.76	0.04	0.04
12/28/2006					0.0029	0.0029						
1/1/2007												
1/8/2007		4.28	4.28	0.63	<0.04	0.02	0.23	0.23	0.5	0.5	0.03	0.03
1/9/2007												
1/10/2007												
1/23/2007					0.0022	0.0022						
2/1/2007												
2/8/2007												
2/12/2007		5.59	5.59	0.67	<0.04	0.02	1.19	1.19	0.57	0.57	0.05	0.05
2/13/2007					<0.04	0.02						
2/27/2007					0.0052	0.0052						
3/1/2007												
3/7/2007												
3/12/2007		4.63	4.63	1.47			1.49	1.49	0.51	0.51	0.03	0.03
3/27/2007					0.0036	0.0036						
4/1/2007												
4/3/2007												
4/9/2007		3.34	3.34	1.66	<0.04	0.02	1.54	1.54	0.66	0.66	0.04	0.04
4/10/2007												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	
4/25/2007					0.0071	0.0071						
5/1/2007												
5/14/2007		5.28	5.28	1.57	<0.04	0.02	0.66	0.66	0.66	0.66	0.05	0.05
5/15/2007												
5/21/2007												
5/30/2007		3.89	3.89	1.27	<0.04	0.02	<1	0.5	<1	0.5	<0.25	0.125
5/30/2007					0.0032	0.0032						
6/1/2007												
6/4/2007		4.39	4.39	1.79	<0.04	0.02	0.72	0.72	0.5	0.5	0.05	0.05
6/5/2007												
6/22/2007												
6/26/2007					0.0035	0.0035						
7/1/2007												
7/9/2007		4.77	4.77	1.13	<0.04	0.02	1.78	1.78	0.49	0.49	0.04	0.04
7/10/2007												
7/30/2007					0.0045	0.0045						
8/1/2007												
8/3/2007												
8/13/2007		4.32	4.32	1.24	<0.04	0.02	1.61	1.61	0.43	0.43	<0.25	0.125
8/14/2007												
8/29/2007					0.0043	0.0043						
9/1/2007												
9/10/2007		6.72	6.72	1.55	0.02	0.02	2.42	2.42	0.48	0.48	<0.25	0.125
9/11/2007												
9/25/2007					0.0046	0.0046						
10/1/2007												
10/4/2007												
10/9/2007		5.91	5.91	1.5	<0.04	0.02	2.12	2.12	0.48	0.48	0.18	0.18
10/10/2007												
10/30/2007					0.0043	0.0043						
11/1/2007												
11/13/2007		5.15	5.15	0.74	<0.04	0.02	2.32	2.32	0.45	0.45	0.07	0.07
11/14/2007												
11/19/2007												
11/29/2007					0.0038	0.0038						
12/1/2007												
12/4/2007					0.0028	0.0028						
12/10/2007		5.08	5.08	0.74			1.36	1.36	0.47	0.47	0.05	0.05
12/11/2007												
12/21/2007												
1/7/2008					0.0025	0.0025						
1/10/2008												
1/14/2008		5.68	5.68	0.84			1.13	1.13	0.51	0.51	<0.25	0.125
1/14/2008												
1/15/2008												
2/1/2008												
2/4/2008		5.41	5.41	0.87			1.78	1.78	0.69	0.69	<0.25	0.125
2/4/2008												
2/5/2008					<0.001	0.0005						

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	
2/12/2008												
3/1/2008												
3/5/2008					0.00319	0.00319						
3/10/2008		4.26	4.26	0.82			1.26	1.26	0.49	0.49	0.09	0.09
3/10/2008												
3/11/2008												
3/12/2008												
4/1/2008												
4/7/2008		4.57	4.57	0.57			4.57	4.57	0.43	0.43	0.05	0.05
4/7/2008												
4/8/2008												
4/9/2008					0.0044	0.0044						
4/18/2008												
4/23/2008												
5/5/2008					0.0043	0.0043						
5/7/2008												
5/9/2008												
5/12/2008		4.26	4.26	0.5			1.35	1.35	0.45	0.45	0.08	0.08
5/12/2008												
5/13/2008												
6/3/2008					0.0044	0.0044						
6/9/2008		4.89	4.89	0.5			1.86	1.86	0.47	0.47	0.07	0.07
6/9/2008												
6/10/2008												
6/19/2008												
6/27/2008												
7/2/2008					0.0166	0.0166						
7/9/2008		6.53	6.53	0.71			5.19	5.19	0.55	0.55	0.09	0.09
7/9/2008												
7/10/2008												
7/17/2008												
8/11/2008		4.29	4.29	0.42			2.73	2.73	0.47	0.47	0.05	0.05
8/12/2008												
8/13/2008					0.0016	0.0016						
8/21/2008												
9/2/2008		5.82	5.82	0.53			2.01	2.01	0.5	0.5	0.07	0.07
9/3/2008												
9/4/2008					0.0031	0.0031						
9/10/2008												
9/15/2008												
10/1/2008					0.0015	0.0015						
10/6/2008												
10/14/2008		5.74	5.74	0.4			1.65	1.65	0.46	0.46	0.03	0.03
10/15/2008												
10/27/2008												
11/10/2008					0.0016	0.0016						
11/13/2008		5.35	5.35	0.47			2.67	2.67	0.47	0.47	0.06	0.06
11/18/2008												
12/5/2008												
12/8/2008		7.07	7.07	0.51			1.63	1.63	0.51	0.51	0.06	0.06

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR		6		7	8		9		10		11	
	Total Chromium	Copper	1/2 Copper	Lead	Mercury	1/2 Mercury	Nickel	1/2 Nickel	Selenium	1/2 Selenium	Silver	1/2 Silver
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	
12/9/2008												
MEC		7.07		6	0.03		5.19		0.8		0.18	
MAXIMUM		7.07		6	0.03		5.19		0.8		0.18	
MINIMUM		2.5		0.4	0.00056		0.23		0.2		0.03	
DETECTS		51		55	46		46		53		27	
COUNT		55		55	87		55		55		55	
% NONDETECT		7.27273		0	47.1264		16.364		3.6364		50.90909	
ST DEVIATION			0.9952	1.04263		0.00849		2.7893		0.1138056		0.1611343
AVERAGE			4.74436	1.54218		0.01176		2.4935		0.5076364		0.1092727
CV			0.20977	0.67608		0.72228		1.1186		0.2241873		1.4746071
Default CV			0.2	0.7		0.7		1.1		0.2		1.5
ECA multipliers Table 1												
ECA Acute 99 multiplier			0.643	0.281		0.281		0.187		0.643		0.144
ECA Chronic99 multiplier			0.797	0.481		0.481		0.345		0.797		0.264
AMEL multiplier95			1.172	1.651		1.651		2.041		1.172		2.401
MDEL multiplier99			1.554	3.559		3.559		5.338		1.554		6.930
MDEL/AMEL Multiplier			1.326	2.156		2.156		2.615		1.326		2.887
Bold = Detect												
Blue = DNQ												
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present												

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
8/1/2004														
8/9/2004	<1	80												
8/9/2004														
8/10/2004			2.2	2.2		<2	<0.5	0.25	0.2	0.2	5	0.9	0.9	6.35
8/18/2004														
9/1/2004														
9/13/2004		70												
9/13/2004														
9/14/2004			1.4	1.4										
10/1/2004														
10/4/2004		80												
10/4/2004														
10/5/2004			3.3	3.3			<0.5	0.25	0.5	0.5	9	3	3	12.75
11/1/2004		70												
11/1/2004														
11/2/2004			<5	2.5			<0.5	0.25	0.3	0.3	6	1	1	7.55
12/1/2004														
12/6/2004		110												
12/6/2004														
12/7/2004			4.4	4.4			<1	0.5	0.29	0.29	2.5	0.47	0.47	3.76
12/8/2004	<1	100	7	7		<2	<1	0.5	0.2	0.2	5	0.79	0.79	6.49
1/1/2005														
1/3/2005		50												
1/3/2005														
1/4/2005			2.5	2.5										
2/1/2005														
2/7/2005	<0.25	50												
2/7/2005														
2/8/2005			1.4	1.4		<2	<0.5	0.25	0.3	0.3	5	1	1	6.3
3/1/2005		50												
3/1/2005														
3/2/2005			2	2										
3/30/2005														
4/1/2005														
4/4/2005		60												
4/4/2005														
4/5/2005			2.5	2.5			<0.5	0.25	0.2	0.2	7	1	1	8.2
4/28/2005														
5/1/2005														
5/2/2005		50												
5/2/2005														
5/3/2005			2.4	2.4			<0.5	0.25	0.2	0.2	4	0.7	0.7	4.9
5/25/2005														
6/1/2005														
6/6/2005		60												
6/6/2005														

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
6/7/2005			1.2	1.2			<0.5	0.25	0.1	0.1	5	0.8	0.8	5.9
6/27/2005														
6/28/2005														
7/1/2005														
7/11/2005		60												
7/11/2005														
7/12/2005			<5	2.5			<1	0.5	<1	0.5	5.1	<1	0.5	5.1
7/26/2005														
8/1/2005														
8/2/2005	0.03	60												
8/3/2005			2	2		<2	<0.5	0.25	0.1	0.1	5	0.6	0.6	5.7
8/24/2005														
9/1/2005														
9/6/2005		60												
9/7/2005			<5	2.5			<0.5	0.25	0.2	0.2	5	0.8	0.8	6
9/28/2005														
10/1/2005														
10/11/2005		60												
10/12/2005			<5	2.5			<0.5	0.25	0.2	0.2	8	1	1	9.2
10/20/2005														
10/25/2005														
11/1/2005														
11/7/2005		60												
11/8/2005			1.3	1.3			<0.5	0.25	0.1	0.1	3	0.4	0.4	3.5
11/29/2005														
12/1/2005														
12/12/2005		70												
12/13/2005			2.6	2.6			<0.5	0.25	0.4	0.4	6	2	2	8.4
12/28/2005														
1/1/2006														
1/9/2006		53.3												
1/10/2006			4.1	4.1			<0.5	0.25	0.4	0.4	7	1	1	8.4
1/30/2006														
2/1/2006														
2/13/2006	<0.25	83												
2/14/2006			1.7	1.7		<2	<0.5	0.25	<0.5	0.25	4.3	1.2	1.2	5.5
3/1/2006														
3/6/2006		74												
3/7/2006			4.3	4.3			<0.5	0.25	0.3	0.3	8	2	2	10.3
3/30/2006														
4/1/2006														
4/11/2006		71.7												
4/12/2006			<5	2.5			<0.5	0.25	0.2	0.2	4	1	1	5.2
4/26/2006														
5/1/2006														
5/8/2006		69.9												
5/9/2006			1.9	1.9			<0.5	0.25	0.2	0.2	8	2	2	10.2
5/31/2006														

Other priority pollutants not listed were not detected in the effluent.

14/36
03/19/09

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
6/1/2006														
6/12/2006		71												
6/13/2006			1.1	1.1			<0.5	0.25	0.1	0.1	7.5	1.2	1.2	8.8
6/26/2006														
7/1/2006														
7/10/2006		66												
7/11/2006			<5	2.5			<0.5	0.25	0.2	0.2	7	2	2	9.2
7/26/2006														
8/1/2006	0.01	67.1												
8/2/2006					<2	<0.5	0.25		0.3	0.3	6	2	2	8.3
8/15/2006			1.2	1.2										
8/29/2006														
9/1/2006														
9/5/2006		66.5												
9/6/2006						<0.5	0.25		0.3	0.3	9	2	2	11.3
9/21/2006			<5	2.5										
9/27/2006														
10/1/2006														
10/9/2006		74.3												
10/10/2006			2.2	2.2			<0.5	0.25	0.3	0.3	8	2	2	10.3
10/24/2006														
11/1/2006			New test method											
11/7/2006			1.4	1.4										
11/13/2006		65.5												
11/14/2006						<0.5	0.25		0.3	0.3	9	2	2	11.3
11/21/2006														
12/1/2006														
12/7/2006			2.6	2.6										
12/14/2006		75.2				<0.5	0.25		0.3	0.3	10	2	2	12.3
12/28/2006														
1/1/2007														
1/8/2007		74.9												
1/9/2007														
1/10/2007			1.7	1.7										
1/23/2007														
2/1/2007														
2/8/2007			2.2	2.2										
2/12/2007	<0.25	68.2												
2/13/2007					<2	<0.5	0.25		1	1	18	6	6	25
2/27/2007														
3/1/2007														
3/7/2007			2	2										
3/12/2007		72.1												
3/27/2007														
4/1/2007														
4/3/2007			1.1	1.1										
4/9/2007		62.3												
4/10/2007						<0.5	0.25		0.3	0.3	5	2	2	7.3

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
4/25/2007														
5/1/2007														
5/14/2007		61.9												
5/15/2007							<0.5	0.25	0.6	0.6	8	3	3	11.6
5/21/2007			1.7	1.7										
5/30/2007		63.8	<5	2.5	<2	<0.5	0.25	0.4	0.4	8	1	1	1	9.4
5/30/2007	<0.25													
6/1/2007														
6/4/2007		74.1												
6/5/2007							0.3	0.3	3	3	16	10	10	29.3
6/22/2007			<5	2.5										
6/26/2007														
7/1/2007														
7/9/2007		59.6	1.4	1.4										
7/10/2007														
7/30/2007														
8/1/2007														
8/3/2007			<5	2.5										
8/13/2007	<0.25	67				<2	<0.5	0.25	0.2	0.2	5	1	1	6.2
8/14/2007														
8/29/2007														
9/1/2007														
9/10/2007		69.2	1.4	1.4										
9/11/2007														
9/25/2007														
10/1/2007														
10/4/2007			3.1	3.1										
10/9/2007		65.4												
10/10/2007							0.6	0.6	5	5	18	13	13	36.6
10/30/2007														
11/1/2007														
11/13/2007		71.2												
11/14/2007							0.4	0.4	2	2	13	6	6	21.4
11/19/2007			<5	2.5										
11/29/2007														
12/1/2007														
12/4/2007														
12/10/2007		67.1												
12/11/2007							<0.5	0.25	1	1	14	6	6	21
12/21/2007			1.9	1.9										
1/7/2008														
1/10/2008			2.5	2.5										
1/14/2008		76.6												
1/14/2008														
1/15/2008														
2/1/2008														
2/4/2008	<0.25	69												
2/4/2008														
2/5/2008						<2	0.3	0.3	2	2	15	8	8	25.3

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
2/12/2008			<5	2.5										
3/1/2008														
3/5/2008														
3/10/2008		72.6												
3/10/2008														
3/11/2008														
3/12/2008			2	2										
4/1/2008														
4/7/2008		73.1												
4/7/2008														
4/8/2008							0.2	0.2	2	2	18	9	9	29.2
4/9/2008														
4/18/2008			2.9	2.9										
4/23/2008														
5/5/2008														
5/7/2008														
5/9/2008			2.2	2.2										
5/12/2008		61.7												
5/12/2008														
5/13/2008							0.2	0.2	0.7	0.7	7	2	2	9.9
6/3/2008														
6/9/2008		57.2												
6/9/2008														
6/10/2008							0.8	0.8	6	6	25	16	16	47.8
6/19/2008			1.6	1.6										
6/27/2008														
7/2/2008														
7/9/2008		61.4												
7/9/2008														
7/10/2008														
7/17/2008			2	2										
8/11/2008	<0.25	53												
8/12/2008						<2	0.4	0.4	4	4	21	12	12	37.4
8/13/2008														
8/21/2008			1.8	1.8										
9/2/2008		59												
9/3/2008														
9/4/2008														
9/10/2008			1.2	1.2										
9/15/2008														
10/1/2008														
10/6/2008			1.9	1.9										
10/14/2008		53												
10/15/2008							0.4	0.4	3	3	19	11	11	33.4
10/27/2008														
11/10/2008														
11/13/2008		58					0.3	0.3	3	3	24	13	13	40.3
11/18/2008			2.4	2.4										
12/5/2008			2.9	2.9										
12/8/2008		58												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	12	13	14		16	17	20		23		26	27		
	Thallium	Zinc	Cyanide	1/2 Cyanide	2,3,7,8-TCDD	Acrolein	Bromoform	1/2 Bromoform	Chlorodibromomethane	1/2 Chlorodibromomethane	Chloroform	Bromodichloromethane	1/2 Bromodichloromethane	Total Trihalomethanes
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
12/9/2008							0.3	0.3	3	3	21	11	11	35.3
MEC	0.03	110	3.1		0	<2	0.8		6		25	16		47.8
MAXIMUM	0.03	110	3.1		0	0	0.8		6		25	16		47.8
MINIMUM	0.01	50	1.1		0	0	0.2		0.1		2.5	0.4		3.5
DETECTS	2	55	22		0	0	11		42		44	43		44
COUNT	11	55	27		0	11	44		44		44	44		44
% NONDETECT	81.8182	0	18.5185		#DIV/0!	100	75		4.545455		0	2.273		0
ST DEVIATION	0.01414	11.12		0.54231	#DIV/0!	#DIV/0!		0.117		1.413771	6.036		4.283	11.7
AVERAGE	0.02	66.67		2.08889	#DIV/0!	#DIV/0!		0.3		1.003182	9.623		3.758	14.49
CV	0.70711	0.167		0.25962	#DIV/0!	#DIV/0!		0.389		1.409287	0.627		1.14	0.807
Default CV	0.6	0.2		0.4		0.6		0.4		1.4	0.6		1.1	0.8
ECA multipliers Table 1														
ECA Acute 99 multiplier	0.321	0.643		0.440	1.000	0.321	0.440		0.153	0.321	1.000	0.187	0.249	
ECA Chronic99 multiplier	0.527	0.797		0.643	1.000	0.527	0.643		0.281	0.527	1.000	0.345	0.440	
AMEL multiplier95	1.552	1.172		1.358	1.000	1.552	1.358		2.315	1.552	1.000	2.041	1.750	
MDEL multiplier99	3.114	1.554		2.275	1.000	3.114	2.275		6.556	3.114	1.000	5.338	4.009	
MDEL/AMEL Multiplier	2.006	1.326		1.675	1.000	2.006	1.675		2.832	2.006	1.000	2.615	2.291	
Bold = Detect														
Blue = DNQ														
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present														

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
8/1/2004													
8/9/2004								<10	<0.02	<0.02	<2	<0.02	
8/9/2004													<2
8/10/2004	<0.5	0.07	0.07		<0.5	0.09	0.09						
8/18/2004													
9/1/2004													
9/13/2004										<0.02	<2		
9/13/2004													
9/14/2004					<0.5								
10/1/2004													
10/4/2004								0.41		<0.02	<2		
10/4/2004													
10/5/2004	0.08	0.06	0.06		<0.5	<0.5	0.25						
11/1/2004									<0.02	<0.02	1.1	<0.02	
11/1/2004					<0.5								
11/2/2004		0.06	0.06										
12/1/2004													
12/6/2004								0.33		<0.02	<2		
12/6/2004													
12/7/2004	<1	<2	1		<0.5	<0.5	0.25						
12/8/2004	<1	<2	1		<0.5	<0.5	0.25	<10	<0.02	<0.02	<2	<0.02	<2
1/1/2005													
1/3/2005													
1/3/2005										<0.02	<2		
1/4/2005					<0.5								
2/1/2005													
2/7/2005								0.31		<0.02	<2		<2
2/7/2005									<0.02			<0.02	
2/8/2005	<0.5	0.08	0.08		<0.5	0.2	0.2						
3/1/2005										<0.02	<2		
3/1/2005													
3/2/2005					<0.5								
3/30/2005													
4/1/2005													
4/4/2005								<10		<0.02	<2		
4/4/2005													
4/5/2005	<0.5	0.1	0.1		<0.5	<0.5	0.25						
4/28/2005													
5/1/2005													
5/2/2005									<0.02	<0.02	<2		<2
5/2/2005												<0.02	
5/3/2005		0.2	0.2		<0.5	0.1	0.1						
5/25/2005													
6/1/2005													
6/6/2005								<10		<0.02	<2		<2
6/6/2005												<0.02	

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
6/7/2005	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
6/27/2005													
6/28/2005													
7/1/2005													
7/11/2005								<10		<0.02	<2	<0.02	<2
7/11/2005													
7/12/2005		<10	5	<1	<1		0.5						
7/26/2005													
8/1/2005													
8/2/2005									<0.02	<0.02		<0.02	
8/3/2005	<0.5	0.5	0.5	<0.5	<0.5	0.25							
8/24/2005													
9/1/2005													
9/6/2005								<10		<0.02	<2	<0.02	<2
9/7/2005		<0.5	0.25	<0.5	<0.5	0.25							
9/28/2005													
10/1/2005													
10/11/2005								<10		<0.02	<2	<0.02	<2
10/12/2005	0.1	0.09	0.09	<0.5	<0.5	0.25							
10/20/2005								<10		<0.02	<2	<0.02	<2
10/25/2005													
11/1/2005													
11/7/2005									<0.02	<0.02	<2	<0.02	<2
11/8/2005		0.09	0.09	<0.5	<0.5	0.25							
11/29/2005													
12/1/2005													
12/12/2005								<10		<0.02	<2	<0.02	<2
12/13/2005	<0.5	0.05	0.05	<0.5	<0.5	0.25							
12/28/2005													
1/1/2006													
1/9/2006								<10		<0.02	<2	<0.02	<2
1/10/2006	<0.5	0.25		<0.5	<0.5	0.25							
1/30/2006													
2/1/2006													
2/13/2006								<10	<0.02	<0.02	<2	<0.02	<2
2/14/2006	<0.5	<0.5	0.25	<0.5	<0.5	0.25							
3/1/2006													
3/6/2006								<10		<0.02	5.3	<0.02	<2
3/7/2006		0.2	0.2	<0.5	0.09	0.09							
3/30/2006													
4/1/2006													
4/11/2006								<10		<0.02	<2	<0.02	<2
4/12/2006	0.08	<0.5	0.25	<0.5	0.09	0.09							
4/26/2006													
5/1/2006													
5/8/2006									<0.02	<0.02	<2	<0.02	<2
5/9/2006		0.05	0.05	<0.5	0.07	0.07							
5/31/2006													

Other priority pollutants not listed were not detected in the effluent.

20/36
03/19/09

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
6/1/2006													
6/12/2006								<10		<0.02	<2	<0.02	<2
6/13/2006	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
6/26/2006													
7/1/2006													
7/10/2006								<10		<0.02	<2	<0.02	<2
7/11/2006		0.08	0.08		<0.5	<0.5	0.25						
7/26/2006													
8/1/2006								<10	<0.02	<0.02	<2	<0.02	<2
8/2/2006	<0.5	0.08	0.08		<0.5	0.08	0.08						
8/15/2006													
8/29/2006													
9/1/2006													
9/5/2006								<10		<0.02	<2	<0.02	<2
9/6/2006		0.09	0.09		<0.5	<0.5	0.25						
9/21/2006													
9/27/2006													
10/1/2006													
10/9/2006								<10		<0.02		<0.02	<2
10/10/2006	<0.5	0.09	0.09		<0.5	<0.5	0.25				<2		
10/24/2006													
11/1/2006													
11/7/2006													
11/13/2006									<0.02	<0.02	<2	<0.02	<2
11/14/2006		0.05	0.05		<0.5	0.2	0.2						
11/21/2006													
12/1/2006													
12/7/2006													
12/14/2006	<0.5	0.08	0.08		<0.5	0.1	0.1	<10		<0.02	<2	<0.02	<2
12/28/2006													
1/1/2007													
1/8/2007										<0.02	<2		
1/9/2007					<0.5								
1/10/2007													
1/23/2007													
2/1/2007													
2/8/2007													
2/12/2007								<10	<0.02	<0.02	<2	<0.02	<2
2/13/2007	<0.5	0.08	0.08		<0.5	<0.5	0.25						
2/27/2007													
3/1/2007													
3/7/2007													
3/12/2007										<0.02	<2		
3/27/2007													
4/1/2007													
4/3/2007													
4/9/2007								<10		<0.02	<2		
4/10/2007	<0.5	0.06	0.06		<0.5	<0.5	0.25						

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
4/25/2007													
5/1/2007													
5/14/2007									<0.02	<0.02	<2	<0.02	
5/15/2007		0.1	0.1	<0.5									
5/21/2007													
5/30/2007		0.08	0.08	<0.5					<0.02	<0.02	<2	<0.02	
5/30/2007	<0.5				<0.5	0.25	<10						<2
6/1/2007													
6/4/2007							<10		<0.02	<2			
6/5/2007	0.1	0.08	0.08	<0.5	<0.5	0.25							
6/22/2007													
6/26/2007													
7/1/2007													
7/9/2007									<0.02	<2			
7/10/2007				<0.5									
7/30/2007													
8/1/2007													
8/3/2007													
8/13/2007							<10	<0.02	<0.02	<2	<0.02		
8/14/2007	<0.5	0.07	0.07	<0.5	<0.5	0.25							
8/29/2007													
9/1/2007													
9/10/2007									<0.02	<2			
9/11/2007				<0.5									
9/25/2007													
10/1/2007													
10/4/2007													
10/9/2007							<10		<0.02	<2			
10/10/2007	<0.5	0.2	0.2	<0.5	<0.5	0.25							
10/30/2007													
11/1/2007													
11/13/2007								<0.02	<0.02	<2	<0.02		
11/14/2007	<0.5	0.25		<0.5									
11/19/2007													
11/29/2007													
12/1/2007													
12/4/2007													
12/10/2007							<10		<0.02	<2			
12/11/2007	<0.5	<0.5	0.25	<0.5	<0.5	0.25							
12/21/2007													
1/7/2008													
1/10/2008													
1/14/2008									<0.02	<2			
1/14/2008													
1/15/2008				<0.5									
2/1/2008													
2/4/2008								0.4	<0.02	<0.02		<0.02	
2/4/2008											<2		
2/5/2008	<0.5	<0.5	0.25		0.2	<0.5	0.25						

Other priority pollutants not listed were not detected in the effluent.

22/36
03/19/09

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
2/12/2008													
3/1/2008													
3/5/2008													
3/10/2008										<0.02	0.33		
3/10/2008													
3/11/2008					<0.5								
3/12/2008													
4/1/2008													
4/7/2008								<10		<0.02	0.5		
4/7/2008													
4/8/2008	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
4/9/2008													
4/18/2008													
4/23/2008													
5/5/2008													
5/7/2008													
5/9/2008													
5/12/2008									0.021	0.015	<2	0.016	
5/12/2008													
5/13/2008		<0.5	0.25		<0.5								
6/3/2008													
6/9/2008								<10		0.037	0.32		
6/9/2008													
6/10/2008	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
6/19/2008													
6/27/2008													
7/2/2008													
7/9/2008										<0.02	<2		
7/9/2008													
7/10/2008					<0.5								
7/17/2008													
8/11/2008								<10	<0.02	<0.02	<2	<0.02	
8/12/2008	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
8/13/2008													
8/21/2008													
9/2/2008										<0.02	<2		
9/3/2008					<0.5								
9/4/2008													
9/10/2008													
9/15/2008													
10/1/2008													
10/6/2008													
10/14/2008								<10		<0.02	<2		
10/15/2008	<0.5	<0.5	0.25		<0.5	<0.5	0.25						
10/27/2008													
11/10/2008													
11/13/2008		<0.5	0.25		<0.5				<0.02	<0.02	<2	<0.02	
11/18/2008													
12/5/2008													
12/8/2008								<10		<0.02	<2		

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	35	36		37	38	39		55	62	64	68	74	75
	Chloromethane (Methyl chloride)	Methylene chloride	1/2 methylene chloride	1,1,2,2-Tetrachloroethane	Tetrachloroethylene	Toluene	1/2 Toluene	2,4,6-Trichlorophenol	Benzo(b)fluoranthene	Benzo(k)fluoranthene	Bis(2-ethylhexyl)phthalate [aka Diethylhexyl Phthalate]	Dibenzo(a,h)anthracene	1,2-Dichlorobenzene
	µg/L	µg/L		µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
12/9/2008	0.2	<0.5	0.25		<0.5	<0.5	0.25						
MEC	0.2	0.5		<0.5	0.2	0.2		0.41	0.021	0.037	5.3	0.016	0
MAXIMUM	0.2	0.5		<1	0.2	0.2		0.41	0.021	0.037	5.3	0.016	0
MINIMUM	0.08	0.05		<0.5	0.2	0.07		0.31	0.021	0.015	0.32	0.016	0
DETECTS	5	25		0	1	9		4	1	2	5	1	0
COUNT	29	44		0	54	39		35	20	56	55	34	25
% NONDETECT	82.759	43.18182		#DIV/0!	98.148	77		88.57143	95	96.428571	90.90909	97.059	100
ST DEVIATION	0.0502		0.750749	#DIV/0!	#DIV/0!		0.0771	0.049917	#DIV/0!	0.0155563	2.142475	#DIV/0!	#DIV/0!
AVERAGE	0.112		0.311136	#DIV/0!	0.2		0.2249	0.3625	0.021	0.026	1.51	0.016	#DIV/0!
CV	0.4482		2.412926	#DIV/0!	#DIV/0!		0.3429	0.137701	#DIV/0!	0.5983211	1.418858	#DIV/0!	#DIV/0!
Default CV	0.6		2.4		0.6		0.3	0.6	0.6	0.6	0.6	0.6	0.6
ECA multipliers Table 1													
ECA Acute 99 multiplier	0.321		0.104	1.000	0.321		0.527	0.321	0.321	0.321	0.321	0.321	0.321
ECA Chronic99 multiplier	0.527		0.174	1.000	0.527		0.715	0.527	0.527	0.527	0.527	0.527	0.527
AMEL multiplier95	1.552		3.027	1.000	1.552		1.264	1.552	1.552	1.552	1.552	1.552	1.552
MDEL multiplier99	3.114		9.583	1.000	3.114		1.896	3.114	3.114	3.114	3.114	3.114	3.114
MDEL/AMEL Multiplier	2.006		3.166	1.000	2.006		1.500	2.006	2.006	2.006	2.006	2.006	2.006
Bold = Detect													
Blue = DNQ													
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present													

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105												
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)											
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L											
8/1/2004					<0.001	0.0005											
8/9/2004	<1	<2	<5	2.5													
8/9/2004			0.76	0.76													
8/10/2004																	
8/18/2004	<1																
9/1/2004					<0.001	0.0005											
9/13/2004			<5	2.5													
9/13/2004	<1		0.58	0.58													
9/14/2004	<1																
10/1/2004					0.01	0.01											
10/4/2004	<1		<5	2.5													
10/4/2004			0.64	0.64													
10/5/2004	<1																
11/1/2004	<1		<5	2.5	0.007	0.007											
11/1/2004	<1		0.49	0.49													
11/2/2004	<1																
12/1/2004					0.006	0.006											
12/6/2004	<1		<5	2.5													
12/6/2004			0.48	0.48													
12/7/2004	<1																
12/8/2004	<1	<2	<5	2.5													
1/1/2005					0.002	0.002											
1/3/2005	<1		<5	2.5													
1/3/2005			0.43	0.43													
1/4/2005																	
2/1/2005					0.006	0.006											
2/7/2005	<1	<2	<5	2.5													
2/7/2005			0.55	0.55													
2/8/2005																	
3/1/2005			<5	2.5	0.006	0.006											
3/1/2005			0.51	0.51													
3/2/2005																	
3/30/2005																	
4/1/2005					<0.0007	0.00035											
4/4/2005			<5	2.5													
4/4/2005			0.26	0.26													
4/5/2005																	
4/28/2005																	
5/1/2005					0.005	0.005											
5/2/2005			<5	2.5													
5/2/2005			0.55	0.55													
5/3/2005																	
5/25/2005																	
6/1/2005					<0.0007	0.00035											
6/6/2005			0.35	0.35													
6/6/2005			<5	2.5													

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105											
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)										
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L										
6/7/2005																
6/27/2005			0.39	0.39												
6/28/2005																
7/1/2005					<0.0007	0.00035										
7/11/2005		<5		2.5												
7/11/2005			0.53	0.53												
7/12/2005																
7/26/2005																
8/1/2005					<0.0007	0.00035										
8/2/2005			0.27	0.27												
8/3/2005																
8/24/2005																
9/1/2005					<0.0007	0.00035										
9/6/2005		<5		2.5												
9/7/2005																
9/28/2005																
10/1/2005					<0.0007	0.00035										
10/11/2005	<1		<5	2.5												
10/12/2005																
10/20/2005	<1	0.28	<5	2.5												
10/25/2005																
11/1/2005					<0.0007	0.00035										
11/7/2005	<1		<5	2.5												
11/8/2005																
11/29/2005																
12/1/2005					<0.0007	0.00035										
12/12/2005	<1		<5	2.5												
12/13/2005																
12/28/2005																
1/1/2006					<0.001	0.0005										
1/9/2006	<1		<5	2.5												
1/10/2006																
1/30/2006																
2/1/2006					<0.001	0.0005										
2/13/2006	<1	<2	<5	2.5												
2/14/2006																
3/1/2006					<0.001	0.0005										
3/6/2006	<1		<5	2.5												
3/7/2006																
3/30/2006																
4/1/2006					<0.001	0.0005										
4/11/2006	<1		<5	2.5												
4/12/2006																
4/26/2006																
5/1/2006					<0.001	0.0005										
5/8/2006	<1		<5	2.5												
5/9/2006																
5/31/2006																

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105												
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)											
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L											
6/1/2006					<0.001	0.005											
6/12/2006	<1		<5	2.5													
6/13/2006																	
6/26/2006																	
7/1/2006					<0.001	0.0005											
7/10/2006	<1		<5	2.5													
7/11/2006																	
7/26/2006																	
8/1/2006	<1	0.6	<5	2.5	<0.001	0.0005											
8/2/2006																	
8/15/2006																	
8/29/2006																	
9/1/2006					<0.001	0.0005											
9/5/2006	<1		<5	2.5													
9/6/2006																	
9/21/2006																	
9/27/2006																	
10/1/2006					0.02	0.02											
10/9/2006	<1		0.6	0.6													
10/10/2006																	
10/24/2006																	
11/1/2006					0.007	0.007											
11/7/2006																	
11/13/2006	<1		<5	2.5													
11/14/2006																	
11/21/2006																	
12/1/2006					<0.001	0.0005											
12/7/2006																	
12/14/2006	<1		<5	2.5													
12/28/2006																	
1/1/2007					0.002	0.002											
1/8/2007	<1		<5	2.5													
1/9/2007																	
1/10/2007																	
1/23/2007																	
2/1/2007					0.003	0.003											
2/8/2007																	
2/12/2007	<1	<2	<5	2.5													
2/13/2007																	
2/27/2007																	
3/1/2007					0.008	0.008											
3/7/2007																	
3/12/2007	<1		<5	2.5													
3/27/2007																	
4/1/2007					0.004	0.004											
4/3/2007																	
4/9/2007	<1		<5	2.5													
4/10/2007																	

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105											
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)										
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L										
4/25/2007																
5/1/2007					<0.001	0.0005										
5/14/2007			<5	2.5												
5/15/2007																
5/21/2007																
5/30/2007	<1	<2														
5/30/2007			<5	2.5												
6/1/2007					0.01	0.01										
6/4/2007			<5	2.5												
6/5/2007																
6/22/2007																
6/26/2007																
7/1/2007					<0.001	0.0005										
7/9/2007			<5	2.5												
7/10/2007																
7/30/2007																
8/1/2007					<0.001	0.0005										
8/3/2007																
8/13/2007		<2	<5	2.5												
8/14/2007																
8/29/2007																
9/1/2007					<0.001	0.0005										
9/10/2007			<5	2.5												
9/11/2007																
9/25/2007																
10/1/2007					0.005	0.005										
10/4/2007																
10/9/2007			<5	2.5												
10/10/2007																
10/30/2007																
11/1/2007					0.003	0.003										
11/13/2007			<5	2.5												
11/14/2007																
11/19/2007																
11/29/2007																
12/1/2007					<0.001	0.0005										
12/4/2007																
12/10/2007			<5	2.5												
12/11/2007																
12/21/2007																
1/7/2008																
1/10/2008																
1/14/2008			<5	2.5												
1/14/2008			0.34	0.34												
1/15/2008	<0.48				0.004	0.004										
2/1/2008																
2/4/2008		<2	<5	2.5												
2/4/2008			0.49	0.49												
2/5/2008	0.4				<0.001	0.0005										

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105											
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)										
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L										
2/12/2008																
3/1/2008	<0.37															
3/5/2008																
3/10/2008			<5	2.5												
3/10/2008			0.44	0.44												
3/11/2008					<0.001	0.0005										
3/12/2008																
4/1/2008																
4/7/2008			<5	2.5												
4/7/2008			0.49	0.49												
4/8/2008	<0.37				<0.001	<0.001										
4/9/2008																
4/18/2008																
4/23/2008																
5/5/2008																
5/7/2008																
5/9/2008																
5/12/2008			<5	2.5												
5/12/2008			0.69	0.69												
5/13/2008	0.3				0.004	0.004										
6/3/2008																
6/9/2008			<5	2.5												
6/9/2008			0.78	0.78												
6/10/2008	<0.37				<0.001	0.0005										
6/19/2008																
6/27/2008																
7/2/2008																
7/9/2008			<5	2.5												
7/9/2008			0.9	0.9												
7/10/2008	<0.37				0.01	0.01										
7/17/2008																
8/11/2008		<2	0.3	0.3												
8/12/2008	<0.37				<0.001	0.0005										
8/13/2008																
8/21/2008																
9/2/2008			0.26	0.26												
9/3/2008	<0.37				<0.001	0.0005										
9/4/2008																
9/10/2008																
9/15/2008																
10/1/2008	<0.37															
10/6/2008																
10/14/2008			0.13	0.13												
10/15/2008					0.008	0.008										
10/27/2008																
11/10/2008	<0.32															
11/13/2008			0.094	0.094	<0.001	0.0005										
11/18/2008																
12/5/2008																
12/8/2008			0.082	0.082												

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR	77	79	96		105												
	P-Dichlorobenzene (aka 1,4-Dichlorobenzene)	Diethyl Phthalate	N-nitrosodimethylamine	1/2 N-nitrosodimethylamine	Lindane (Gamma-BHC)	1/2 Lindane (Gamma-BHC)											
	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L											
12/9/2008																	
MEC	0.4	0.6	0.9		0.02												
MAXIMUM	0.4	0.6	0.9		0.02												
MINIMUM	0.3	0.28	0.082		0.002												
DETECTS	2	2	27		20												
COUNT	46	11	76		52												
% NONDETECT	95.6522	81.82	64.4737		61.53846												
ST DEVIATION	0.07071	0.226		0.990799		0.003887											
AVERAGE	0.35	0.44		1.774816		0.002918											
CV	0.20203	0.514		0.558255		1.332146											
Default CV	0.6	0.6		0.6		1.3											
ECA multipliers Table 1																	
ECA Acute 99 multiplier	0.321	0.321		0.321		0.162											
ECA Chronic99 multiplier	0.527	0.527		0.527		0.300											
AMEL multiplier95	1.552	1.552		1.552		2.226											
MDEL multiplier99	3.114	3.114		3.114		6.166											
MDEL/AMEL Multiplier	2.006	2.006		2.006		2.770											
Bold = Detect																	
Blue = DNQ																	
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present																	

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR															
8/1/2004															
8/9/2004															
8/9/2004															
8/10/2004															
8/18/2004															
9/1/2004															
9/13/2004															
9/13/2004															
9/14/2004															
10/1/2004															
10/4/2004															
10/4/2004															
10/5/2004															
11/1/2004															
11/1/2004															
11/2/2004															
12/1/2004															
12/6/2004															
12/6/2004															
12/7/2004															
12/8/2004															
1/1/2005															
1/3/2005															
1/3/2005															
1/4/2005															
2/1/2005															
2/7/2005															
2/7/2005															
2/8/2005															
3/1/2005															
3/1/2005															
3/2/2005															
3/30/2005															
4/1/2005															
4/4/2005															
4/4/2005															
4/5/2005															
4/28/2005															
5/1/2005															
5/2/2005															
5/2/2005															
5/3/2005															
5/25/2005															
6/1/2005															
6/6/2005															
6/6/2005															

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR															
6/7/2005															
6/27/2005															
6/28/2005															
7/1/2005															
7/11/2005															
7/11/2005															
7/12/2005															
7/26/2005															
8/1/2005															
8/2/2005															
8/3/2005															
8/24/2005															
9/1/2005															
9/6/2005															
9/7/2005															
9/28/2005															
10/1/2005															
10/11/2005															
10/12/2005															
10/20/2005															
10/25/2005															
11/1/2005															
11/7/2005															
11/8/2005															
11/29/2005															
12/1/2005															
12/12/2005															
12/13/2005															
12/28/2005															
1/1/2006															
1/9/2006															
1/10/2006															
1/30/2006															
2/1/2006															
2/13/2006															
2/14/2006															
3/1/2006															
3/6/2006															
3/7/2006															
3/30/2006															
4/1/2006															
4/11/2006															
4/12/2006															
4/26/2006															
5/1/2006															
5/8/2006															
5/9/2006															
5/31/2006															

Other priority pollutants not listed were not detected in the effluent.

Table D1

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR														
6/1/2006														
6/12/2006														
6/13/2006														
6/26/2006														
7/1/2006														
7/10/2006														
7/11/2006														
7/26/2006														
8/1/2006														
8/2/2006														
8/15/2006														
8/29/2006														
9/1/2006														
9/5/2006														
9/6/2006														
9/21/2006														
9/27/2006														
10/1/2006														
10/9/2006														
10/10/2006														
10/24/2006														
11/1/2006														
11/7/2006														
11/13/2006														
11/14/2006														
11/21/2006														
12/1/2006														
12/7/2006														
12/14/2006														
12/28/2006														
1/1/2007														
1/8/2007														
1/9/2007														
1/10/2007														
1/23/2007														
2/1/2007														
2/8/2007														
2/12/2007														
2/13/2007														
2/27/2007														
3/1/2007														
3/7/2007														
3/12/2007														
3/27/2007														
4/1/2007														
4/3/2007														
4/9/2007														
4/10/2007														

Other priority pollutants not listed were not detected in the effluent.

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

Other priority pollutants not listed were not detected in the effluent.

JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

Other priority pollutants not listed were not detected in the effluent.

Table D1
JOS - Pomona WRP
Effluent Data
(CA0053619, CI#0755)

CTR															
12/9/2008															
MEC															
MAXIMUM															
MINIMUM															
DETECTS															
COUNT															
% NONDETECT															
ST DEVIATION															
AVERAGE															
CV															
Default CV															
ECA multipliers Table 1															
ECA Acute 99 multiplier															
ECA Chronic99 multiplier															
AMEL multiplier95															
MDEL multiplier99															
MDEL/AMEL Multiplier															
Bold = Detect															
Blue = DNQ															
Red = Excluded data prior to Nov. 2006, different Test Method used from Nov.2006 to present															