

Attachment L
Ventura Water Reclamation Facility
Non-priority Pollutants Effluent RPA
(CA0053651, CI-1822)

CONSTITUENT	CV										REASONABLE POTENTIAL				
	Units	Number of Samples	Maximum Observed Effluent Concentration*	Multiplier	Projected Maximum Effluent Concentration (99/99)	Dilution Ratio	Background Concentration	Projected Maximum Receiving Water Result	Water Quality Objectives	BU - Beneficial use protection NC-Human noncarcinogen AP-Aquatic life protection					
Ammonia Nitrogen Nitrate + Nitrite as Nitrogen Nitrite Nitrogen Nitrate Nitrogen MBAS Oil and Grease Acute Toxicity (Single Test) Chronic Toxicity (Ceriodaphnia Survival) Chronic Toxicity (Ceriodaphnia Reproduction) Chronic Toxicity (Fathead Survival) Chronic Toxicity (Fathead Growth) Chronic Toxicity (Selenastrum Growth)	mg/L	47	3.600	0.577753	1.72	6.18		6.18	0.045	AP	YES				
	mg/L	47	18.8	0.164874	1.18	22.17	0	22.17	10	BU	YES				
	mg/L	47	0.215	0.010922	1.01	0.22	0	0.22	1	BU	NO				
	mg/L	47	18.6	0.167173	1.18	21.98	0	21.98	45	BU	NO				
	mg/L	46	0.85	0.962725	2.28	1.94	0	1.94	0.5	BU	YES				
	mg/L	47	2	0.534381	1.66	3.31	0	3.31	10	BU	NO				
	TUa	4	100	0	1.00	100.00	0	100.00	100	AP	NO				
	TUa	10	1	0	1.00	1.00	0	1.00	1	AP	NO				
	TUa	10	1.1	0.231529	1.58	1.73	0	1.73	1	AP	YES				
	TUa	9	1	0	1.00	1.00	0	1.00	1	AP	NO				
	TUa	9	1	0	1.00	1.00	0	1.00	1	AP	NO				
	TUa	47	5.56	0.571014	1.71	9.49	0	9.49	1	AP	YES				