Bill Jennings

California Sportfishing Protection Alliance

3536 Rainier Avenue

Stockton, CA 95204

Tel: 209-464-5067

Fax: 209-464-1028

E-mail: deltakeep@aol.com

Mike Jackson

Law Office of Mike Jackson

P.O. Box 207

429 W. Main Street

Quincy, CA 95971

Tel: 530-283-1007

Fax: 530-283-0712

E-mail: mjatty@sbcglobal.net

Andrew Packard

Law Office of Andrew Packard

319 Pleasant Street

Petaluma, CA 94952

Tel: 707-763-7227

Fax: 707-763-9227

E-mail: andrew@packardlawoffices.com

For Petitioner California Sportfishing Protection Alliance

BEFORE THE STATE WATER RESOURCES CONTROL BOARD

In the Matter of Waste Discharge Requirements	_))
For City of Portola Wastewater Treatment Plant;))
California Regional Water Quality Control Board)	PETITION FOR REVIEW
- Central Valley Region Order No. R5-2009-0093))
NPDES No. CA0077844	_)	<u> </u>

Pursuant to Section 13320 of California Water Code and Section 2050 of Title 23 of the California Code of Regulations (CCR), California Sportfishing Protection Alliance ("CSPA" or "petitioner") petitions the State Water Resources Control Board (State Board) to review and vacate the final decision of the California Regional Water Quality Control Board for the Central Valley Region ("Regional Board") in adopting Waste Discharge Requirements (NPDES No.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 2 of 28.

CA0077844) for City of Portola Wastewater Treatment Plant, on 8 October 2009. See Order No. R5-2009-0093. The issues raised in this petition were raised in timely written comments.

1. NAME AND ADDRESS OF THE PETITIONERS:

California Sportfishing Protection Alliance 3536 Rainier Avenue Stockton, California 95204 Attention: Bill Jennings, Executive Director

2. THE SPECIFIC ACTION OR INACTION OF THE REGIONAL BOARD WHICH THE STATE BOARD IS REQUESTED TO REVIEW AND A COPY OF ANY ORDER OR RESOLUTION OF THE REGIONAL BOARD WHICH IS REFERRED TO IN THE PETITION:

Petitioner seeks review of Order No. R5-2009-0093, Waste Discharge Requirements (NPDES No. CA0077844) for the City of Portola Wastewater Treatment Plant. A copy of the adopted Order is attached as Attachment No. 1.

3. THE DATE ON WHICH THE REGIONAL BOARD ACTED OR REFUSED TO ACT OR ON WHICH THE REGIONAL BOARD WAS REQUESTED TO ACT:

8 October 2009

4. A FULL AND COMPLETE STATEMENT OF THE REASONS THE ACTION OR FAILURE TO ACT WAS INAPPROPRIATE OR IMPROPER:

CSPA submitted detailed comment letters on 13 May 2009 and 30 September 2009. Those letters and the following comments set forth in detail the reasons and points and authorities why CSPA believes the Order fails to comport with statutory and regulatory requirements. The specific reasons the adopted Orders are improper are:

A. The Permit contains an effluent Limitation for percent removal of BOD contrary to Federal Regulations 40 CFR 133.103 (Secondary Treatment Standards) and 40 CFR 122.44 (l)(1) (Antibacksliding) and fails to contain the basis for permit limitations in the Fact Sheet as required by 40 CFR 124.8.

The Permit, page F-6, states that:

"BOD percentage Removal- The discharger has experienced problems meeting the percentage removal effluent limitations for BOD. The 85 percent BOD removal

requirement was not met twice in 2004 (although the BOD values are suspect due to the potential laboratory error noted above), three times in 2005 and four times in 2006. For the last two discharge seasons, the Discharger has met the requirement for BOD percentage removal. Removal percentages during months that requirements were not met were generally around 80 percent, and there have been no violations of effluent BOD concentration limitations. The Discharger performed extensive work on their collection system in the late 1990s to reduce infiltration/inflow (I/I) in response to Cease and Desist Order No. 93-068.

In part, the problem of effluent percentage BOD removals is also due to the fact that discharge occurs only during months in which I/I is more likely to dilute the influent, but the discharge consists of wastewater that has been received both during dry (low dilution) and wet (high dilution) months. Another situation that is contributing to the problem is the Discharger's receipt of septage. Septage is very high in BOD and total suspended solids. Although septage is discharged to the Facility, its pollutant contribution has not been taken into account when assessing influent pollutant loads and pollutant removal. This Order requires the Discharger to obtain monthly samples of septage for BOD and TSS analysis, and allows the Discharger to take into account the contribution of septage to the influent BOD and TSS load when calculating percentage removals. The Order also requires that the Discharger perform a study to determine if the amount of septage being accepted may be interfering with the plants performance."

The Permit states on pages F-12 and F-13 that:

"The treatment works provide significant biological treatment of municipal wastewater."

Recent data gathered by the discharger indicate that the pond system cannot consistently meet effluent limitations required by secondary treatment standards. The 95th percentile effluent values for BOD and TSS using the last two years of data are 55.6 and 103 mg/L, respectively, thus exceeding the effluent values given in 40 CFR 133.102. The data also show that the treatment process results in significant biological treatment in accordance with 40 CFR 133.101(k) (65% BOD removal)."

The Permit further states on pages F-35 that:

"3. Satisfaction of Anti-Backsliding Requirements. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order except percentage removal of BOD. 40 CFR 122.44(1)(2)(i)(B)(1) allows a less stringent effluent limitation if information is available which was not available at the time of permit issuance, which would have justified the application of a less stringent effluent limitation at the time of permit issuance. The Discharger has recently supplied data (August 2009) that indicates

that they cannot meet 30/30 effluent limitations for BOD and total suspended solids on a year-round basis, as required in 40 CFR 133.102, which is new information. This new information justifies the application of a less stringent effluent limitation in accordance with 40 CFR 133.105. However, the average monthly BOD and total suspended solids effluent limitation for discharge to the Feather River during the allowable discharge period is unchanged from the previous permit and previous versions of this draft permit. The CWA allows revision of effluent limitations only if such revision is subject to and consistent with a State's antidegradation policy. The antibacksliding requirements also prohibit the reissued permits to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving water to violate the applicable state water quality standard under Section 303 of the CWA."

Regional Board staff testified at the 8 October 2009 public hearing that the Discharger can meet the BOD and TSS percent removal during periods when they are allowed, under the terms of the permit, to discharge to surface waters. The collected samples, which the Regional Board cites as new information, showing the percent removal cannot be met were collected during a period when discharges to surface waters are prohibited by the permit. This sampling outside the discharge period does not constitute two years of normal operating data. There is no information regarding the WWTP which shows that the samples were not collected during a period of upset or different land disposal operating conditions. Pond wastewater treatment systems have different seasonal operating capabilities. There is no information that the seasonal prohibition against discharges to surface waters from this treatment facility was not originally based on their inability to meet secondary discharge standards. There is also no information regarding the remainder of the two-year operating period and whether the percent removal can routinely be achieved.

Federal Regulation 40 CFR 124.8 (applicable to State programs) requires preparation of a Fact Sheet which set forth the principal facts and significant factual, legal, methodological and policy questions considered in preparing that draft permit.

• The statement that: "The treatment works provide significant biological treatment of municipal wastewater" has been added to the Permit. There is no basis or supporting documentation that this statement is factual. The methodology and/or data for determining "significant biological treatment" have not been presented.

Generally this type of pond system sees BOD and TSS reductions due to long process detention times and the surface water interactions with the atmosphere providing aeration. It is just as reasonable in this case, based on the information presented, that dilute BOD and TSS levels due to I/I with corresponding high flow rates could reduce the

pond cell residence time and not produce "significant biological treatment". This later case would better explain the request for a reduced percent BOD and TSS removal. The Permit does not contain any information that "significant biological treatment" is being provided.

- The Permit states, as cited above that: "For the last two discharge seasons, the Discharger has met the requirement for BOD percentage removal." Then the Permit proposes to relax this limit and states that: "The 95th percentile effluent values for BOD and TSS using the last two years of data are 55.6 and 103 mg/L, respectively, thus exceeding the effluent values given in 40 CFR 133.102."
 - o BOD and TSS effluent levels can be elevated and percent removal requirements can be met. The Permit Fact Sheet does not set forth the principal facts and methodologies necessary to calculate percent removal efficiencies. What are the influent BOD and TSS values that correspond to the cited 95th percentile effluent values for BOD and TSS? Removal efficiencies cannot be calculated absent this data.
 - o If the Permit is correct that: "For the last two discharge seasons, the Discharger has met the requirement for BOD percentage removal" what data is being used to justify relaxing the limitation for percent removal?
 - o The Permit states that the WWTP is subject to significant I/I which would dilute the influent. The Permit also states that the WWTP receives septage which would have the opposite effect of raising the influent BOD and TSS. Page F-6 states that septage discharges have not been accounted for in analyzing BOD and TSS levels to calculate removal efficiencies. If this is true; the Permit cannot then contain sufficiently accurate information to relax the limitation for BOD and TSS removal efficiencies. Have the impacts of I/I and septage been accounted for in the calculation of BOD and TSS removal efficiencies?

Federal Regulation 40 CFR 133.101 (g) and 133.103 (c) states that minimum secondary treatment standards may be relaxed to "equivalent to secondary standards" if: (1) The BOD and SS effluent concentrations consistently achievable through proper operation and maintenance of the treatment works exceed the minimum level of the effluent quality set forth in 133.102(a) and 133.102(b), (2) a trickling filter or waste stabilization pond is used as the principal process, and (3) the treatment works provide a significant biological treatment of municipal wastewater. There is no information in the Permit or the Fact Sheet to indicate that any elevated BOD and TSS levels were observed during periods of "normal" operations and not during upset.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 6 of 28.

Federal Regulation 40 CFR 133.103 (d)(3) states that for less concentrated influent wastewater for separate sewers the State Director is authorized to substitute a lower percent removal only if the less concentrated influent is not due to excessive inflow and infiltration (I/I). The facility is not eligible for relaxed percent removal limitations as identified problems are at least in part due to excessive inflow and infiltration (I/I). "In part, the problem of effluent percentage BOD removals is also due to the fact that discharge occurs only during months in which I/I is more likely to dilute the influent..." (Page F-6) This would indicate that "significant biological treatment" is not being provided. Regional Board staff has stated that the Discharger has reduced I/I levels to the wastewater treatment plant but has not presented influent flow monitoring data, which is necessary to confirm this conclusion.

Federal Regulation 122.44 (1)(2)(i) requires that renewed, reissued or modified NPDES permits may not contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit. Exceptions to the antibacksliding requirements are for material and substantial alterations to the permitted facility; new information is available; technical mistakes were made in the permit; events have occurred over which the permittee has no control, or; the permittee has installed the treatment facilities to meet the limitations, has properly operated the system and the facilities fail to meet the limitations. The Permit does not meet a single Antibacksliding requirement of 40 CFR 122.44. The Permit only identifies the Antidegradation Policy as a means for relaxing NPDES Permit limitations (Page F-34) and ignores the exceptions of 40 CFR 122.44.

The cited "new" information to justify backsliding is described on Permit pages F-13 as: "Recent data gathered by the discharger indicate that the pond system cannot consistently meet effluent limitations required by secondary treatment standards." This recently gathered data would be from Discharger Self Monitoring Reports, which are submitted to the Regional Board on a monthly basis for the ongoing wastewater discharge. This is not new information; the Regional Board has been reviewing the Discharger's Self Monitoring Reports on a monthly basis for years. Otherwise, why did the Discharger not submit monitoring data showing that they were not achieving a secondary level of treatment?

Under the Clean Water Act (CWA), point source dischargers are required to obtain federal discharge (NPDES) permits and to comply with water quality based effluent limits (WQBELs) in NPDES permits sufficient to make progress toward the achievement of water quality standards or goals. The antibacksliding and antidegradation rules clearly spell out the interest of Congress in achieving the CWA's goal of continued progress toward eliminating all pollutant discharges. Congress clearly chose an overriding environmental interest in clean water through discharge reduction, imposition of technological controls, and adoption of a rule against relaxation of limitations once they are established.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 7 of 28.

Upon permit reissuance, modification, or renewal, a discharger may seek a relaxation of permit limitations. However, according to the CWA, relaxation of a WQBEL is permissible only if the requirements of the antibacksliding rule are met. The antibacksliding regulations prohibit EPA from reissuing NPDES permits containing interim effluent limitations, standards or conditions less stringent than the final limits contained in the previous permit, with limited exceptions. These regulations also prohibit, with some exceptions, the reissuance of permits originally based on best professional judgment (BPJ) to incorporate the effluent guidelines promulgated under CWA §304(b), which would result in limits less stringent than those in the previous BPJ-based permit. Congress statutorily ratified the general prohibition against backsliding by enacting §§402(o) and 303(d)(4) under the 1987 Amendments to the CWA. The amendments preserve present pollution control levels achieved by dischargers by prohibiting the adoption of less stringent effluent limitations than those already contained in their discharge permits, except in certain narrowly defined circumstances.

When attempting to backslide from WOBELs under either the antidegradation rule or an exception to the antibacksliding rule, relaxed permit limits must not result in a violation of applicable water quality standards. The general prohibition against backsliding found in §402(o)(1) of the Act contains several exceptions. Specifically, under §402(o)(2), a permit may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant if: (A) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation; (B)(i) information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (ii) the Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under subsection (a)(1)(B) of this section; (C) a less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy [(e.g., Acts of God)]; (D) the permittee has received a permit modification under section 1311(c), 1311(g), 1311(h), 1311(i), 1311(k), 1311(n), or 1326(a) of this title; or (E) the permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit, and has properly operated and maintained the facilities, but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

Even if a discharger can meet either the requirements of the antidegradation rule under §303(d)(4) or one of the statutory exceptions listed in §402(o)(2), there are still limitations as to how far a permit may be allowed to backslide. Section 402(o)(3) acts as a floor to restrict the extent to which BPJ and water quality-based permit limitations may be relaxed under the

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 8 of 28.

antibacksliding rule. Under this subsection, even if EPA allows a permit to backslide from its previous permit requirements, EPA may never allow the reissued permit to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving waters to violate the applicable state water quality standard adopted under the authority of §303.49.

Federal regulations 40 CFR 122.44 (l)(1) have been adopted to implement the antibacksliding requirements of the CWA:

- (1) Reissued permits. (1) Except as provided in paragraph (1)(2) of this section when a permit is renewed or reissued, interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under Sec. 122.62.)
- (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.
- (i) Exceptions--A permit with respect to which paragraph (1)(2) of this section applies may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant, if:
 - (A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation;
 - (B)(1) Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (2) The Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b);
 - (C) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy;
 - (D) The permittee has received a permit modification under section 301(c), 301(g), 301(h), 301(i), 301(k), 301(n), or 316(a); or

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 9 of 28.

- (E) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).
- (ii) Limitations. In no event may a permit with respect to which paragraph (1)(2) of this section applies be renewed, reissued, or modified to contain an effluent limitation which is less stringent than required by effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into waters be renewed, issued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of a water quality standard under section 303 applicable to such waters.
- B. The Permit contains an allowance for a mixing zone that does not comply with the requirements of the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (SIP) or the Basin Plan.

The Permit grants a mixing zone allowance for ammonia, copper and electrical conductivity. With respect to the mixing zone the Permit contains the following on pages F-20 and F-21:

"Discharge to the Middle Fork of the Feather River is prohibited when river flow is less than 40 cfs; In addition, discharge is prohibited unless the complete mixing dilution in the River is 50:1 or greater.

A mixing model referred to in the Technical support document was consulted by the Discharger's Engineer to verify the mixing regime of the outfall and river. The model is applicable to point discharges where rapid vertical mixing occurs. According to the Technical support document, the model is based on *Mixing in Inland and Coastal Waters* by H.B. Fischer et al. (1979, Academic Press Inc.). The configuration of the River is complex at the discharge location. The discharge is just upstream of a railroad bridge that spans the Middle Fork of the Feather River. The Bridge Abutments separate the stream into two primary channels at the point of discharge, a middle channel and a western channel when the River is at approximately 40 cfs. The Discharger's engineer indicates this flow regime is typical even at substantially higher flows. There is also another channel to the east, which receives approximately 20% of the River flow, and passes by the effluent discharge location. Directly downstream of the effluent discharge, the stream turns approximately 45 degrees due to the adjacent topography and railroad bridge

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 10 of 28.

abutment, and also increases its velocity to approximately 3 feet per second. Both of these conditions should provide good mixing.

Use of this mixing model by the Discharger's engineer allows the assumption of a dilution of at least 40% of the ultimate dilution in the River at the edge of the acute toxicity mixing zone, approximate 100 feet downstream of the discharge, with a width of approximately 30 feet. The 20:1 dilution has been used for both the acute and chronic toxicity mixing zones, because of the specified method of discharge, which is based upon a volumetric percentage of the River flow. The toxicity mixing zone also allows a zone of passage, and should not prove toxic to organisms floating through the mixing zone.

This Order requires the Discharger to install an effluent diffuser to obtain rapid mixing at the point of discharge to the Middle Fork of the Feather River. The Discharger must also, by a dilution study, show that the minimum dilution at the point of the outfall is 20:1 in a mixing zone that complies with the SIP, the Basin Plan, and the USEPA Technical support document."

Despite the statements in the Permit; it does not appear that a formal mixing zone analysis has been completed for this discharge. The Permit does not identify whether the discharge is completely mixed. A diffuser does not currently exist. A mixing zone study is required by the Permit. The permit statements are replete with assumptions and estimates without firm numeric statements. The "mixing zone" granted in the Permit appears to be solely based on the flow volumes of the effluent and the receiving stream; such an analysis does not meet the requirements of the SIP and/or the Basin Plan.

"A mixing zone is an area where an effluent discharge undergoes initial dilution and is extended to cover the secondary mixing in the ambient waterbody. A mixing zone is an allocated impact zone where water quality criteria can be exceeded as long as acutely toxic conditions are prevented" according to EPA's *Technical Support Document for Water Quality-based Toxics Control* (TSD) (USEPA, 1991), (Water quality criteria must be met at the edge of a mixing zone.) Mixing zones are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at concentrations that routinely exceed human health and aquatic life water quality standards (the maximum levels of pollutants that can be tolerated without endangering people, aquatic life, and wildlife.) Mixing zone policies allow a discharger's point of compliance with state and federal water quality standards to be moved from the "end of the pipe" to the outer boundaries of a dilution zone. The CWA was adopted to minimize and eventually eliminate the release of pollutants into public waters because fish were dying and people were getting sick. The CWA requires water quality standards (WQS) be met in all waters to prohibit concentrations of pollutants at levels assumed to cause harm. Since WQS criteria are routinely exceeded in mixing zones it is likely that in some locations harm is

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 11 of 28.

occurring. The general public is rarely aware that local waters are being degraded within these mixing zones, the location of mixing zones within a waterbody, the nature and quantities of pollutants being diluted, the effects the pollutants might be having on human health or aquatic life, or the uses that may be harmed or eliminated by the discharge. Standing waist deep at a favorite fishing hole, a fisherman has no idea that he is in the middle of a mixing zone for pathogens for a sewage discharger that has not been required to adequately treat their waste.

In 1972, backed by overwhelming public support, Congress overrode President Nixon's veto and passed the Clean Water Act. Under the CWA, states are required to classify surface waters by uses – the beneficial purposes provided by the waterbody. For example, a waterbody may be designated as a drinking water source, or for supporting the growth and propagation of aquatic life, or for allowing contact recreation, or as a water source for industrial activities, or all of the above. States must then adopt *criteria* – numeric and narrative limits on pollution, sufficient to protect the uses assigned to the waterbody. Uses + Criteria = Water Quality Standards (WQS). WQS are regulations adopted by each state to protect the waters under their jurisdiction. If a waterbody is classified for more than one use, the applicable WQS are the criteria that would protect the most sensitive use.

All wastewater dischargers to surface waters must apply for and receive a permit to discharge pollutants under the National Pollutant Discharge Elimination System (NPDES.) Every NPDES permit is required to list every pollutant the discharger anticipates will be released, and establish effluent limits for these pollutants to ensure the discharger will achieve WQS. NPDES permits also delineate relevant control measures, waste management procedures, and monitoring and reporting schedules.

It is during the process of assigning effluent limits in NPDES permits that variances such as mixing zones alter the permit limits for pollutants by multiplying the scientifically derived water quality criteria by dilution factors. The question of whether mixing zones are legal has never been argued in federal court.

Mixing zones are never mentioned or sanctioned in the CWA. To the contrary, the CWA appears to speak against such a notion:

"whenever...the discharges of pollutants from a point source...would interfere with the attainment or maintenance of that water quality...which shall assure protection of public health, public water supplies, agricultural and industrial uses, and the protection and propagation of a balanced population of shellfish, fish and wildlife, and allow recreational activities in and on the water, effluent limitations...shall be established which can reasonably be expected to contribute to the attainment or maintenance of such water quality."

A plain reading of the above paragraph calls for the application of effluent limitations whenever necessary to assure that WQS will be met in all waters. Despite the language of the Clean Water Act; US EPA adopted 40 CFR 131.13, General policies, that allows States to, at their discretion, include in their State standards, policies generally affecting their application and implementation, such as mixing zones, low flows and variances. According to EPA; (EPA, Policy and Guidance on Mixing Zones, 63 Fed Reg. 36,788 (July 7, 1998)) as long as mixing zones do not eliminate beneficial uses in the whole waterbody, they do not violate federal regulation or law. California has mixing zone policies included in individual Water Quality Control Plans (Basin Plans) and the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (2005) permitting pollutants to be diluted before being measured for compliance with the state's WQS.

Federal Antidegradation regulations at 40 CFR 131.12 require that states protect waters at their present level of quality and that all beneficial uses remain protected. The corresponding State Antidegradation Policy, Resolution 68-16, requires that any degradation of water quality not unreasonably affect present and anticipated beneficial uses. Resolution 68-16 further requires that: "Any activity which produces or may produce or increase volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with the maximum benefit to the people of the State will be maintained."

- Pollution is defined in the California Water Code as an alteration of water quality to a degree, which unreasonably affects beneficial uses. In California, Water Quality Control Plans (Basin Plans) contain water quality standards and objectives which are necessary to protect beneficial uses. The Basin Plan for California's Central Valley Regional Water Board states that: "According to Section 13050 of the California Water Code, Basin Plans consist of a designation or establishment for the waters within a specified area of beneficial uses to be protected, water quality objectives to protect those uses, and a program of implementation needed for achieving the objectives. State law also requires that Basin Plans conform to the policies set forth in the Water Code beginning with Section 13000 and any state policy for water quality control. Since beneficial uses, together with their corresponding water quality objectives, can be defined per federal regulations as water quality standards, the Basin Plans are regulatory references for meeting the state and federal requirements for water quality control (40 CFR 131.20)."
- Nuisance is defined in the California Water Code as anything, which is injurious to health, indecent, offensive or an obstruction of the free use of property, which affects an entire community and occurs as a result of the treatment or disposal of waste.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 13 of 28.

The Antidegradation Policy (Resolution 68-16) allows water quality to be lowered as long as beneficial uses are protected (pollution or nuisance will not occur), best practicable treatment and control (BPTC) of the discharge is provided, and the degradation is in the best interest of the people of California. Water quality objectives were developed as the maximum concentration of a pollutant necessary to protect beneficial uses and levels above this concentration would be considered pollution. The Antidegradation Policy does not allow water quality standards and objectives to be exceeded. Mixing zone are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at concentrations that routinely exceed water quality standards.

The Antidegradation Policy (Resolution 68-16) requires that best practicable treatment or control (BPTC) of the discharge be provided. Mixing zones have been allowed in lieu of treatment to meet water quality standards at the end-of-the-pipe prior to discharge. To comply with the Antidegradation Policy, the trade of receiving water beneficial uses for lower utility rates must be in the best interest of the people of the state and must also pass the test that the Discharger is providing BPTC. By routinely permitting excessive levels of pollutants to be legally discharged, mixing zones act as an economic disincentive to Dischargers who might otherwise have to design and implement better treatment mechanisms. Although the use of mixing zones may lead to individual, short-term cost savings for the discharger, significant long-term health and economic costs may be placed on the rest of society. An assessment of BPTC, and therefore compliance with the Antidegradation Policy, must assess whether treatment of the wastestream can be accomplished, is feasible, and not simply the additional costs of compliance with water quality standards. A BPTC case can be made for the benefits of prohibiting mixing zones and requiring technologies that provide superior waste treatment and reuse of the wastestream.

EPA's Water Quality Standards Handbook states that: "It is not always necessary to meet all water quality criteria within the discharge pipe to protect the integrity of the waterbody as a whole." The primary mixing area is commonly referred to as the zone of initial dilution, or ZID. Within the ZID acute aquatic life criteria are exceeded. To satisfy the CWA prohibition against the discharge of toxic pollutants in toxic amounts, regulators assume that if the ZID is small, significant numbers of aquatic organisms will not be present in the ZID long enough to encounter acutely toxic conditions. EPA recommends that a ZID not be located in an area populated by non-motile or sessile organisms, which presumably would be unable to leave the primary mixing area in time to avoid serious contamination.

Determining the impacts and risks to an ecosystem from mixing pollutants with receiving waters at levels that exceed WQS is extremely complex. The range of effects pollutants have on different organisms and the influence those organisms have on each other further compromises the ability of regulators to assess or ensure "acceptable" short and long-term impacts from the use of mixing zones. Few if any mixing zones are examined prior to the onset of discharging for

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 14 of 28.

the potential effects on impacted biota (as opposed to the physical and chemical fate of pollutants in the water column). Biological modeling is especially challenging — while severely toxic discharges may produce immediately observable effects, long-term impacts to the ecosystem can be far more difficult to ascertain. The effects of a mixing zone can be insidious; impacts to species diversity and abundance may be impossible to detect until it is too late for reversal or mitigation.

The CALIFORNIA CONSTITUTION, ARTICLE 10, WATER, SEC. 2 states that: "It is hereby declared that because of the conditions prevailing in this State the general welfare requires that the water resources of the State be put to beneficial use to the fullest extent of which they are capable, and that the waste or unreasonable use or unreasonable method of use of water be prevented, and that the conservation of such waters is to be exercised with a view to the reasonable and beneficial use thereof in the interest of the people and for the public welfare. The right to water or to the use or flow of water in or from any natural stream or water course in this State is and shall be limited to such water as shall be reasonably required for the beneficial use to be served, and such right does not and shall not extend to the waste or unreasonable use or unreasonable method of use or unreasonable method of diversion of water. Riparian rights in a stream or water course attach to, but to no more than so much of the flow thereof as may be required or used consistently with this section, for the purposes for which such lands are, or may be made adaptable, in view of such reasonable and beneficial uses; provided, however, that nothing herein contained shall be construed as depriving any riparian owner of the reasonable use of water of the stream to which the owner's land is riparian under reasonable methods of diversion and use, or as depriving any appropriator of water to which the appropriator is lawfully entitled. This section shall be self-executing, and the Legislature may also enact laws in the furtherance of the policy in this section contained." The granting of a mixing zone is an unreasonable use of water when proper treatment of the wastestream can be accomplished to meet end-of-pipe limitations. Also contrary to the California Constitution, a mixing zone does not serve the beneficial use; to the contrary, beneficial uses are degraded within the mixing zone.

The Central Valley Regional Water Quality Control Board's Basin Plan, page IV-16.00, requires the Regional Board use EPA's *Technical Support Document for Water Quality Based Toxics Control (TSD)* in assessing mixing zones. The TSD, page 70, defines a first stage of mixing, close to the point of discharge, where complete mixing is determined by the momentum and buoyancy of the discharge. The second stage is defined by the TSD where the initial momentum and buoyancy of the discharge are diminished and waste is mixed by ambient turbulence. The TSD goes on to state that in large rivers this second stage mixing may extend for miles. The TSD, Section 4.4, requires that if complete mix does not occur in a short distance mixing zone monitoring and modeling must be undertaken.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 15 of 28.

The State's Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California (SIP), Section 1.4.2.2, contains requirements for a mixing zone study which must be analyzed before a mixing zone is allowed for a wastewater discharge. Properly adopted state Policy requirements are not optional. The proposed Effluent Limitations in the Permit are not supported by the scientific investigation that is required by the SIP and the Basin-Plan.

SIP Section 1.4.2.2 requires that a mixing zone shall not:

- 1. Compromise the integrity of the entire waterbody.
- 2. Cause acutely toxic conditions to aquatic life.
- 3. Restrict the passage of aquatic life.
- 4. Adversely impact biologically sensitive habitats.
- 5. Produce undesirable aquatic life.
- 6. Result in floating debris.
- 7. Produce objectionable color, odor, taste or turbidity.
- 8. Cause objectionable bottom deposits.
- 9. Cause Nuisance.
- 10. Dominate the receiving water body or overlap a different mixing zone.
- 11. Be allowed at or near any drinking water intake.

The Permit's mixing zones have not addressed a single required item of the SIP. A very clear unaddressed requirement (SIP Section 1.4.2.2) for mixing zones is that the point(s) in the receiving stream where the applicable criteria must be met shall be specified in the Permit. The "edge of the mixing zone" has not been defined.

Few mixing zones are adequately evaluated to determine whether the modeling exercise was in fact relevant or accurate, or monitored over time to assess the impacts of the mixing zone on the aquatic environment. The sampling of receiving waters often consists of analyzing one or two points where the mixing zone boundary is supposed to be – finding no pollution at the mixing zone boundary is often considered proof that mixing has been "successful" when in fact the sampling protocol might have missed the plume altogether.

C. The Permit does not contain Effluent Limitations for chronic toxicity and therefore does not comply with Federal regulations, at 40 CFR 122.44 (d)(1)(i) and the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (SIP).

Permit, State Implementation Policy states that: "On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed*

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 16 of 28.

Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP."

The SIP, Section 4, Toxicity Control Provisions, Water Quality-Based Toxicity Control, states that: "A chronic toxicity effluent limitation is required in permits for all dischargers that will cause, have a reasonable potential to cause, or contribute to chronic toxicity in receiving waters." The SIP is a state *Policy* and CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy.

Federal regulations, at 40 CFR 122.44 (d)(1)(i), require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including state narrative criteria for water quality. There has been no argument that domestic sewage contains toxic substances and presents a reasonable potential to cause toxicity if not properly treated and discharged. The Water Quality Control Plan for the Sacramento/San Joaquin River Basins (Basin Plan), Water Quality Objectives (Page III-8.00) for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. The Permit states that: "...to ensure compliance with the Basin Plan's narrative toxicity objective, the discharger is required to conduct whole effluent toxicity testing...". However, sampling does not equate with or ensure compliance. The Tentative Permit requires the Discharger to conduct an investigation of the possible sources of toxicity if a threshold is exceeded. This language is not a limitation and essentially eviscerates the Regional Board's authority, and the authority granted to third parties under the Clean Water Act, to find the Discharger in violation for discharging chronically toxic constituents. An effluent limitation for chronic toxicity must be included in the Order. In addition, the Chronic Toxicity Testing Dilution Series should bracket the actual dilution at the time of discharge, not use default values that are not relevant to the discharge.

Permit is quite simply wrong; by failing to include effluent limitations prohibiting chronic toxicity the Permit does not "...implement the SIP". The Permit must be revised to prohibit

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 17 of 28.

chronic toxicity (mortality and adverse sublethal impacts to aquatic life, (sublethal toxic impacts are clearly defined in EPA's toxicity guidance manuals)) in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i) and the Basin Plan and the SIP.

D. The Permit fails to contain mass-based effluent limits for ammonia and copper as required by Federal Regulations 40 CFR 122.45(b).

Federal Regulation, 40 CFR 122.45 (b) requires that in the case of POTWs, permit Effluent Limitations, standards, or prohibitions shall be based on design flow. Concentration is not a basis for design flow. Mass limitations are concentration multiplied by the design flow and therefore meet the regulatory requirement.

Section 5.7.1 of U.S. EPA's *Technical Support Document for Water Quality Based Toxics Control* (TSD, EPA/505/2-90-001) states with regard to mass-based Effluent Limits:

"Mass-based effluent limits are required by NPDES regulations at 40 CFR 122.45(f). The regulation requires that all pollutants limited in NPDES permits have limits, standards, or prohibitions expressed in terms of mass with three exceptions, including one for pollutants that cannot be expressed appropriately by mass. Examples of such pollutants are pH, temperature, radiation, and whole effluent toxicity. Mass limitations in terms of pounds per day or kilograms per day can be calculated for all chemical-specific toxics such as chlorine or chromium. Mass-based limits should be calculated using concentration limits at critical flows. For example, a permit limit of 10 mg/l of cadmium discharged at an average rate of 1 million gallons per day also would contain a limit of 38 kilograms/day of cadmium.

Mass based limits are particularly important for control of bioconcentratable pollutants. Concentration based limits will not adequately control discharges of these pollutants if the effluent concentrations are below detection levels. For these pollutants, controlling mass loadings to the receiving water is critical for preventing adverse environmental impacts.

However, mass-based effluent limits alone may not assure attainment of water quality standards in waters with low dilution. In these waters, the quantity of effluent discharged has a strong effect on the instream dilution and therefore upon the RWC. At the extreme case of a stream that is 100 percent effluent, it is the effluent concentration rather than the mass discharge that dictates the instream concentration. Therefore, EPA recommends that permit limits on both mass and concentration be specified for effluents discharging into waters with less than 100 fold dilution to ensure attainment of water quality standards."

Federal Regulations, 40 CFR 122.45 (f), states the following with regard to mass limitations:

- "(1) all pollutants limited in permits shall have limitations, standards, or prohibitions expressed in terms of mass except:
 - (i) For pH, temperature, radiation or other pollutants which cannot be expressed by mass;
 - (ii) When applicable standards and limitations are expressed in terms of other units of measurement; or
 - (iii) If in establishing permit limitations on a case-by-case basis under 125.3, limitations expressed in terms of mass are infeasible because the mass of the pollutant discharged cannot be related to a measure of operation (for example, discharges of TSS from certain mining operations), and permit conditions ensure that dilution will not be used as a substitute for treatment.
- (2) Pollutants limited in terms of mass additionally may be limited in terms of other units of measurement, and the permit shall require the permittee to comply with both limitations."

Federal Regulations, 40 CFR 122.45 (B)(1), states the following: "In the case of POTWs, permit effluent limitations, standards, or prohibitions shall be calculated based on design flow."

Traditional wastewater treatment plant design utilizes average dry weather flow rates for organic, individual constituent, loading rates and peak wet weather flow rates for hydraulic design of pipes, weir overflow rates, and pumps.

Increased wet weather flow rates are typically caused by inflow and infiltration (I/I) into the sewer collection system that dilutes constituent loading rates and does not add to the mass of wastewater constituents.

For POTWs priority pollutants, such as metals, have traditionally been reduced by the reduction of solids from the wastestream, incidental to treatment for organic material. Following adoption of the CTR, compliance with priority pollutants is of critical importance and systems will need to begin utilizing loading rates of individual constituents in the WWTP design process. It is highly likely that the principal design parameters for individual priority pollutant removal will be based on mass, making mass based Effluent Limitations critically important to compliance. The inclusion of mass limitations will be of increasing importance to achieving compliance with requirements for individual pollutants.

As systems begin to design to comply with priority pollutants, the design systems for POTWs will be more sensitive to similar restrictions as industrial dischargers currently face where production rates (mass loadings) are critical components of treatment system design and compliance. Currently, Industrial Pretreatment Program local limits are frequently based on mass. Failure to include mass limitations would allow industries to discharge mass loads of individual pollutants during periods of wet weather when a dilute concentration was otherwise observed, upsetting treatment processes, causing effluent limitation processes, sludge disposal issues, or problems in the collection system.

In addition to the above citations, on June 26th 2006 U.S. EPA, Mr. Douglas Eberhardt, Chief of the CWA Standards and Permits Office, sent a letter to Dave Carlson at the Central Valley Regional Water Quality Control Board strongly recommending that NPDES permit effluent limitations be expressed in terms of mass as well as concentration.

E. The Permit does not contain an Effluent Limitation for oil and grease in violation of Federal Regulations 40 CFR 122.44 and California Water Code Section 13377.

The Permit is for a domestic wastewater treatment plant. Domestic wastewater treatment plants, by their nature, receive oil and grease in concentrations from home cooking and restaurants that present a reasonable potential to exceed the Basin Plan water quality objective for oil and grease (Basin Plan III-5.00). Confirmation sampling is not necessary to establish that domestic wastewater treatment systems contain oil and grease in concentrations that present a reasonable potential to exceed the water quality objective. It is not unusual for sewerage systems to allow groundwater cleanup systems, such as from leaking underground tanks, to discharge into the sanitary sewer. Groundwater polluted with petroleum hydrocarbons can also infiltrate into the collection system as easily as sewage exfiltrates. The Central Valley Regional Board has a long established history of including oil and grease limitations in NPDES permits at 15 mg/l as a daily maximum and 10 mg/l as a monthly average, which has established BPTC for POTWs.

The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter. US EPA has interpreted 40 CFR 122.44(d) in Central Tenets of the National Pollutant Discharge Elimination System (NPDES) Permitting Program (Factsheets and Outreach Materials,

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 20 of 28.

08/16/2002) that although States will likely have unique implementation policies there are certain tenets that may not be waived by State procedures. These tenets include that "where the preponderance of evidence clearly indicates the potential to cause or contribute to an exceedance of State water quality standards (even though the data may be sparse or absent) a limit MUST be included in the permit." Failure to include an effluent limitation for oil and grease in the Permit violates 40 CFR 122.44 and CWC 13377.

F. The Permit allows for degradation of groundwater quality absent any Antidegradation Policy (Resolution 68-16) analysis or discussion and contrary to California Water Code (CWC) Sections 13146 and 13247.

The Permit contains the following with respect to groundwater:

"B. Groundwater Limitations, 1. Release of waste constituents from any portion of the Facility shall not cause groundwater to: Contain any of the following constituents in concentrations greater than listed or greater than natural background quality, whichever is greater. Table 7. Groundwater Limitations

Constituent	Units	Limitation
Total Coliform Organisms	MPN/100 mL	<2.2
Electrical Conductivity @ 25°C1	μmhos/cm	700
Total Dissolved Solids1	mg/L	450
Nitrite Nitrogen, Total (as N)	mg/L	1
Nitrate Nitrogen, Total (as N)	mg/L	10
Ammonia (as NH4)	mg/L	1.5

The Permit allows groundwater to be <u>degraded to whichever is greater</u> background water quality or water quality objectives. If one assumes that groundwater quality is pristine, which is a reasonable assumption in Portola along the Feather River; degradation beyond background is allowed to water quality standards or objectives. An allowance to degrade groundwater is granted without considering the parameters of the Antidegradation Policy. A minimal antidegradation analysis must also analyze whether: 1) such degradation is consistent with the maximum benefit to the people of the state; 2) the activity is necessary to accommodate important economic or social development in the area; 3) the highest statutory and regulatory requirements and best management practices for pollution control are achieved; and 4) resulting water quality is adequate to protect and maintain existing beneficial uses. Confirming that such an analysis has not taken place; Page 20 of the Permit requires: "BPTC Evaluation Tasks. The Discharger shall propose a work plan and schedule for providing BPTC as required by Resolution 68-16. The technical report describing the work plan and schedule shall contain a

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 21 of 28.

preliminary evaluation of each component and propose a time schedule for completing the comprehensive technical evaluation."

CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy. The State Board has adopted the Antidegradation Policy (Resolution 68-16), which the Regional Board has incorporated into its Basin Plan. The Regional Board is required by the CWC to comply with the Antidegradation Policy.

Implementation of the state's antidegradation policy is guided by the State Antidegradation Guidance, SWRCB Administrative Procedures Update 90-004, 2 July 1990 ("APU 90-004") and USEPA Region IX, "Guidance on Implementing the Antidegradation Provisions of 40 CFR 131.12" (3 June 1987) ("Region IX Guidance"), as well as Water Quality Order 86-17.

The Regional Board must apply the antidegradation policy whenever it takes an action that will lower water quality (State Antidegradation Guidance, pp. 3, 5, 18, and Region IX Guidance, p. 1). Application of the policy does not depend on whether the action will actually impair beneficial uses (State Antidegradation Guidance, p. 6). Actions that trigger use of the antidegradation policy include issuance, re-issuance, and modification of NPDES and Section 404 permits and waste discharge requirements, waiver of waste discharge requirements, issuance of variances, relocation of discharges, issuance of cleanup and abatement orders, increases in discharges due to industrial production and/or municipal growth and/other sources, exceptions from otherwise applicable water quality objectives, etc. (State Antidegradation Guidance, pp. 7-10, Region IX Guidance, pp. 2-3).

Any antidegradation analysis must comport with implementation requirements in State Board Water Quality Order 86-17, State Antidegradation Guidance, APU 90-004 and Region IX Guidance. The conclusory, unsupported, undocumented statements in the Permit are no substitute for a defensible antidegradation analysis.

G. The Permit contains an Effluent Limitation for electrical conductivity (EC) that will cause and contribute to exceedance of the Basin Plan water quality objective contrary to the California Water Code and Federal Regulations.

The Permit contains an Effluent Limitation for EC of 684 umhos/cm as a monthly average. The Basin Plan Table III-3 requires that EC not exceed 150 umhos/cm (90th percentile) in well mixed waters of the Feather River. EC is a measure of salt.

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 22 of 28.

In adopting the NPDES permit for Linda County Water District, R5-2006-0096, the Regional Board granted 100% of the remaining assimilative capacity for EC within the Feather River. Later, the Regional Board granted additional, non-existing, EC assimilative capacity within the Feather River to the city of Yuba City (R5-2007-0134). There is no available assimilative capacity for EC in the Feather River. Salts are conservative, they do not volatilize. The volume of salt discharged in Portola will be seen in downstream waters unless they are physically removed. A discharge of higher salt loads upstream will contribute to impairment of downstream waters.

Federal Regulations, 40 CFR 122.44 (d)(i), requires that; "Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality." The Water Quality Control Plan (Basin Plan) for the Central Valley Region, Water Quality Objectives, Table III-3 requires that EC not exceed 150 umhos/cm (90th percentile) in well mixed waters of the Feather River.

The beneficial uses of receiving streams may be degraded by salt concentrations in wastewater discharges and Federal Regulation, 40 CFR 122.4 (a), (d) and (g) require that no permit may be issued when the conditions of the permit do not provide for compliance with the applicable requirements of the CWA, or regulations promulgated under the CWA, when imposition of conditions cannot ensure compliance with applicable water quality requirements and for any discharge inconsistent with a plan or plan amendment approved under Section 208(b) of the CWA. California Water Code, section 13377, requires that: "Notwithstanding any other provision of this division, the state board and the regional boards shall, as required or authorized by the Federal Water Pollution Control Act, as amended, issue waste discharge and dredged or fill material permits which apply and ensure compliance with all applicable provisions of the act and acts amendatory thereof or supplementary, thereto, together with any more stringent effluent standards or limitations necessary to implement water quality control plans, or for the protection of beneficial uses, or to prevent nuisance." The Region 5 Permits does not protect the beneficial uses of the receiving stream, the Sacramento River, and therefore does not comply with the requirements of Federal Regulations and the California Water Code.

H. The Permit establishes Effluent Limitations for metals based on the hardness of the effluent as opposed to the ambient upstream receiving water hardness as required by Federal Regulations, the California Toxics Rule (CTR, 40 CFR 131.38(c)(4)).

Federal Regulation 40 CFR 131.38(c)(4) states that: "For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 23 of 28.

surface water shall be used in those equations." (Emphasis added). The Permit states that the effluent hardness and the downstream hardness were used to calculate Effluent Limitations for metals. The definition of ambient is "in the surrounding area", "encompassing on all sides". It has been the Region 5, Sacramento, NPDES Section, in referring to Basin Plan objectives for temperature, to define ambient as meaning upstream. It is reasonable to assume, after considering the definition of ambient, that EPA is referring to the hardness of the receiving stream before it is potentially impacted by an effluent discharge. It is also reasonable to make this assumption based on past interpretations and since EPA, in permit writers' guidance and other reference documents, generally assumes receiving streams have dilution, which would ultimately "encompass" the discharge. Ambient conditions are in-stream conditions unimpacted by the discharge.

The Federal Register, Volume 65, No. 97/Thursday, May 18th 2000 (31692), adopting the California Toxics Rule in confirming that the ambient hardness is the upstream hardness, absent the wastewater discharge, states that: "A hardness equation is most accurate when the relationship between hardness and the other important inorganic constituents, notably alkalinity and pH, are nearly identical in all of the dilution waters used in the toxicity tests and in the surface waters to which the equation is to be applied. If an effluent raises hardness but not alkalinity and/or pH, using the lower hardness of the downstream hardness might provide a lower level of protection than intended by the 1985 guidelines. If it appears that an effluent causes hardness to be inconsistent with alkalinity and/or pH the intended level of protection will usually be maintained or exceeded if either (1) data are available to demonstrate that alkalinity and/or pH do not affect the toxicity of the metal, or (2) the hardness used in the hardness equation is the hardness of upstream water that does not include the effluent. The level of protection intended by the 1985 guidelines can also be provided by using the WER procedure."

On March 24, 2000 the US Fish and Wildlife Service (Service) and the National Marine Fisheries Service (NMFS) issued a biological opinion on the effects of the final promulgation of the CTR on listed species and critical habitats in California in accordance with section 7 of the Endangered Species Act of 1973, as amended (16 USC 1531 et seq.; Act). The biological opinion was issued to the U.S. Environmental Protection Agency, Region 9, with regard to the "Final Rule for the Promulgation of Water Quality Standards: Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California" (CTR)". The document represented the Services' final biological opinion on the effects of the final promulgation of the CTR on listed species and critical habitats in California in accordance with section 7 of the Endangered Species Act of 1973, as amended (16 USC 1531 et seq.; Act).

The biological opinion contains the following discussion, beginning on page 205, regarding the use of hardness in developing limitations for toxic metals:

"The CTR should more clearly identify what is actually to be measured in a site water to determine a site-specific hardness value. Is the measure of hardness referred to in the CTR equations a measure of the water hardness due to calcium and magnesium ions only? If hardness computations were specified to be derived from data obtained in site water calcium and magnesium determinations alone, confusion could be avoided and more accurate results obtained (APHA 1985). Site hardness values would thus not include contributions from other multivalent cations (e.g., iron, aluminum, manganese), would not rise above calcium + magnesium hardness values, or result in greater-than-intended site criteria when used in formulas. In this Biological opinion, what the Services refer to as hardness is the water hardness due to calcium + magnesium ions only.

The CTR should clearly state that to obtain a site hardness value, samples should be collected upstream of the effluent source(s). Clearly stating this requirement in the CTR would avoid the computation of greater-than-intended site criteria in cases where samples were collected downstream of effluents that raise ambient hardness, but not other important water qualities that affect metal toxicity (e.g., pH, alkalinity, dissolved organic carbon, calcium, sodium, chloride, etc.). Clearly, it is inappropriate to use downstream site water quality variables for input into criteria formulas because they may be greatly altered by the effluent under regulation. Alterations in receiving water chemistry by a discharger (e.g., abrupt elevation of hardness, changes in pH, exhaustion of alkalinity, abrupt increases in organic matter etc.) should not result, through application of hardness in criteria formulas, in increased allowable discharges of toxic metals. If the use of downstream site water quality variables were allowed, discharges that alter the existing, naturally-occurring water composition would be encouraged rather than discouraged. Discharges should not change water chemistry even if the alterations do not result in toxicity, because the aquatic communities present in a water body may prefer the unaltered environment over the discharge-affected environment. Biological criteria may be necessary to detect adverse ecological effects downstream of discharges, whether or not toxicity is expressed.

The CTR proposes criteria formulas that use site water hardness as the only input variable. In contrast, over twenty years ago Howarth and Sprague (1978) cautioned against a broad use of water hardness as a "shorthand" for water qualities that affect copper toxicity. In that study, they observed a clear effect of pH in addition to hardness. Since that time, several studies of the toxicity of metals in test waters of various compositions have been performed and the results do not confer a singular role to hardness in ameliorating metals toxicity. In recognition of this fact, most current studies carefully vary test water characteristics like pH, calcium, alkalinity, dissolved organic carbon, chloride, sodium, suspended solid s, and others while observing the responses of test organisms. It is likely that understanding metal toxicity in waters of various chemical

makeups is not possible without the use of a geochemical model that is more elaborate than a regression formula. It may also be that simple toxicity tests (using mortality, growth, or reproductive endpoints) are not capable of discriminating the role of hardness or other water chemistry characteristics in modulating metals toxicity (Erickson et al. 1996). Gill surface interaction models have provided a useful framework for the study of acute metals toxicity in fish (Pagenkopf 1983; Playle et al. 1992; Playle et al. 1993a; Playle et al. 1993b; Janes and Playle 1995; Playle 1998), as have studies that observe physiological (e.g. ion fluxes) or biochemical (e.g. enzyme inhibition) responses (Lauren and McDonald 1986; Lauren and McDonald 1987a; Lauren and McDonald 1987b; Reid and McDonald 1988; Verbost et al. 1989; Bury et al. 1999a; Bury et al. 1999b). Even the earliest gill models accounted for the effects of pH on metal speciation and the effects of alkalinity on inorganic complexation, in addition to the competitive effects due to hardness ions (Pagenkopf 1983). Current gill models make use of sophisticated, computer-based, geochemical programs to more accurately account for modulating effects in waters of different chemical makeup (Playle 1998). These programs have aided in the interpretation of physiological or biochemical responses in fish and in investigations that combine their measurement with gill metal burdens and traditional toxicity endpoints.

The Services recognize and acknowledge that hardness of water and the hardness acclimation status of a fish will modify toxicity and toxic response. However the use of hardness alone as a universal surrogate for all water quality parameters that may modify toxicity, while perhaps convenient, will clearly leave gaps in protection when hardness does not correlate with other water quality parameters such as DOC, pH, Cl- or alkalinity and will not provide the combination of comprehensive protection and site specificity that a multivariate water quality model could provide. In our review of the best available scientific literature the Services have found no conclusive evidence that water hardness, by itself, in either laboratory or natural water, is a consistent, accurate predictor of the aquatic toxicity of all metals in all conditions.

SWRCB prescidential Order No. WQ 2008-0008 (Corrected) regarding a petition for consideration of the City of Davis' NPDES Permit states and concludes that:

"Based on the current record, it would be more appropriate to use the lowest reliable upstream receiving water hardness values of 78 mg/l for Willows Slough Bypass and 85 mg/l for Conaway Ranch Toe Drain for protection from acute toxicity impacts, regardless of when the samples were taken or whether they were influenced by storm events. Because high flow conditions may deviate from the design flow conditions for selection of hardness as specified in the CTR, it may not be necessary, in some circumstances, to select the lowest hardness values from high flow or storm event conditions. Regardless of

the hardness used, the resulting limits must always be protective of water quality criteria under all flow conditions."

"Conclusion: The Central Valley Water Board was justified in using upstream receiving water hardness values rather than effluent hardness values. However, for protection from acute toxicity impacts in the receiving waters, which can occur in short durations even during storm events, in this case, based on the existing record, the Central Valley Water Board should have used the lowest valid upstream receiving water hardness values of 78 mg/l for Willow Slough Bypass and 85 mg/l for Conaway Ranch Toe Drain. Effluent limitations must protect beneficial uses considering reasonable, worst-case conditions. We recognize that this approach does not necessarily agree with conclusions in other guidance stating that low flow conditions are the "worst-case" conditions. However, nothing in this Order is intended to suggest that low flows are inappropriate for determining the reasonable, worst-case conditions in other contexts." (Emphasis added)

The most typical wastewater discharge situation is where the receiving water hardness is lower than the effluent hardness. Metals are more toxic in lower hardness water. Therefore in this case it must follow those metals would be more toxic in the receiving water than in the effluent. For example; if the receiving water hardness is 25 mg/l and the effluent hardness is 50 mg/l a corresponding chronic discharge limitation for copper based on the different hardness's would be 2.9 ug/l and 5.2 ug/l, respectively. Obviously, the limitation based on the ambient receiving water hardness is more restrictive. For this case however the Regional Board's argues that the higher effluent hardness or the downstream hardness is protective of all beneficial uses. Since the limitation based on the upstream ambient hardness is more restrictive; the Regional Board's argument can only be made if in-stream mixing is considered. Mixing zones may be granted in accordance with extensive requirements contained in the SIP and the Basin Plan to establish Effluent Limitations. Mixing zones cannot be considered in conducting a reasonable potential analysis to determine whether a constituent will exceed a water quality standard or objective. The Regional Board's approach in using the effluent or downstream hardness to conduct a reasonable potential analysis and consequently establish effluent limitations can only be utilized if mixing is considered; otherwise the ambient (upstream) hardness results in significantly more restrictive limitations. A mixing zone allowance has not been discussed with regard to this issue and therefore does not comply with the SIP. Verification of the Regional Boards use of "mixing" in implementing their procedure can be found in text of Finding No. 4. The issue is that the Regional Board fails to comply with the regulatory requirement to use the ambient instream hardness for limiting hardness dependant metals under the CTR. Use of the effluent or the effluent receiving water mix simply does not meet the definition of the actual ambient hardness of the receiving stream.

5. THE MANNER IN WHICH THE PETITIONERS ARE AGGRIEVED.

CSPA is a non-profit, environmental organization that has a direct interest in reducing pollution to the waters of the Central Valley. CSPA's members benefit directly from the waters in the form of recreational hiking, photography, fishing, swimming, hunting, bird watching, boating, consumption of drinking water and scientific investigation. Additionally, these waters are an important resource for recreational and commercial fisheries. Central Valley waterways also provide significant wildlife values important to the mission and purpose of the Petitioners. This wildlife value includes critical nesting and feeding grounds for resident water birds, essential habitat for endangered species and other plants and animals, nursery areas for fish and shellfish and their aquatic food organisms, and numerous city and county parks and open space areas. CSPA's members reside in communities whose economic prosperity depends, in part, upon the quality of water. CSPA has actively promoted the protection of fisheries and water quality throughout California before state and federal agencies, the State Legislature and Congress and regularly participates in administrative and judicial proceedings on behalf of its members to protect, enhance, and restore declining aquatic resources. CSPA member's health, interests and pocketbooks are directly harmed by the failure of the Regional Board to develop an effective and legally defensible program addressing discharges to waters of the state and nation.

6. THE SPECIFIC ACTION BY THE STATE OR REGIONAL BOARD WHICH PETITIONER REQUESTS.

Petitioners seek an Order by the State Board to:

- A. Vacate Order No. R5-2009-0093 (NPDES No. CA0077844) and remand to the Regional Board with instructions prepare and circulate a new tentative order that comports with regulatory requirements.
- B. Alternatively; prepare, circulate and issue a new order that is protective of identified beneficial uses and comports with regulatory requirements.

7. A STATEMENT OF POINTS AND AUTHORITIES IN SUPPORT OF LEGAL ISSUES RAISED IN THE PETITION.

CSPA's arguments and points of authority are adequately detailed in the above comments and our 13 May 2009 and 30 September 2009 comment letters. Should the State Board have additional questions regarding the issues raised in this petition, CSPA will provide additional briefing on any such questions. The petitioners believe that an evidentiary hearing before the State Board will not be necessary to resolve the issues raised in this petition. However, CSPA welcomes the opportunity to present oral argument and respond to any questions the State Board

CSPA, SWRCB, Petition for Review, Order No. R-5-2009-0093 4 November 2009, Page 28 of 28.

may have regarding this petition.

8. A STATEMENT THAT THE PETITION HAS BEEN SENT TO THE APPROPRIATE REGIONAL BOARD AND TO THE DISCHARGERS, IF NOT THE PETITIONER.

A true and correct copy of this petition, without attachment, was sent electronically and by First Class Mail to Ms. Pamela Creedon, Executive Officer, Regional Water Quality Control Board, Central Valley Region, 11020 Sun Center Drive #200, Rancho Cordova, CA 95670-6114. A true and correct copy of this petition, without attachment, was sent to the Discharger in care of: Mr. Todd Roberts, City of Portola, P.O. Box 1225, Portola, CA, 96122

9. A STATEMENT THAT THE ISSUES RAISED IN THE PETITION WERE PRESENTED TO THE REGIONAL BOARD BEFORE THE REGIONAL BOARD ACTED, OR AN EXPLANATION OF WHY THE PETITIONER COULD NOT RAISE THOSE OBJECTIONS BEFORE THE REGIONAL BOARD.

CSPA presented the issues addressed in this petition to the Regional Board in 13 May 2009 and 30 September 2009 comment letters that were accepted into the record.

If you have any questions regarding this petition, please contact Bill Jennings at (209) 464-5067 or Michael Jackson at (530) 283-1007.

Dated: 4 November 2009

Respectfully submitted,

Bill Jennings, Executive Director

California Sportfishing Protection Alliance

Attachment No. 1: Order No. R5-2009-0093

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD CENTRAL VALLEY REGION

415 Knollcrest Drive, Suite 100, Redding, California 96002 Phone (530) 224-4845• FAX (530) 224-4857 http://www.waterboards.ca.gov/centralvalley

ORDER NO. R5-2009-0093 NPDES NO. CA0077844

WASTE DISCHARGE REQUIREMENTS FOR THE CITY OF PORTOLA PORTOLA WASTEWATER TREATMENT PLANT PLUMAS COUNTY

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

Table I. Discharger in	HOTHIGUOT,
Discharger	City of Portola
Name of Facility	Portola Wastewater Treatment Plant
	120 Main Street
Facility Address	Portola, CA, 96122
	Plumas County
	tal Protection Agency (USEPA) and the Regional Water Quality Control Board have ge as a minor discharge.

The discharge by the City of Portola from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

Discharge	Effluent	Discharge Point	Discharge Point	Receiving Water
Point	Description	Latitude	Longitude	
001	Secondary Treated Wastewater	39°, 48', 15" N	120°, 29', 29" W	Middle Fork, Feather River

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	8 October 2009
This Order shall become effective on:	8 October 2009
This Order shall expire on:	1 October 2014
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	180 days prior to the Order expiration date

IT IS HEREBY ORDERED, that Order No. R5-2003-0110 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 8 October 2009.

Original signed by Kenneth D. Landau for PAMELA C. CREEDON, Executive Officer

Table of Contents

I.	Facility Information	1
11.	Findings	
III.	Discharge Prohibitions	6
IV.	Effluent Limitations and Discharge Specifications	8
	A. Effluent Limitations – Discharge Point D-001	8
	1.Final Effluent Limitations – Discharge Point D-001	
	2.Interim Effluent Limitations	9
	B. Land Discharge Specifications – Discharge Points LND-001, LND-002, LND-003,	
	LND-004, LND-005, LND-006, LND-007, and LND-008, Aerated and Facultative	
	Ponds	
	C. Reclamation Specifications –Not Applicable	
V.	Receiving Water Limitations	
	A. Surface Water Limitations	10
	B. Groundwater Limitations	12
VI.	Provisions	
	A. Standard Provisions	12
	B. Monitoring and Reporting Program (MRP) Requirements	17
	C. Special Provisions	17
•	1.Reopener Provisions	
	2. Special Studies, Technical Reports and Additional Monitoring Requirements	
	3.Best Management Practices and Pollution Prevention	
	4. Construction, Operation and Maintenance Specifications	
	5. Special Provisions for Municipal Facilities (POTWs Only)	
	6.Other Special Provisions	
	7.Compliance Schedules-Not Applicable	29
VII.	Compliance Determination	29
	List of Tables	
Tab	le 1. Discharger InformationCo	ver
Tab	le 2. Discharge LocationCo	ver
	le 3. Administrative Information	
	le 4. Facility Information	
	le 5. Basin Plan Beneficial Uses	
	le 6. Effluent Limitations	
	le 7. Groundwater Limitations	
	List of Attachments	
۸ 44 ۸	chment A – Definitions	Δ 1
	chment B – MapI	
	chment C – Flow Schematic	
	chment D – Standard Provisions	
Alla	chment E – Monitoring and Reporting Program (MRP)	ノ- I これ
	chment F – Fact Sheet	
\neg ua	CHITCHET LAGEOROCE	1

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

Discharger	City_of Portola			
Name of Facility	Portola Wastewater Treatment Plant			
	120 Main Street			
Facility Address	Portola, CA, 96122			
	Plumas County			
Facility Contact, Title, and Phone	Michael Achter, Operator, (530) 258 6598			
Mailing Address	P.O. Box 1225, Portola, CA, 96122			
Type of Facility	Publicly Owned Treatment Works			
Facility Design Flow	0.5 million gallons per day (mgd)			

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Regional Water Board), finds:

- A. Background. The City of Portola (hereinafter Discharger) is currently discharging pursuant to Order No. R5-2003-0110 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0077844. The Discharger submitted a Report of Waste Discharge, dated December 10, 2007, and applied for a NPDES permit renewal to discharge up to 0.5 mgd (monthly average dry weather flow) of treated wastewater from the Portola wastewater treatment plant, hereinafter Facility. The application was deemed complete on February 22, 2008.
- B. Facility Description. The Discharger owns and operates a municipal wastewater treatment plant. The collection system consists of approximately 15 miles of gravity line and force mains. There are two lift stations in the collection system, one on the north side of the Middle Fork of the Feather River, and one on the South side of the River and discharge to the ponds is by force main from either one of the two lift stations. The treatment system consists of a headworks with bar screen and influent parshall flumes for flow measurement (one flume for each pump station discharge), emergency pond, aerated and unaerated ponds, chlorination, and dechlorination. Wastewater is discharged from Discharge D-001 (see table on cover page) to a small constructed wetlands, then to the Middle Fork of the Feather River, a water of the United States within the Feather River Watershed. Discharge is allowed only from 1 November to 15 May; in some years the discharge occurs for only one or two months. Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.
- **C. Legal Authorities.** This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental

Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

- D. Background and Rationale for Requirements. The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through F are also incorporated into this Order.
- **E.** California Environmental Quality Act (CEQA). Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100-21177.
- F. Technology-based Effluent Limitations. Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations (CFR)¹ require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at Part 133. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).
- **G. Water Quality-based Effluent Limitations.** Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State's narrative criterion, supplemented with other relevant information, as provided in 40 CFR section 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Regional Water Board adopted a Water Quality Control Plan, Fourth Edition (Revised August 2006), for the Sacramento and San

All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

Joaquin River Basins (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to Middle Fork of the Feather River are as follows:

Table 5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Middle Fork of the Feather River (From Last Chance Creek to Lake Oroville)	Existing: Municipal and domestic water supply (MUN); contact recreation and canoeing and rafting (REC-1); noncontact (REC-2) water recreation; warm freshwater habitat (WARM); cold freshwater habitat (COLD); cold water spawning (SPWN); and wildlife habitat (WILD)

Requirements of this Order implement the Basin Plan.

- I. National Toxics Rule (NTR) and California Toxics Rule (CTR). USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- J. State Implementation Policy. On March 2, 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Compliance Schedules and Interim Requirements. In general, an NPDES permit must include final effluent limitations that are consistent with Clean Water Act section 301 and with 40 CFR 122.44(d). There are exceptions to this general rule. The State Water Board has concluded that where the Regional Water Board's Basin Plan allows for schedules of compliance and the Regional Water Board is newly interpreting a narrative standard, it may include schedules of compliance in the permit to meet effluent

limits that implement a narrative standard. See In the Matter of Waste Discharge Requirements for Avon Refinery (State Board Order WQ 2001-06 at pp. 53-55). See also Communities for a Better Environment et al. v. State Water Resources Control Board, 34 Cal.Rptr.3d 396, 410 (2005). The Basin Plan for the Sacramento and San Joaquin Rivers includes a provision that authorizes the use of compliance schedules in NPDES permits for water quality objectives that are adopted after the date of adoption of the Basin Plan, which was September 25, 1995 (See Basin Plan at page IV-16). Consistent with the State Water Board's Order in the CBE matter, the Regional Water Board has the discretion to include compliance schedules in NPDES permits when it is including an effluent limitation that is a "new interpretation" of a narrative water quality objective. This conclusion is also consistent with the United States Environmental Protection Agency policies and administrative decisions. See, e.g., Whole Effluent Toxicity (WET) Control Policy. The Regional Water Board, however, is not required to include a schedule of compliance, but may issue a Time Schedule Order pursuant to Water Code section 13300 or a Cease and Desist Order pursuant to Water Code section 13301 where it finds that the discharger is violating or threatening to violate the permit. The Regional Water Board will consider the merits of each case in determining whether it is appropriate to include a compliance schedule in a permit, and, consistent with the Basin Plan, should consider feasibility of achieving compliance, and must impose a schedule that is as short as practicable to achieve compliance with the objectives, criteria, or effluent limit based on the objective or criteria.

For CTR constituents, Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation that exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order does not include compliance schedules

- L. Alaska Rule. On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 C.F.R. § 131.21; 65 Fed. Reg. 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.
- M. Stringency of Requirements for Individual Pollutants. This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD₅, TSS, pH, and

percent removal. The water quality-based effluent limitations consist of restrictions on pathogens, ammonia, electrical conductivity, and copper. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations are based on the CTR-SIP, which was approved by USEPA on May 1, 2001. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the [Clean Water] Act" pursuant to 40 CFR section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

- N. Antidegradation Policy. Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 is consistent with the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet the permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.
- O. Anti-Backsliding Requirements. Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order, except for percent removal of effluent BOD. The fact sheet explains how the modified effluent limitations for percentage BOD removal are authorized.
- P. Monitoring and Reporting. Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.

- Q. Standard and Special Provisions. Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- R. Provisions and Requirements Implementing State Law. The provisions/requirements in subsections IV.B, IV.C, and V.B of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- **S. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- **T. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location or in a manner different from that described in the Findings is prohibited.
- B. The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C. Neither the discharge nor its treatment shall create a nuisance as defined in Section 13050 of the California Water Code.
- D. The Discharger shall not allow pollutant-free wastewater to be discharged into the collection, treatment, and disposal system in amounts that significantly diminish the system's capability to comply with this Order. Pollutant-free wastewater means rainfall, groundwater, cooling waters, and condensates that are essentially free of pollutants.
- E. Discharge from the wetlands to the River is prohibited when River flow as measured at the "DWR MFP" (Middle Fork Feather River Portola) gauging station is less than 40 cfs.
- F. Discharge to the Middle Fork of the Feather River is prohibited between 1 May and 31 October.

- G. The discharge to the Middle Fork of the Feather River shall not exceed 2% of the River flow as measured at the "DWR MFP" (Middle Fork Feather River Portola) gauging station.
- H. The average daily dry weather influent flow to the wastewater treatment facility shall not exceed 0.5 mgd.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point D-001

1. Final Effluent Limitations – Discharge Point D-001

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point D-001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP (Attachment E):

a. The Discharger shall maintain compliance with the effluent limitations specified in Table 6:

Table 6. Effluent Limitations

The Discharger shall maintain compliance with the following effluent limitation at Disccharge Point 001

		Effluent Limitations				
Parameter	Units	Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
DOD 5 dov @ 20°C	mg/L	30	45	. 90		
BOD 5-day @ 20°C	lbs/day ¹	1	1	1		
Total Cuspended Calida	mg/L	30	45	90		
Total Suspended Solids	lbs/day ¹	1	1	1		
рН	standard units				6.0	9.0
Ammonia, Total as N	mg/L	23		45		
Copper, total	ug/L	53		106		
		-				

- The average mass discharge for the period from 1 November to 31 April shall not exceed 125.1 lb/day.
 - b. **Percent Removal:** The average monthly percent removal of BOD 5-day 20°C and total suspended solids shall not be less than 65 percent
 - c. **Acute Whole Effluent Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:
 - i. 70%, minimum for any one bioassay; and
 - ii. 90%, median for any three consecutive bioassays.
 - d. Total Residual Chlorine. Effluent total residual chlorine shall not exceed:
 - i. 0.01 mg/L, as a 4-day average;
 - ii. 0.02 mg/L, as a 1-hour average;

- e. Total Coliform Organisms. Effluent total coliform organisms shall not exceed:
 - i. 23 most probable number (MPN) per 100 mL, as a 7-day median; and
 - ii. 240 MPN/100 mL, more than once in any 30-day period.
- f. **Electrical Conductivity**. Electrical Conductivity shall not exceed 684 umhos/cm as an annual average concentration.
- 2. Interim Effluent Limitations-Not Applicable
- B. Land Discharge Specifications Discharge Points LND-001, LND-002, LND-003, LND-004, LND-005, LND-006, LND-007, and LND-008, Aerated and Facultative Ponds
 - 1. The discharge of waste classified as "hazardous" as defined in section 2521(a) of Title 23, California Code of Regulations (CCR), or "designated", as defined in section 13173 of the CWC, to the treatment ponds is prohibited.
 - 2. Objectionable odors originating at this facility shall not be perceivable beyond the limits of the wastewater treatment and disposal facility.
 - 3. As a means of discerning compliance with Land Discharge Specification 4, the dissolved oxygen content in the upper zone (1 foot) of wastewater in ponds shall not be less than 1.0 mg/L.
- C. Reclamation Specifications -Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in the Middle Fork of the Feather River:

- 1. **Bacteria**. The fecal coliform concentration, based on a minimum of not less than five samples for any 30-day period, to exceed a geometric mean of 200 MPN/100 mL, nor more than ten percent of the total number of fecal coliform samples taken during any 30-day period to exceed 400 MPN/100 mL.
- 2. **Biostimulatory Substances**. Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
- 3. **Chemical Constituents**. Chemical constituents to be present in concentrations that adversely affect beneficial uses.
- 4. Color. Discoloration that causes nuisance or adversely affects beneficial uses.

5. Dissolved Oxygen:

- a. The monthly median of the mean daily dissolved oxygen concentration to fall below 85 percent of saturation in the main water mass;
- b. The 95 percentile dissolved oxygen concentration to fall below 75 percent of saturation; nor
- c. The dissolved oxygen concentration to be reduced below 7.0 mg/L at any time.
- 6. **Floating Material**. Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
- 7. **Oil and Grease**. Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
- 8. **pH**. The pH to be depressed below 6.5, raised above 8.5, nor changed by more than 0.5 units: A one-month averaging period may be applied when calculating the pH change of 0.5 units.

9. Pesticides:

- a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
- b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;

- c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by USEPA or the Executive Officer.
- d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR §131.12.).
- e. Pesticide concentrations to exceed the lowest levels technically and economically achievable.
- f. Pesticides to be present in concentration in excess of the maximum contaminant levels set forth in California Code of Regulations, Title 22, Division 4, Chapter 15.
- g. Thiobencarb to be present in excess of 1.0 µg/L

10. Radioactivity:

- a. Radionuclides to be present in concentrations that are harmful to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life.
- b. Radionuclides to be present in excess of the maximum contaminant levels specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations.
- 11. **Salinity**. Electrical Conductivity at 25° C shall not exceed 150 umhos/cm (90th percentile) in well-mixed waters of the Middle Fork of the Feather River over a 10 year rolling average
- 12. **Suspended Sediments**. The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.
- 13 **Settleable Substances**. Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.
- 14. **Suspended Material**. Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.
- 15. **Taste and Odors**. Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.
- 16. **Temperature**. The natural temperature to be increased by more than 5°F.
- 17. **Toxicity**. Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.

18. **Turbidity**. The turbidity to increase as follows:

- a. More than 1 Nephelometric Turbidity Unit (NTU) where natural turbidity is between 0 and 5 NTUs.
- b. More than 20 percent where natural turbidity is between 5 and 50 NTUs.
- c. More than 10 NTU where natural turbidity is between 50 and 100 NTUs.
- d. More than 10 percent where natural turbidity is greater than 100 NTUs.

Appropriate averaging periods may be used where approved by the executive officer.

B. Groundwater Limitations

- 1. Release of waste constituents from any portion of the Facility shall not cause groundwater to:
 - **a.** Contain any of the following constituents in concentrations greater than listed or greater than natural background quality, whichever is greater.

Table 7. Groundwater Limitations

Constituent	Units	Limitation
Total Coliform Organisms	MPN/100 mL	<2.2
Electrical Conductivity @ 25°C1	µmhos/cm	700
Total Dissolved Solids ¹	mg/L	450
Nitrite Nitrogen, Total (as N)	mg/L	1
Nitrate Nitrogen, Total (as N)	mg/L	10
Ammonia (as NH ₄)	mg/L	1.5

A cumulative impact limit that accounts for several dissolved constituents in addition to those listed here separately [e.g., alkalinity (carbonate and bicarbonate), calcium, hardness, phosphate, and potassium].

- **b.** Exhibit a pH of less than 6.5 or greater than 8.4 pH units.
- **c.** Impart taste, odor, chemical constituents, toxicity, or color that creates nuisance or impairs any beneficial use.

VI. PROVISIONS

A. Standard Provisions

- 1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
- 2. The Discharger shall comply with the following provisions:
 - a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and

- operated by persons possessing certificates of appropriate grade according to Title 23, CCR, Division 3, Chapter 26.
- b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. violation-of-any-term-or-condition-contained-in-this-Order;
 - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
 - iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- New regulations. New regulations have been promulgated under Section 405(d) of the Clean Water Act, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- Land application plans. When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- Change in sludge use or disposal practice. Under 40 Code of Federal Regulations (CFR) 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Regional Water Board may review and revise this Order at any time upon application of any affected person or the Regional Water Board's own motion.

c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Regional Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by USEPA under Section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. The discharge of any radiological, chemical or biological warfare agent or high-level, radiological waste is prohibited.
- A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- j. Safeguard to electric power failure:
 - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Regional Water Board the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past five years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Regional Water Board.