

Table A6
 Donald C. Tillman Water Reclamation Plant
 Revised Reasonable Potential Analyses and Limit Derivations
 (CA0056227, CI-5695)

| CTR# | Pollutant | MEC | CTR WQC=C | Basin Plan WQC Title 22 GWR=C | Lowest C | MEC>C | MEC>Title 22 GWR | Receiving Water>ME |
|------|----------------------------|-----|-----------|-------------------------------|----------|-------|------------------|--------------------|
| 14 | Cyanide (CN) | 0 | 5.2 | | 5.2 | NO | | NO |
| 38 | Tetrachloroethylene | 0 | 8.85 | 5 | 5 | NO | NO | NO |
| 68 | Bis(2-ethylhexyl)phthalate | 1 | 5.9 | 4 | 4 | NO | NO | NO |
| 105 | Gamma-BHC | 0 | 0.063 | | 0.063 | NO | | NO |

The above **New Numerical Limitations** were based on effluent data between January 1, 2008 and December 31, 2008. The DC Tillman WRP has had the optimal NDN process since October 1, 2007, this date was confirmed with the City of Los Angeles.

Table A6
 Donald C. Tillman Water Reclamation Plant
 Revised Reasonable Potential Analyses and Limit Derivations
 (CA0056227, CI-5695)

| CTR# | Pollutant | RPA | New Numerical Limitation | |
|------|----------------------------|--------------|--------------------------|---------------|
| | | | Monthly Average | Daily Maximum |
| 14 | Cyanide (CN) | NO (MEC < C) | No limit | No limit |
| 38 | Tetrachloroethylene | NO (MEC < C) | No limit | No limit |
| 68 | Bis(2-ethylhexyl)phthalate | NO (MEC < C) | No limit | No limit |
| 105 | Gamma-BHC | NO (MEC < C) | No limit | No limit |