

2. Intermittent Injection Wells (Frequency of Analysis):

Constituent	Unit	Type of Sample	23 T	23 Y	24 B	24 E	24 H	24 M	24 Q	24 V	24 X	24 Z	25 C	25 E	25 H	25 K1	25 Q	25 T	25 W	25 Y	26 A	26 B	26 C	26 D	26 J	26 N	26 R	26 T	26 Y	27 A
Total Waste Flow	gal/day	totalizer	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
pH	pH Units	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Temperature	°F	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Total Suspended Solids	mg/L	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Turbidity	NTU	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Settleable Solids	ml/L	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Oil and Grease	mg/L	grab	✓								✓											✓						✓		
BOD520oC	mg/L	grab	✓								✓											✓						✓		
Residual Chlorine	mg/L	grab	✓								✓											✓						✓		
Copper (Cu)	µg/L	grab	✓								✓											✓						✓		
Lead (Pb)	µg/L	grab	✓								✓											✓						✓		
Total Chromium	µg/L	grab	✓								✓											✓						✓		
1,1 Dichloroethane	µg/L	grab	✓								✓											✓						✓		
1,1 Dichloroethylene	µg/L	grab	✓								✓											✓						✓		
1,1,1 Trichloroethane	µg/L	grab	✓								✓											✓						✓		
1,1,2 Trichloroethane	µg/L	grab	✓								✓											✓						✓		
1,1,2,2 Tetrachloroethane	µg/L	grab	✓								✓											✓						✓		
1,2 Dichloroethane	µg/L	grab	✓								✓											✓						✓		
1,2-Trans Dichloroethylene	µg/L	grab	✓								✓											✓						✓		
Tetrachloroethylene	µg/L	grab	✓								✓											✓						✓		
Trichloroethylene	µg/L	grab	✓								✓											✓						✓		
Carbon Tetrachloride	µg/L	grab	✓								✓											✓						✓		
Vinyl Chloride	µg/L	grab	✓								✓											✓						✓		
Total Trihalomethanes	µg/L	grab	✓								✓											✓						✓		
Benzene	µg/L	grab	✓								✓											✓						✓		
Methyl tertiary butyl ether (MTBE)	µg/L	grab	✓								✓											✓						✓		
Perchlorate	µg/L	grab	✓								✓											✓						✓		
1-4 Dioxane	µg/L	grab	✓								✓											✓						✓		
N-Nitrosodimethylamine (NDMA)	µg/L	grab	✓								✓											✓						✓		
Acute Toxicity	% survival	grab	✓								✓											✓						✓		

✓ = Once per discharge event (Analysis is required once per discharge event, however, if discharges is continuous for more than 30-days the minimum frequency sampling becomes monthly.)

2. Intermittent Injection Wells (Frequency of Analysis): (Cont.)

Constituent	Unit	Type of Sample	27 B	27 E	27 F	27 J	27 M	27 Q	27 T	27 W	27 Y	28 A	28 C	28 H	28 R	28 T	28 W	28 Y	28 Y1	28 Y2	28 ZZ1	28 Z1	28 Z2	28 Z3	29 AA1	29 A1	29 A2	29 A3	29 A4B	29 B	29 B1	
Total Waste Flow	gal/day	totalizer	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
pH	pH Units	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Temperature	°F	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Total Suspended Solids	mg/L	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Turbidity	NTU	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Settleable Solids	ml/L	grab	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Oil and Grease	mg/L	grab								✓							✓									✓						
BOD520oC	mg/L	grab								✓							✓									✓						
Residual Chlorine	mg/L	grab								✓							✓									✓						
Copper (Cu)	µg/L	grab								✓							✓									✓						
Lead (Pb)	µg/L	grab								✓							✓									✓						
Total Chromium	µg/L	grab								✓							✓									✓						
1,1 Dichloroethane	µg/L	grab								✓							✓									✓						
1,1 Dichloroethylene	µg/L	grab								✓							✓									✓						
1,1,1 Trichloroethane	µg/L	grab								✓							✓									✓						
1,1,2 Trichloroethane	µg/L	grab								✓							✓									✓						
1,1,2,2 Tetrachloroethane	µg/L	grab								✓							✓									✓						
1,2 Dichloroethane	µg/L	grab								✓							✓									✓						
1,2-Trans Dichloroethylene	µg/L	grab								✓							✓									✓						
Tetrachloroethylene	µg/L	grab								✓							✓									✓						
Trichloroethylene	µg/L	grab								✓							✓									✓						
Carbon Tetrachloride	µg/L	grab								✓							✓									✓						
Vinyl Chloride	µg/L	grab								✓							✓									✓						
Total Trihalomethanes	µg/L	grab								✓							✓									✓						
Benzene	µg/L	grab								✓							✓									✓						
Methyl tertiary butyl ether (MTBE)	µg/L	grab								✓							✓									✓						
Perchlorate	µg/L	grab								✓							✓									✓						
1-4 Dioxane	µg/L	grab								✓							✓									✓						
N-Nitrosodimethylamine (NDMA)	µg/L	grab								✓							✓									✓						
Acute Toxicity	% survival	grab								✓							✓									✓						

✓ = Once per discharge event (Analysis is required once per discharge event, however, if discharges is continuous for more than 30-days the minimum frequency sampling becomes monthly.)