

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

**MONITORING AND REPORTING PROGRAM NO. 6743
for
METROPOLITAN WATER DISTRICT OF SOUTHERN CALIFORNIA
(Foothill Feeder Power Plant)
(CA0059641)**

I. Reporting Requirements

- A. Metropolitan Water District of Southern California, Foothill Feeder Power Plant (hereinafter Foothill or Discharger) shall implement this monitoring program on the effective date of this Order. All monitoring reports shall be submitted quarterly and must be received by the Regional Board by the dates in the following schedule. All monitoring reports should be addressed to the Regional Board, Attention: Information Technology Unit. The first monitoring report under this Program is due by November 1, 2005.

Reporting Period	Report Due
January – March	May 1
April – June	August 1
July-September	November 1
October-December	February 1
Annual Summary Report	March 1

If there is no discharge during any reporting period, the report shall so state.

- B. The Discharger shall submit an annual summary report containing a discussion of the previous year's effluent and receiving water monitoring data, as well as graphical and tabular summaries of the data. The data shall be submitted to the Regional Board on hard copy and on a 3 ½" computer diskette. Submitted data must be IBM compatible, preferably using EXCEL software. This annual report is to be received by the Regional Board by March 1 of each year following the calendar year of data collection.
- C. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with waste discharge requirements, as well as all excursions of effluent limitations.

- D. The Discharger shall inform the Regional Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements.

II. Effluent Monitoring Requirements

- A. A sampling station shall be established for each point of discharge and shall be located where representative samples of that effluent can be obtained. A representative sample shall be collected for the discharge through NPDES Discharge Serial No. 001 (Latitude 34° 30' 52" N, Longitude 118° 36' 29" W) to Castaic Lake Afterbay from the sample tap at the Discharge Serial 001 sump.
- B. This Regional Board shall be notified in writing of any change in the sampling stations once established or in the methods for determining the quantities of pollutants in the individual waste streams.
- C. Pollutants shall be analyzed using the analytical methods described in 40 CFR sections 136.3, 136.4, and 136.5 (revised May 14, 1999); or, where no methods are specified for a given pollutant, by methods approved by this Regional Board or the State Board. Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Health Services Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided each time a new certification and/or renewal of the certification is obtained from ELAP.

The monitoring reports shall specify the analytical method used, the Method Detection Limit (MDL), and the Minimum Level (ML) for each pollutant. For the purpose of reporting compliance with numerical limitations, performance goals, and receiving water limitations, analytical data shall be reported by one of the following methods, as appropriate:

1. An actual numerical value for sample results greater than or equal to the ML; or,
2. "Detected, but Not Quantified (DNQ)" if results are greater than or equal to the laboratory's MDL but less than the ML; or,
3. "Not-Detected (ND)" for sample results less than the laboratory's MDL with the MDL indicated for the analytical method used.

Current MLs (Attachment A) are those published by the State Water Resources Control Board in the *Policy for the Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (or SIP), March 2, 2000*.

- D. Where possible, the MLs employed for effluent analyses shall be lower than the permit limitations established for a given parameter. If the ML value is not below the effluent limitation, then the lowest ML value and its associated analytical method shall be selected for compliance purposes. At least once a year, the Discharger shall submit a list of the analytical methods employed for each test and associated laboratory QA/QC procedures.

The Regional Board, in consultation with the State Board Quality Assurance Program, shall establish an ML that is not contained in Attachment A to be included in the Discharger's permit in any of the following situations:

1. When the pollutant under consideration is not included in Attachment A;
 2. When the Discharger and Regional Board agree to include in the permit a test method that is more sensitive than that specified in 40 Code of Federal Regulation (CFR) Part 136 (revised May 14, 1999);
 3. When the Discharger agrees to use an ML that is lower than that listed in Attachment A;
 4. When the Discharger demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Attachment A, and proposes an appropriate ML for their matrix; or,
 5. When the Discharger uses a method whose quantification practices are not consistent with the definition of an ML. Examples of such methods are the United States Environmental Protection Agency (U.S. EPA) approved method 1613 for dioxins and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Discharger, the Regional Board, and the State Board shall agree on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.
- E. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR section 136.3. All quality assurance and control (QA/QC)

items must be run on the same dates the samples were actually analyzed, and the results shall be reported in the Regional Board format, when it becomes available, and submitted with the laboratory reports. Proper chain of custody procedures must be followed, and a copy of the chain of custody shall be submitted with the report.

- F. All analyses shall be accompanied by the chain of custody, including but not limited to data and time of sampling, sample identification, and name of person who performed sampling, date of analysis, name of person who performed analysis, QA/QC data, method detection limits, analytical methods, copy of laboratory certification, and a perjury statement executed by the person responsible for the laboratory.
- G. Quarterly effluent analyses shall be performed during the months of February, May, August, and November. Semi-annual effluent analyses shall be performed during the months of February and August. Annual effluent analyses shall be performed during the month of February. Results of monthly, quarterly, and annual analyses shall be reported in the appropriate quarterly monitoring report, as indicated in Section I.A.
- H. For parameters for which both monthly average and daily maximum limits are specified and the monitoring frequency is less than four times a month, the following shall apply. If an analytical result is greater than the monthly average limit, the sampling frequency shall be increased (within 1 week of receiving the test results) to a minimum of once weekly at equal intervals, until at least four consecutive weekly samples have been obtained, and compliance with the monthly average limit has been demonstrated. The Discharger shall provide for the approval of the Executive Officer a program to ensure future compliance with the monthly average limit.

III. Effluent Monitoring Program

- A. This Order requires that sampling for effluent monitoring for Discharge Serial No. 001 shall be conducted at the point of discharge to Castaic Lake Afterbay. Monitoring is required to determine compliance with effluent limitations and characterize the discharge. The Table below shall constitute the effluent monitoring program for NPDES Discharge Serial No. 001 (Latitude 34° 30' 52" N, Longitude 118° 36' 29" W) to Castaic Lake Afterbay.
- B. The Discharger is also required to monitor the effluent for the California Toxics Rule (CTR) priority pollutants, to determine reasonable potential. The monitoring

requirements for CTR priority pollutants are discussed in Section VI. Details of the toxicity tests are available in Section IV.

Pollutant	Units	Type of Sample	Sampling Frequency
Total Waste Flow	gallons per day	----	Monthly
pH	standard units	Grab	Monthly
Temperature	° F	Grab	Monthly
Dissolved Oxygen	mg/L	Grab	Monthly
Settleable Solids	ml/L	Grab	Semi-Annually
Turbidity	NTU	Grab	Semi-Annually
Total Suspended Solids (TSS)	mg/L	Grab	Semi-Annually
Oil and Grease	mg/L	Grab	Semi-Annually
Biochemical Oxygen Demand (BOD) ¹	mg/L	Grab	Semi-Annually
Dibenzo(a,h)anthracene	µg/L	Grab	Quarterly
Indeno(1,2,3-cd)pyrene	µg/L	Grab	Quarterly
Remaining Priority Pollutants ²	µg/L	Grab	Annually
Acute Toxicity ³	% survival	Grab	Annually
Chronic Toxicity ⁴	TU _c	Grab	Annually

¹ 5-day BOD at 20 °C.

² See Section VI

³ See Section IV

⁴ See Section IV

IV. Toxicity Monitoring Requirements

A. Acute Toxicity Effluent Monitoring Program

1. The Discharger shall conduct acute toxicity tests on effluent grab samples by methods specified in 40 CFR Part 136 which cites U.S. EPA's *Methods for Measuring the Acute Toxicity of Effluents to Freshwater and Marine Organisms*, Fifth Edition, October, 2002 (EPA/821-R-02-012) or a more recent edition to ensure there is no toxicity in 100 % effluent, for discharges from Discharge Serial No. 001.
2. The fathead minnow, *Pimephales promelas*, shall be used as the test species for fresh water discharges and the topsmelt, *Atherinops affinis*, shall be used as the test species for brackish effluent. The method for topsmelt is found in U.S. EPA's *Short-term Method for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms*, First Edition, August 1995 (EPA/600/R-95/136).
3. In lieu of conducting the standard acute toxicity testing with the fathead minnow, the Discharger may elect to report the results or endpoint from the

first 48 hours of the chronic toxicity test as the results of the acute toxicity test.

4. Effluent samples shall be collected before discharge to the receiving water.

B. Chronic Toxicity Effluent Monitoring Program

1. The Discharger shall conduct critical life stage chronic toxicity tests on 24-hour composite 100 percent effluent samples in accordance with EPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Third Edition, July 1994 (EPA/600/4-91/002) or EPA's *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, Third Edition, October 2002, (EPA/821/R-02-014).
2. Effluent samples shall be collected after all treatment processes and before discharge to the receiving water.

Test Species and Methods:

- a. The Discharger shall conduct tests as follows: with a vertebrate, an invertebrate, and a plant for the first three suites of tests. After the screening period, monitoring shall be conducted using the most sensitive species.
- b. Re-screening is required every 15 months. The Discharger shall re-screen with the three species listed above and continue to monitor with the most sensitive species. If the first suite of re-screening tests demonstrates that the same species is the most sensitive than re-screening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity then the Discharger shall proceed with suites of screening tests for a minimum of three, but not to exceed five suites.
- c. The presence of chronic toxicity shall be estimated as specified using West Coast marine organisms according to EPA's *Short-Term Methods for Estimating Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms*, August, 1995 (EPA/600/R-95/136).

C. Quality Assurance

1. Concurrent testing with a reference toxicant shall be conducted. Reference toxicant tests shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
2. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the test methods manuals (EPA/821/R-02/013 and EPA/821-R-02-014), then the Discharger must re-sample and re-test at the earliest time possible.
3. Control and dilution water should be receiving water or laboratory water, as appropriate, as described in the manual. If the dilution water used is different from the culture water, a second control using culture water shall be used.

D. Accelerated Monitoring

1. If toxicity exceeds the limitations (as defined in Order No. R4-2005-XXXX, Sections I.B.4.a.1. and 1.B.4.b.1), then the Discharger shall immediately implement accelerated testing as specified in Sections I.B.4.a.2 and 1.B.4.b.2. The Discharger shall ensure that they receive results of a failing acute toxicity test within 24 hours of the close of the test and the additional tests shall begin within 3 business days of the receipt of the result. If the accelerated testing shows consistent toxicity, the Discharger shall immediately implement the Initial Investigation of the Toxicity Reduction Evaluation (TRE) Workplan.
2. If implementation of the initial investigation TRE Workplan indicates the source of toxicity (e.g., a temporary plant upset, etc.), then the Discharger may discontinue the Toxicity Identification Evaluation (TIE).
3. The first step in the initial Investigation TRE Workplan for downstream receiving water toxicity can be a toxicity test protocol designed to determine if the effluent from Discharge Serial No. 001 causes or contributes to the measured downstream chronic toxicity. If this first step TRE testing shows that the Discharge Serial No. 001 effluent does not cause or contribute to downstream chronic toxicity, using EPA' s Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms, August 1995, (EPA/600/R-95/136). Then a report on this testing shall be submitted to the Board and the TRE will be considered to be completed. Routine testing in accordance with MRP No. 7743 shall be continued thereafter.

E. Steps in TRE and TIE procedures:

1. Following a TRE trigger, the Discharger shall initiate a TRE in accordance with the facility's initial investigation TRE workplan. At a minimum, the Discharger shall use EPA manuals EPA/600/2-88/070 (industrial) or EPA/833B-99/002 (municipal) as guidance. The Discharger shall expeditiously develop a more detailed TRE workplan for submittal to the Executive Officer within 30 days of the trigger, which will include, but not be limited to:
 - a. Further actions to investigate and identify the cause of toxicity;
 - b. Actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity;
 - c. Standards the Discharger will apply to consider the TRE complete and to return to normal sampling frequency; and,
 - d. A schedule for these actions.
2. The following is a stepwise approach in conducting the TRE:
 - a. Step 1 - Basic data collection. Data collected for the accelerated monitoring requirements may be used to conduct the TRE:
 - b. Step 2 - Evaluates optimization of the treatment system operation, facility housekeeping, and the selection and use of in-plant process chemicals;
 - c. If Steps 1 and 2 are unsuccessful, Step 3 implements a TIE and employment of all reasonable efforts and using currently available TIE methodologies. The objective of the TIE is to identify the substance or combination of substances causing the observed toxicity;
 - d. Assuming successful identification or characterization of the toxicant(s), Step 4 evaluates final effluent treatment options;
 - e. Step 5 evaluates in-plant treatment options; and,
 - f. Step 6 consists of confirmation once a toxicity control method has been implemented.

Many recommended TRE elements parallel source control, pollution prevention, and storm water control program best management practices (BMPs). To prevent duplication of efforts, evidence of implementation of these control measures may be sufficient to comply with TRE requirements.

By requiring the first steps of a TRE to be accelerated testing and review of the facility's TRE workplan, a TRE may be ended in its early stages. All reasonable steps shall be taken to reduce toxicity to the required level. The TRE may be ended at any stage if monitoring indicates there is no longer toxicity (or six consecutive chronic toxicity results are less than or equal to 1.0 TU_c).

3. The Discharger may initiate a TIE as part of the TRE process to identify the cause(s) of toxicity. The Discharger shall use the EPA acute and chronic manuals, EPA/600/6-91/005F (Phase I)/EPA/600/R-96-054 (for marine), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III) as guidance.
4. If a TRE/TIE is initiated prior to completion of the accelerated testing schedule required by Part I.B.4.a.2 and Part I.B.4.b.2 of this permit, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer.
5. Toxicity tests conducted as part of a TRE/TIE may also be used for compliance, if appropriate.
6. The Board recognizes that toxicity may be episodic and identification of causes of and reduction of sources of toxicity may not be successful in all cases. Consideration of enforcement action by the Board will be based in part on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

F. Reporting

1. The Discharger shall submit a full report of the toxicity test results. Test results shall be reported as % survival with the discharge monitoring reports (DMR) for the month in which the test is conducted.
2. If an initial investigation indicates the source of toxicity and accelerated testing is unnecessary, then those results also shall be submitted with the DMR for the period in which the investigation occurred.
 - a. The full report shall be submitted on or before the end of the month in which the DMR is submitted.
 - b. The full report shall consist of (1) the results for each sample collected and (2) the dates of sample collection and initiation of each toxicity test.

3. Test results for toxicity tests also shall be reported according to the appropriate manual chapter on Report Preparation and shall be attached to the DMR. Routine reporting shall include, at a minimum, as applicable, for each test:
 - a. Sample date(s);
 - b. Test initiation date;
 - c. Test species;
 - d. End point values for each dilution (e.g., number of young, growth rate, percent survival);
 - e. NOEC value(s) in percent effluent;
 - f. IC₁₅, IC₂₅, IC₄₀ and IC₅₀ values in percent effluent;
 - g. TU_c values $\left(TU_c = \frac{100}{NOEC} \right)$;
 - h. Mean percent mortality (\pm standard deviation) after 96 hours in 100% effluent (if applicable);
 - i. NOEC and LOEC values for reference toxicant test(s);
 - j. C₂₅ value for reference toxicant test(s);
 - k. Any applicable charts; and
 - l. Available water quality measurements for each test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, ammonia).

V. Receiving Water Monitoring

Foothill is required to perform general observations of the receiving water when discharges occur and report the observations in the quarterly monitoring report. The receiving water monitoring program shall consist of periodic surveys of receiving water and shall include studies of those physical-chemical characteristics of the receiving water that may be impacted by the discharge.

Receiving Water Observations. General observations of the receiving water shall be made at each discharge point on a monthly basis and shall be reported in the quarterly monitoring report. If no discharge occurred during the observation period, this shall be reported.

Observations shall be descriptive where applicable, such that colors, approximate amounts, or types of materials are apparent. The following observations shall be made:

- a. Time, and date of monitoring

- b. Weather conditions
- c. Color of water
- d. Appearance of oil films or grease, or floatable materials
- e. Extent of visible turbidity or color patches
- f. Description of odor, if any, of the receiving water
- g. Presence and activity of California Least Tern and California Brown Pelican.

Further, quarterly monitoring for pH, dissolved oxygen, dissolved sulfide, and ammonia is required to determine compliance with receiving water limitations established in Section I.C.4 of Order No. R4-2005-XXXX.

In addition, according to the SIP, the Discharger is required to monitor the receiving water for the CTR priority pollutants, to determine reasonable potential. Accordingly, the Regional Board is requiring that the Discharger conduct annual receiving water monitoring for the CTR priority pollutants. Details of the monitoring requirements for CTR priority pollutants are discussed in Section VI.

VI. Intake Water Monitoring

The Discharger is required to monitor the intake water prior to entry into the power plant to provide data to characterize the influent. Further, to assess the viability of obtaining intake water credit for WQBELs, the proposed Order requires the Discharger to monitor the intake water annually for the CTR priority pollutants, as described in Section VII of this Monitoring and Reporting Program.

VII. Effluent, Receiving Water, and Intake Water Monitoring for Reasonable Potential Determination

- A. The SIP requires that the Regional Boards require periodic monitoring of effluent and receiving water for pollutants for which criteria or objectives apply and for which no effluent limitations have been established. Accordingly, the Regional Board is requiring that the Discharger conduct effluent and receiving water monitoring of the priority pollutants as listed below. Effluent samples shall be collected at Discharge Serial 001. Receiving water samples shall be collected upstream of the effluent discharge point in the receiving water outside the influence of the discharge. Where feasible receiving water sample should be collected 50 feet upstream from the point of discharge into Castaic Lake Afterbay.
- B. Sampling shall occur at the following locations:
 - Intake water location: As close as possible to the point of intake water, determined by the site conditions, with a footnote as to the sampling port

distance from the intake water point.

- Effluent discharge point: Discharge Serial No. 001 (Latitude 34° 30' 52" North, Longitude 118° 36' 29" West), prior to entry into the receiving water.
- Receiving water: The monitoring location shall be outside the influence of the discharge; where possible, at least 50 feet from the discharge location into the receiving water (Castaic Lake Afterbay).

The required monitoring frequency and type of sample for pH, hardness, salinity, and toxic pollutants are listed below.

Pollutant	Units	Type of Sample	Monitoring Frequency
pH	standard units	Grab	Annually ¹
Hardness (as CaCO ₃)	mg/L	Grab	Annually ¹
Salinity	g/L	Grab	Annually ¹
Antimony	µg/L	Grab	Annually
Arsenic ²	µg/L	Grab	Annually
Beryllium	µg/L	Grab	Annually
Cadmium ²	µg/L	Grab	Annually
Chromium (III) ²	µg/L	Grab	Annually
Chromium (VI) ²	µg/L	Grab	Annually
Copper ²	µg/L	Grab	Annually
Lead ²	µg/L	Grab	Annually
Mercury	µg/L	Grab	Annually
Nickel ²	µg/L	Grab	Annually
Selenium	µg/L	Grab	Annually
Silver ²	µg/L	Grab	Annually
Thallium	µg/L	Grab	Annually
Zinc ²	µg/L	Grab	Annually
Cyanide	µg/L	Grab	Annually
Asbestos	Fibers/L	Grab	Annually
Acrolein	µg/L	Grab	Annually
Acrylonitrile	µg/L	Grab	Annually
Benzene	µg/L	Grab	Annually
Bromoform	µg/L	Grab	Annually
Carbon tetrachloride	µg/L	Grab	Annually
Chlorobenzene	µg/L	Grab	Annually
Chlorodibromomethane	µg/L	Grab	Annually
Chloroethane	µg/L	Grab	Annually
2-Chloroethylvinyl ether	µg/L	Grab	Annually
Chloroform	µg/L	Grab	Annually
Dichlorobromomethane	µg/L	Grab	Annually
1,1-Dichloroethane	µg/L	Grab	Annually
1,2-Dichloroethane	µg/L	Grab	Annually
1,1-Dichloroethylene	µg/L	Grab	Annually
1,2-Dichloropropane	µg/L	Grab	Annually
1,3-Dichloropropylene	µg/L	Grab	Annually
Ethylbenzene	µg/L	Grab	Annually

Metropolitan Water District of Southern California – Foothill Feeder Power Plant CA0059641
 Monitoring and Reporting Program No. CI-6743

Pollutant	Units	Type of Sample	Monitoring Frequency
Methyl bromide	µg/L	Grab	Annually
Methyl chloride	µg/L	Grab	Annually
Methylene chloride	µg/L	Grab	Annually
1,1,2,2-Tetrachloroethane	µg/L	Grab	Annually
Tetrachloroethylene	µg/L	Grab	Annually
Toluene	µg/L	Grab	Annually
1,2-Trans-dichloroethylene	µg/L	Grab	Annually
1,1,1-Trichloroethane	µg/L	Grab	Annually
1,1,2-Trichloroethane	µg/L	Grab	Annually
Trichloroethylene	µg/L	Grab	Annually
Vinyl chloride	µg/L	Grab	Annually
2-Chlorophenol	µg/L	Grab	Annually
2,4-Dichlorophenol	µg/L	Grab	Annually
2,4-Dimethylphenol	µg/L	Grab	Annually
2-Methyl-4,6-dinitrophenol	µg/L	Grab	Annually
2,4-Dinitrophenol	µg/L	Grab	Annually
2-Nitrophenol	µg/L	Grab	Annually
4-Nitrophenol	µg/L	Grab	Annually
3-Methyl-4-chlorophenol	µg/L	Grab	Annually
Pentachlorophenol	µg/L	Grab	Annually
Phenol	µg/L	Grab	Annually
2,4,6-Trichlorophenol	µg/L	Grab	Annually
Acenaphthene	µg/L	Grab	Annually
Acenaphthylene	µg/L	Grab	Annually
Anthracene	µg/L	Grab	Annually
Benzidine	µg/L	Grab	Annually
Benzo(a)anthracene	µg/L	Grab	Annually
Benzo(a)pyrene	µg/L	Grab	Annually
Benzo(b)fluoranthene	µg/L	Grab	Annually
Benzo(g,h,i)perylene	µg/L	Grab	Annually
Benzo(k)fluoranthene	µg/L	Grab	Annually
Bis (2-chloroethoxy)methane	µg/L	Grab	Annually
Bis(2-chloroethyl)ether	µg/L	Grab	Annually
Bis (2-chloroisopropyl)ether	µg/L	Grab	Annually
Bis (2-ethylhexyl)phthalate	µg/L	Grab	Annually
4-Bromophenyl phenyl ether	µg/L	Grab	Annually
Butylbenzyl phthalate	µg/L	Grab	Annually
2-Chloronaphthalene	µg/L	Grab	Annually
4-Chlorophenyl phenyl ether	µg/L	Grab	Annually
Chrysene	µg/L	Grab	Annually
Dibenzo(a,h)anthracene	µg/L	Grab	Annually
1,2-Dichlorobenzene	µg/L	Grab	Annually
1,3-Dichlorobenzene	µg/L	Grab	Annually
1,4-Dichlorobenzene	µg/L	Grab	Annually
3,3'-Dichlorobenzidine	µg/L	Grab	Annually
Diethyl phthalate	µg/L	Grab	Annually
Dimethyl phthalate	µg/L	Grab	Annually

Pollutant	Units	Type of Sample	Monitoring Frequency
Di-n-Butyl phthalate	µg/L	Grab	Annually
2,4-Dinitrotoluene	µg/L	Grab	Annually
2,6-Dinitrotoluene	µg/L	Grab	Annually
Di-n-octyl phthalate	µg/L	Grab	Annually
1,2-Diphenylhydrazine	µg/L	Grab	Annually
Fluoranthene	µg/L	Grab	Annually
Fluorene	µg/L	Grab	Annually
Hexachlorobenzene	µg/L	Grab	Annually
Hexachlorobutadiene	µg/L	Grab	Annually
Hexachlorocyclopentadiene	µg/L	Grab	Annually
Hexachloroethane	µg/L	Grab	Annually
Indeno(1,2,3-cd)pyrene	µg/L	Grab	Annually
Isophorone	µg/L	Grab	Annually
Naphthalene	µg/L	Grab	Annually
Nitrobenzene	µg/L	Grab	Annually
N-Nitrosodimethylamine	µg/L	Grab	Annually
N-Nitrosodi-n-propylamine	µg/L	Grab	Annually
N-Nitrosodiphenylamine	µg/L	Grab	Annually
Phenanthrene	µg/L	Grab	Annually
Pyrene	µg/L	Grab	Annually
1,2,4-Trichlorobenzene	µg/L	Grab	Annually
Aldrin	µg/L	Grab	Annually
alpha-BHC	µg/L	Grab	Annually
beta-BHC	µg/L	Grab	Annually
Gamma-BHC	µg/L	Grab	Annually
delta-BHC	µg/L	Grab	Annually
Chlordane	µg/L	Grab	Annually
4,4'-DDT	µg/L	Grab	Annually
4,4'-DDE	µg/L	Grab	Annually
4,4'-DDD	µg/L	Grab	Annually
Dieldrin	µg/L	Grab	Annually
alpha-Endosulfan	µg/L	Grab	Annually
beta-Endosulfan	µg/L	Grab	Annually
Endosulfan sulfate	µg/L	Grab	Annually
Endrin	µg/L	Grab	Annually
Endrin aldehyde	µg/L	Grab	Annually
Heptachlor	µg/L	Grab	Annually
Heptachlor epoxide	µg/L	Grab	Annually
PCBs – sum ³	µg/L	Grab	Annually
Toxaphene	µg/L	Grab	Annually

¹ Monitoring for pH, salinity, and hardness is required for receiving water only.

² Measured as total recoverable.

³ PCBs sum refers to sum of PCB Aroclors 1016, 1221, 1232, 1242, 1248, 1254, and 1260.

C. In accordance with Section 3 of the SIP, the Discharger is also required to conduct effluent and receiving water monitoring for the presence of the 2,3,7,8-tetrachlorodibenzo-p-dioxin (TCDD or Dioxin) congeners. Also, in order to assess

the viability of giving intake water credit to the facility to potential TCDD exceedances, TCDD monitoring is required for the intake water. The monitoring shall be a grab sample twice during the permit term (once during the 2nd year of the permit and once during the 4th year). The SIP requires monitoring for 2,3,7,8-TCDD and the 16 congeners listed in the Table below. The Discharger is required to calculate Toxic Equivalence (TEQ) for each congener by multiplying its analytical concentration by the appropriate Toxicity Equivalence Factors (TEF) provided below.

Congeners	TEF
2,3,7,8-tetra CDD	1.0
1,2,3,7,8-penta CDD	1.0
1,2,3,4,7,8-hexa CDD	0.1
1,2,3,6,7,8-hexa CDD	0.1
1,2,3,7,8,9-hexa CDD	0.1
1,2,3,4,6,7,8-hepta CDD	0.01
Octa CDD	0.0001
2,3,7,8-tetra CDF	0.1
1,2,3,7,8-penta CDF	0.05
2,3,4,7,8-penta CDF	0.5
1,2,3,4,7,8-hexa CDF	0.1
1,2,3,6,7,8-hexa CDF	0.1
1,2,3,7,8,9-hexa CDF	0.1
2,3,4,6,7,8-hexa CDF	0.1
1,2,3,4,6,7,8-hepta CDF	0.01
1,2,3,4,7,8,9-hepta CDF	0.01
Octa CDF	0.0001

- D. The reports for this required monitoring must be submitted separately from the self-monitoring reports, but in accordance with the quarterly reporting schedule provided in Section I.A. The reports shall reference “Monitoring Results for CTR Priority Pollutants Reasonable Potential Determination, NPDES Permit No. CA0059641, CI-6743”.
- E. SWRCB-approved laboratory methods and the corresponding MLs for the examination of each priority pollutant are listed in Attachment B. Reporting requirements for the data to be submitted are listed in Attachment C. The Regional Board recommends that an analytical method be selected from Attachment A which is capable of achieving the lowest ML for each pollutant as listed on Attachment B. ML is necessary for determining compliance for a priority pollutant when an effluent limit is below the MDL.
- F. The laboratory analytical data shall include applicable MLs, MDL, quality assurance/quality control data, and shall comply with the reporting requirements contained in the Attachments B & C.

- G. Forward all interim monitoring data/reports to The Regional Board, Attn: Industrial Permitting Unit, and please include a reference to “Compliance File No. 6743, NPDES No. CA0059641.”

Ordered by: _____
Jonathan S. Bishop
Executive Officer

Date: May 5, 2005