

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
PMG TIFFANY LTD
(Tiffany Court Apartments)
NPDES NO. CAG994004
CI-6749

FACILITY LOCATION

616 S. Masselin Avenue
 Los Angeles, CA 90036

FACILITY MAILING ADDRESS

22055 Clarendon Street, #200
 Woodland Hills, CA 91367

PROJECT DESCRIPTION

The subject site is an apartment building located at 616 S. Masselin Avenue, Los Angeles, California. General NPDES Permit No. CAG994001, Order No. 97-045, was issued to the subject facility on June 30, 1997 for dewatering activity from the subterranean parking garage. On October 17, 2002, PMG Tiffany Ltd (PMG) submitted a Notice of Intent (NOI) form to continue enrollment under General Permit No. CAG994004, Order No. R4-2003-0111, adopted by this Board on August 7, 2003.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 15,000 gallons per day of groundwater is discharged to the storm drain located at Latitude 34°03'51", Longitude 118°21'07", thence to Ballona Creek, a water of the United States. The site location map is shown as Figure 1.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the table below have been determined to show reasonable potential to exist in the discharge. The dewatering discharge flows into Ballona Creek, therefore, the discharge limitations in Attachment B are not applicable to the discharge.

This table lists the specific constituents and effluent limitations applicable to your discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	
Phenols	mg/L	1.0	
Residual Chlorine	mg/L	0.1	
Methylene Blue Active Substances (MBAS)	mg/L	0.5	

REQUENCY OF DISCHARGE

The discharge is continuous and is expected to continue throughout the life of the building.

REUSE OF WATER

Due to lack of landscaped area at the site, there are no other feasible reuse options for the discharge. Therefore, the wastewater will be discharged to the storm drain.