

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD —  
LOS ANGELES REGION**101 CENTRE PLAZA DRIVE  
MONTEREY PARK, CA 91754-2156  
(213) 266-7500

August 3, 1992

Mr. John Dahl  
Nolte and Associates  
5473 Kearny Villa Road, Suite 300  
San Diego, CA 92123**WASTE DISCHARGE REQUIREMENTS - U. S NAVY, NORTH ISLAND NAVAL AIR  
STATION, SAN CLEMENTE ISLAND (FILE NO. 91-75)**

Our letter dated June 23, 1992, transmitted copies of tentative Waste Discharge Requirements for waste discharge from the above project.

Pursuant to Division 7 of the California Water Code, this California Regional Water Quality Control Board, at a public meeting held on July 20th, 1992, reviewed the tentative Waste Discharge Requirements, considered all factors in the case, and adopted Order No 92-48 (copy attached), relative to this waste discharge.


<u>Project</u>	<u>File No.</u>	<u>Order No.</u>	<u>Monitoring Program No.</u>
North Island Naval Air Station	91-75	92-48	7182

You are required to implement Monitoring and Reporting Program No. 7182 on the effective date of the Order. Your first monitoring report is due the first quarter after commencement of discharge. All Monitoring reports should be sent to the Regional Board, Attn: Technical Support Unit.

Please reference all technical and monitoring reports to our Compliance File No. 7182. We would appreciate it if you would not combine other reports with your monitoring reports.

As the Board adopted the tentative Waste Discharge Requirements with a minor change, we are sending a final copy of the Waste Discharge Requirements to the entire mailing list. The change occurs on page 2, A, 2. The sentence "Any septage handling shall be in such a manner as to prevent waste from reaching surface waters or watercourses." was deleted at the end of the paragraph.

If you have any questions, please call Mr. Magdy Baiady at (213) 266-7586.



ANNE SAFFELL, Chief  
Ground Water Unit

cc: See attached mailing list

Mr. J. Dahl  
Page 2

Mailing List

State Water Resources Control Board, Division of Water  
Quality, Attn: Archie Matthews  
State Water Resources Control Board, Office of Chief Counsel,  
Attn: Jorge Leon  
Department of Water Resources  
Department of Health Services, Public Water Supply Branch,  
Attn: Gary Yamamoto  
South Coast Air Quality Management District  
Los Angeles County, Department of Regional Planning  
Los Angeles County, Department of Health Services, Environmental  
Health - Health Facilities  
Los Angeles County, Department of Public Works, Waste Management  
Division

mb/navy-wdr.let

State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD, LOS ANGELES REGION

ORDER NO. 92-48

WASTE DISCHARGE REQUIREMENTS  
FOR

U.S. DEPARTMENT OF THE NAVY  
NORTH ISLAND NAVAL AIR STATION  
(P-180 Maritime Facility) - SAN CLEMENTE ISLAND  
(File No. 91-75)

The California Regional Water Quality Control Board, Los Angeles Region, finds:

1. U.S. Department of the Navy, North Island, Naval Air Station, San Diego, (hereinafter called the Discharger) has filed a Report of Waste Discharge for disposal of domestic wastes.
2. The Discharger proposes to construct a P-180 Maritime facility, housing 70 persons for weekend training, on the north end of San Clemente Island, Los Angeles County. The site is not served by a community sewer system.
3. The domestic wastes generated on-site will be discharged through a septic tank/leach field system. The system consists of a 6,000-gallon capacity septic tank and a leach field. The maximum capacity of the leach field is 5,800-gallons per day.
4. The facility is within the San Clemente Island Hydrologic Area which is in the San Pedro Channel Island Hydrologic Unit of Los Angeles River Basin.
5. There is no identified ground water in the San Clemente Island Hydrologic Area.
6. The Board adopted a revised Water Quality Control Plan for the Los Angeles River Basin on June 3, 1991, and identifies ocean waters surrounding San Clemente Island as an Area of Special Biological Significance (ASBS). There are no expected water quality impacts on this ASBS from the proposed discharge.
7. This project will result in a minor alteration to land and, as such, is exempt from the requirements of the California Environmental Quality Act (Public Resources Code, commencing with Section 21100) in accordance with Section 15304, Chapter 3, Title 14, of the California Code of Regulations.

The Board has notified the Discharger and interested agencies and persons of its intent to adopt Waste Discharge Requirements for this subsurface sewage disposal project, and has provided them with an opportunity to submit their written views and recommendations.

The Board, in a public meeting, heard and considered all comments pertaining to the discharge and the tentative requirements.

IT IS HEREBY ORDERED that the U.S. Department of the Navy, North Island Naval Air Station, shall comply with the following:

A. DISCHARGE PROHIBITIONS

1. Wastes discharged shall be limited to domestic sewage only; no industrial wastes shall be discharged at this location.
2. There shall be no on-site disposal of septage. Any off-site disposal of septage shall be made only to a legal point of disposal. For purposes of these requirements, a legal disposal site is one for which requirements have been established by a California Regional Water Quality Control Board and which is in full compliance therewith.

B. WASTE DISCHARGE REQUIREMENTS


1. No part of the seepage pit or leach field system shall be closer than 150 feet to any water well, or closer than 100 feet, to any stream, channel or other watercourse.
2. Neither the treatment nor the discharge of waste shall create a condition of pollution, contamination, or nuisance.
3. Wastes discharged shall at no time contain any substance in concentrations toxic to human, plant, or aquatic life.
4. The seepage pit or leach field system shall be maintained in such a manner that at no time will sewage be permitted to surface or overflow at any location.
5. The seepage pit or leach field system shall be protected from damage by storm flows or runoff.

6. Odors of sewage origin shall not be perceivable beyond the limits of the property owned or controlled by the Discharger.
7. Wastes shall not be disposed of in geologically unstable areas or so as to cause earth movement.

C. PROVISIONS

1. The Discharger shall submit as-built construction and operation details of the septic tank/leach field system to the Board for review within 90 days after the system is in place if the system is different from the one specified in the Report of Waste Discharge.
2. This Order includes "Standard provisions applicable to Waste Discharge Requirements".

I, Robert P. Ghirelli, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region on July 20, 1992.

  
\_\_\_\_\_  
ROBERT P. GHIRELLI, D.Env.  
Executive Officer

State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD, LOS ANGELES REGION

MONITORING AND REPORTING PROGRAM NO. 92-48

FOR

U.S. DEPARTMENT OF THE NAVY  
NORTH ISLAND, NAVAL AIR STATION  
(P-180 Maritime Facility)  
(File No. 91-75)

The Discharger shall implement this monitoring program on the effective date of this Order. The first Monitoring report under this program is due by January 15, 1993. Subsequent monitoring reports shall be submitted by the dates in the following schedule:

<u>Reporting Period</u>	<u>Report Due</u>
January - June	July 15
July - December	January 15

The reports shall contain the following information:

- a. The average and maximum quantity of discharge for each month of the quarter, in gallons per day. ✓
- b. Estimated population served during each month of the reporting period.
- c. A statement relative to compliance with discharge specifications during the period report.
- d. If septage is hauled to a legal disposal site, the name and address of the hauler of the septage shall be reported, along with the quantity hauled during the reporting period and the location of the final point of disposal. If no wastes are hauled during the reporting period a statement to that effect shall be submitted and shall include a statement relative to disposal of septage during the period.

GENERAL PROVISIONS FOR REPORTING

For every item where the requirements are not met, the Discharger shall submit a statement of the actions undertaken, or proposed, which will bring the discharge into full compliance with requirements at the earliest time. The Discharger must also submit a timetable for correction.

U.S. Navy  
San Clemete Island

File No. 91-75

These records and reports are public documents and shall be made available for inspection during business hours at the office of the California Regional Water Quality Control Board, Los Angeles Region.

Ordered by Robert P. Ghirelli  
ROBERT P. GHIRELLI, D.Env.  
Executive Officer

Date: July 20, 1992

CS 7182

August 3, 1992

Mr. John Dahl  
Nolte and Associates  
5473 Kearny Villa Road, Suite 300  
San Diego, CA 92123

**WASTE DISCHARGE REQUIREMENTS - U. S NAVY, NORTH ISLAND NAVAL AIR STATION, SAN CLEMENTE ISLAND (FILE NO. 91-75)**

Our letter dated June 23, 1992, transmitted copies of tentative Waste Discharge Requirements for waste discharge from the above project.

Pursuant to Division 7 of the California Water Code, this California Regional Water Quality Control Board, at a public meeting held on July 20th, 1992, reviewed the tentative Waste Discharge Requirements, considered all factors in the case, and adopted Order No 92-48 (copy attached), relative to this waste discharge.

<u>Project</u>	<u>File No.</u>	<u>Order No.</u>	<u>Monitoring Program No.</u>
North Island Naval Air Station	91-75	92-48	7182

You are required to implement Monitoring and Reporting Program No. 7182 on the effective date of the Order. Your first monitoring report is due the first quarter after commencement of discharge. All Monitoring reports should be sent to the Regional Board, Attn: Technical Support Unit.

Please reference all technical and monitoring reports to our Compliance File No. 7182. We would appreciate it if you would not combine other reports with your monitoring reports.

As the Board adopted the tentative Waste Discharge Requirements with a minor change, we are sending a final copy of the Waste Discharge Requirements to the entire mailing list. The change occurs on page 2, A, 2. The sentence "Any septage handling shall be in such a manner as to prevent waste from reaching surface waters or watercourses." was deleted at the end of the paragraph.

If you have any questions, please call Mr. Magdy Baiady at (213) 266-7586.

ANNE SAFFELL, Chief  
Ground Water Unit



John Dahl  
Mailing List

State Water Resources Control Board, Division of Water  
Quality; Attn: Archie Matthews  
State Water Resources Control Board, Office of Chief Counsel;  
Attn: Jorge Leon  
Department of Water Resources  
Department of Fish and Game, Region 5  
Department of Health Services, Sanitary Engineering Section  
U.S. Army Corps of Engineers  
U.S. Coast Guard  
Department of Public Works, Waste Management Division  
Los Angeles City Fire Department, Engineering Unit; Attn:  
Captain John Hall

cc: See attached mailing list

Mailing List

State Water Resources Control Board, Division of Water  
Quality, Attn: Archie Matthews  
State Water Resources Control Board, Office of Chief Counsel,  
Attn: Jorge Leon  
Department of Water Resources  
Department of Health Services, Public Water Supply Branch,  
Attn: Gary Yamamoto  
South Coast Air Quality Management District  
Los Angeles County, Department of Regional Planning  
Los Angeles County, Department of Health Services, Environmental  
Health - Health Facilities  
Los Angeles County, Department of Public Works, Waste Management  
Division

mb/navy-wdr.let