

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
CBS, INC. (TELEVISION CITY)**

**NPDES NO. CAG994004  
CI-7275**

**FACILITY ADDRESS**

7800 Beverly Boulevard  
Los Angeles, California

**FACILITY MAILING ADDRESS**

7800 Beverly Boulevard  
Los Angeles, California

**PROJECT DESCRIPTION:**

CBS Inc. (Discharger) operates Television City, a television program production facility, located at 7800 Beverly Boulevard, Los Angeles (See Figure 1 for site location) and discharges groundwater seepage from the facility's footing drainage under general NPDES permit No. CAG994001. The dewatering is necessary to protect the integrity of the building structure from rising groundwater. The Discharger submitted a complete Notice of Intent Form on November 12, 2004 to apply for continuing enrollment under the general NPDES permit.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Up to 30,000 gallons per day of groundwater will be discharged from the project site. The groundwater will be discharged to Outfall No. 1 (Latitude: 34° 02' 17", Longitude: 118° 22' 07"), which flows to Ballona Creek, a water of the United States.

**APPLICABLE EFFLUENT LIMITATIONS**

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the Table below have been determined to show reasonable potential to exist in the discharge. The groundwater discharge flows into Ballona Creek, which is designated as MUN (Potential) beneficial use. Therefore, the discharge limitations under the "Other Waters" column in Provision E of the permit are applicable. According to Attachment B of the permit, waterbody specific discharge limitations are not applicable to the discharge.

December 28, 2004

This Table lists the specific constituents and effluent limitations applicable to your discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD <sub>5</sub> 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	N/A
Phenols	mg/L	1.0	N/A
Residual Chlorine	mg/L	0.1	N/A
Methylene Blue Active Substances (MBAS)	mg/L	0.5	N/A

**FREQUENCY OF DISCHARGE:**

The groundwater discharge is continuous and will last throughout the life of the building.

**REUSE OF WATER:**

Offsite disposal of the groundwater is not feasible due to the high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation using the groundwater discharge. Since there are no other feasible reuse options, most of the groundwater generated from the construction will be discharged to the storm drain.