

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

101 CENTRE PLAZA DRIVE
MONTEREY PARK, CA 91754-2156
(213) 266-7500
FAX: (213) 266-7600



October 15, 1996

Mr. Gerald Biggers
Oceanview Produce Co.
3000 E. Hueneme Road
P.O. Box 2887
Oxnard, CA 93034

SUBJECT: GENERAL WASTE DISCHARGE REQUIREMENTS FOR SPECIFIED DISCHARGE TO GROUNDWATER FOR OCEANVIEW PRODUCE COMPANY, 3000 E. HUENEME ROAD, OXNARD, CALIFORNIA [File NO. 92-060(10), CI NO. 7713]

We have completed our review of your Report of Waste Discharge to discharge wastewater under Waste Discharge Requirements.

Oceanview Produce Company plans to discharge 500 to 1100 gallons per week of clarified rinsewater for dust control on roads. Farm equipment and vehicles, no engines or engine parts, are rinsed with potable water. The potable water is supplied by the City of Oxnard. No soap or cleaning agents are added to the rinsewater which drains and is stored in a three-stage, 750 gallon concrete clarifier. A small spray system will be used for a few minutes each week to apply the rinsewater to agricultural roads or a dedicated area of adjacent agriculture land.

We have reviewed the information provided and determined that the proposed discharge of the clarified rinsewater meets the conditions specified in Order No. 93-010, "General Waste Discharge Requirements for Specific Discharges to Groundwater in Santa Clara River and Los Angeles River Basins", adopted by this Regional Board on January 25, 1993.

Enclosed are your General Waste Discharge Requirements and Monitoring and Reporting Program. These requirements are applicable to only the proposed waste discharge as described above.

The project is located in the Oxnard Hydrologic Subarea within the Oxnard Plain Hydrologic Area of the Santa Clara-Calleguas Hydrologic Unit, Attachment A, Table 1. Water quality objectives listed in the Oxnard Plain are applicable to your discharge. The Discharger may submit potable water quality data for the clarified rinsewater from the local water supplier in the area of discharge in lieu of the water analysis for pollutants listed in the Attachment B. Before commencing any discharge a representative sample shall be taken and analyzed to determine compliance with the discharge limitations.


Any permit that may be required by the State or other local agencies must be obtained prior to start of the discharge.

Mr. Gerald Biggers
October 15, 1996
Page 2

The "Monitoring and Reporting Program" requires you to implement the monitoring program on the effective date of this Order. Monitoring reports shall be submitted within 30 days following the sampling. All monitoring reports should be sent to the Regional Board, ATTN: Technical Support Unit. Please reference all technical and monitoring reports to our compliance File No. 7713. We would appreciate if you would not combine other reports but would submit each type of report as a separate document.

We are sending Board Order No. 93-010 only to the applicant. For those on the mailing list, Please refer to the Board Order previously sent to you on February 2, 1993. A copy of the Order will be furnished to anyone who requests it.

If you have any questions, please contact Deborah Boadway at (213)266-7565.



ROBERT P. GHIRELLI, D.Env.
Executive Officer

Enclosures

cc: John Youngermen, Division of Water Quality, State Water Resources Control Board
Jorge Leon, Office of Chief Counsel, State Water Resources Control Board
Ahmad Hassan, Department of Water Resources, Southern District
Ventura County Department of Environmental Health
City of Oxnard (copy enclosed)

STATE OF CALIFORNIA
LOS ANGELES REGIONAL WATER QUALITY CONTROL BOARD

MONITORING AND REPORTING PROGRAM NO. 7713
FOR
GENERAL WASTE DISCHARGE REQUIREMENTS
FOR SPECIFIED DISCHARGES TO GROUNDWATER
IN
THE SANTA CLARA AND LOS ANGELES RIVER BASINS

OCEANVIEW PRODUCE COMPANY
[Order No. 93-010]
[File No. 92-060(10)]

The Discharger shall implement this monitoring and reporting program on the effective date of this program. Monitoring reports shall be submitted within 30 days following each sampling period. The semi-annual sampling shall be conducted between January through March and July through September.

II. Effluent Monitoring

The project is located in the Oxnard Hydrologic Subarea within the Oxnard Plain Hydrologic Area of the Santa Clara-Calleguas Hydrologic Unit.

Representative samples shall be analyzed, and the test results must meet all discharge limitations of Order 93-010 (Attachment A, Table 1, and Attachment B).

A sampling station shall be established for each point of discharge and shall be located where representative samples of that effluent can be obtained. The following shall constitute the effluent monitoring program:

1. For Attachment A, Table 1

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Frequency of analysis</u>
Total waste flow	gal/day	-----	-----
pH	°F	grab	semi-annually
Total dissolved solids	mg/L	grab	semi-annually
Chloride	mg/L	grab	semi-annually
Sulfate	mg/L	grab	semi-annually
Boron	mg/L	grab	semi-annually
Oil and grease	mg/L	grab	semi-annually

General Waste Discharge Requirements
Specified Discharges to Groundwater
Oceanview Produce Company, City of Oxnard
Monitoring and Reporting Program No. 7713

Order NO. 93-010

2. For Attachment B.

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum frequency of analysis</u>
All priority pollutants listed in attachment B	mg/L	grab	one-time analysis

Ordered by:

Robert P. Ghirelli
ROBERT P. GHIRELLI, D.Env.
Executive Officer

Date: October 15, 1996

/DXB