

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 9001**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF SAN BUENAVENTURA
(Ventura Water Reclamation Facility)**

**NPDES NO. CAG994001
CI-8208**

FACILITY ADDRESS

City of San Buenaventura
Ventura Water Reclamation Facility
1400 Spinnaker Drive
Ventura, California 93002

FACILITY MAILING ADDRESS

City of San Buenaventura
Ventura Water Reclamation Facility
PO Box 99
Ventura, California 93002-0099

PROJECT DESCRIPTION:

The City of San Buenaventura proposes to construct a new sewer lift station wet well and manhole at 1400 Spinnaker Drive, Ventura, California. During construction, groundwater will be extracted from dewatering wells, treated, and then discharged to a storm drain located at the intersection of Angler Road and Spinnaker Drive.

The proposed treatment system consists of a baffled desanding tank which shall provide more than five minutes detention time, and shall have a "flow through" velocity not exceeding 0.2 feet per second at the anticipated peak flow.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 0.97 million gallons per day (mgd) of treated wastewater will be discharged to a catch basin located at the intersection of Spinnaker Drive and Angler Road in Ventura (Latitude 34°24' and Longitude 119°26'). The wastes flow to the Ventura Keys, a water of the United States.

FREQUENCY OF DISCHARGE:

The discharge will be continuous and is expected to last for six months.

REUSE OF WATER:

Reuse of the groundwater is not feasible because reclaimed water is already being used for landscape irrigation and dust control in the nearby area.