

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF LOS ANGELES DEPARTMENT OF WATER AND POWER
(Sepulveda Trunk Line Project)**

**NPDES NO. CAG994002
CI-8269**

PROJECT LOCATION

Rinaldi Street and Haskell Avenue
Sylmar, CA 91345

FACILITY MAILING ADDRESS

111 N. Hope Street, Room 1213
Los Angeles, CA 90012

PROJECT DESCRIPTION

City of Los Angeles Department of Water and Power (LADWP) proposes to install new drinking water lines in the San Fernando Valley. During construction, dewatering is anticipated on Rinaldi Street and Haskell Avenue in the Sylmar area. LADWP proposes to store the groundwater in settling tanks and to analyze the groundwater prior to discharge into the storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE

LADWP will discharge up to 0.583 million gallons per day (mgd) of groundwater during the construction project. The water will be discharged into a storm drain on Sepulveda Boulevard (Latitude 34° 16' 18", Longitude 118° 28' 33") into Pacoima Wash, thence to the Los Angeles River, a water of the United States.

FREQUENCY OF DISCHARGE

The discharge will be intermittent and will begin in September 2001. The construction project will be completed in December 2002.

REUSE OF WATER

There are no feasible reuse options for the discharge. The project takes place wholly within City streets.