

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
ADAMS RANCH MUTUAL WATER COMPANY  
(Well No. 3 Development Project)**

**NPDES NO. CAG994001  
CI-8286**

**PROJECT LOCATION**

9246 Lower Azusa Road  
Rosemead, CA 91770

**FACILITY MAILING ADDRESS**

P.O. Box 6841  
Rosemead, CA 91770

**PROJECT DESCRIPTION**

Adams Ranch Mutual Water Company (ARMWC) proposes to install a domestic water well (Well No.3) in the City of Rosemead. ARMWC proposes to discharge the groundwater associated with the development of the well to Eton Wash. The water will be stored in a Baker tank and analyzed prior to discharge. The analytical data of groundwater samples collected for NPDES permit application indicated that concentrations of pollutants of concern are below "Daily Maximum" levels specified in Attachment B of Order No. 97-045. Therefore, the discharger is not required to monitor for pollutants of concern specified in Attachment B of Order No. 97-045.

**VOLUME AND DESCRIPTION OF DISCHARGE**

Up to 0.432 million gallons per day (mgd) of the well development water will be discharged. The well development water will be discharged through an outfall located at (Latitude 34° 4' 30", Longitude 117° 53'0") into Eton Wash, thence to San Gabriel River, a water of the United States.

**FREQUENCY OF DISCHARGE**

The discharge will be intermittent and is proposed to begin in June 2001.

**REUSE OF WATER**

There are no feasible reuse options for the discharge. This is a short duration discharge that will last for approximately one week.