

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 WEST 4TH STREET, SUITE 200, LOS ANGELES, CALIFORNIA 90013

FACT SHEET
FOR
DOYNE ROAD ASSOCIATES – KINNELOA MESA HOMES
(TRACT 44323)
(FILE NO. 01-065)

FACILITY ADDRESS

Parcel No. 5860-024-008
Kinneloa Mesa Area
Pasadena, CA

FACILITY MAILING ADDRESS

2250 East Imperial Highway
El Segundo, CA 90245

PROJECT DESCRIPTION:

Tract 44323 has a total area of 13.4 acres. The developer, Doyne Road Associates, proposed to install 8 septic tanks with capacities of either 1200 gallons or 1500 gallons for the 8 lots in the subject tract. Domestic wastewater from lots 1, 2, 3, 4, 5, 6, 7, and 8 will be discharged into seepage pits from septic tanks.

VOLUME AND DESCRIPTION OF DISCHARGE:

An average of 2400 gallons per day of domestic wastes will be discharged to an on-site sewage disposal system (based on the assumption of 300 gallons per day per house) located at the end of Doyne Road via New York Drive and Kinneloa Mesa Drive, Pasadena, CA 91107 (Latitude 34° 30' 00" N, Longitude 118° 05' 30" W). The on-site sewage disposal system consists of septic tanks and seepage pits.

July 30, 2001