

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
ARCO TERMINAL SERVICES CORPORATION
(HATHAWAY TERMINAL)

NPDES NO. CAG674001
CI-8306

FACILITY ADDRESS

2350 Hathaway Avenue
Signal Hill, CA

FACILITY MAILING ADDRESS

2350 Hathaway Avenue
Signal Hill, CA 90806

PROJECT DESCRIPTION:

Arco Terminal Services Corporation (Arco) proposes to discharge hydrostatic test water from Tank No. 104 located at Hathaway Terminal, 2350 Hathaway Avenue, Signal Hill. The hydrostatic testing will be conducted after the tank upgrade. Arco will use potable water supplied by the City of Long Beach.

VOLUME AND DESCRIPTION OF DISCHARGE:

A total of approximately 4.2 million gallons of hydrostatic water will be discharged into the storm drain located at the northeast corner of the property (Latitude: 33° 47' 30", Longitude: 118° 08' 37"). The discharge will occur over a period of six days at a rate of up to 0.7 million gallons per day. Discharge to the storm drain flows to the Los Angeles County Flood Control Channel thence to the Los Cerritos Channel, a water of the United States. Los Cerritos Channel is a part of Miscellaneous Los Angeles County Coastal Streams Watershed. The site vicinity map and the site plan location are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge will be intermittent. Arco expects to begin hydrostatic testing in August 2001.

REUSE OF WATER:

The reuse of hydrostatic test water at the facility was evaluated. Only a very small portion of water can be used for irrigation. Therefore, the majority of the hydrostatic test water will be discharged into the storm drain.