

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
KINDER MORGAN LIQUID TERMINALS, LLC,
CARSON TERMINAL

NPDES NO. CAG674001
CI-8323

FACILITY ADDRESS

Carson Terminal
2000 E. Sepulveda Blvd.
Carson, CA 90810

FACILITY MAILING ADDRESS

Kinder Morgan Liquid Terminals
Carson Terminal
Carson, CA 90810

PROJECT DESCRIPTION

Kinder Morgan Liquid Terminals, LLC proposes to hydrostatically test a 72,000-barrel oil tank with municipal water after the tank is refurbished and cleaned. The test water will be discharged to above-ground irrigation piping and routed via temporary piping to a storm drain.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 750,000 gallons per day of test water (for a total of approximately 3 million gallons) will be discharged. The discharge will be directly into the storm drain (Latitude: 33° 48' 40"N, Longitude: 118° 13' 30"W). The storm drain discharges to the Dominguez Channel, a water of the United States. The facility and the discharge routing are shown on Figure 1, attached.

Prior to commencing discharge, a representative sample of the effluent will be collected and analyzed, and test results must meet all discharge limitations in Part E, and Attachment B of Order No. 97-047.

FREQUENCY OF DISCHARGE

Discharge will occur one time.

REUSE OF WATER

This is a one-time discharge of hydrostatic test water; thus there is no feasible reuse option for the water at the site.