

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles
FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
PLEASANT VALLEY RECREATION & PARK DISTRICT
(Maintenance Facility, Camarillo)

NPDES NO. CAG834001
CI-8345

PROJECT LOCATION

380 Skyway Drive
Camarillo, CA 93010

FACILITY MAILING ADDRESS

1605 E. Burnley Street
Camarillo, CA 93010

PROJECT DESCRIPTION

The maintenance facility located at 380 Skyway Drive, Camarillo is owned and operated by Pleasant Valley Recreation & Park District (The District). Shallow groundwater beneath the site is contaminated with a plume of petroleum hydrocarbon. The subject site is currently under the oversight of Ventura County Environmental Health Division for remediation of impacted groundwater. The District will be operating a groundwater extraction system through on-site groundwater monitoring wells. The extracted groundwater will be treated and polished through a series of two canisters containing granular activated carbon (GAC) prior to discharge into the storm channel.

VOLUME AND DESCRIPTION OF DISCHARGE

The District will discharge up to 2,880 gallons per day of treated groundwater. The water will be discharged into a storm channel which flows into Revolon Slough (Latitude 34°12' 35", Longitude 119°04' 58") thence to Calleguas Creek, a water of the United States. The site location and the schematic of waste flow diagrams are shown as Attachments I and II, respectively.

FREQUENCY OF DISCHARGE

The groundwater remedial activity is scheduled to begin in December 2001. The discharge will be continuous.

REUSE OF WATER

Although the flow rate is relatively low, the Sanitation District is reluctant to accept the discharge when a storm channel is nearby the site. Due to lack of landscaping area at the site, there are no feasible reuse options for the discharge.