

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
HBI, INC.  
(Home Depot Store Construction Project)**

**NPDES NO. CAG994001  
CI-8352**

**PROJECT LOCATION**

401 West Ventura Boulevard  
Camarillo, CA 93010

**FACILITY MAILING ADDRESS**

4921 Birch Street  
Newport Beach, CA 92660

**PROJECT DESCRIPTION**

HBI, Inc. proposes to construct a Home Depot Store in the City of Camarillo. Dewatering is anticipated during the construction activities. HBI, Inc. proposes to store the extracted groundwater in desilting tanks, and to analyze the groundwater prior to discharge into the Camarillo Hills storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

HBI, Inc. will discharge up to 26,000 gallons per day (gpd) of groundwater. The water will be discharged into storm drain (Latitude 34° 12' 45", Longitude 119° 4' 45") which flows into Revolon Slough, thence into Calleguas Creek, a water of the United States. The site location is shown as Attachment I.

**FREQUENCY OF DISCHARGE**

The discharge will be intermittent and will begin in January 2002. The construction project will last approximately three months.

**REUSE OF WATER**

Some of the groundwater will be used during construction for activities such as dust control and compaction. There are no other feasible reuse options for the groundwater, therefore, majority of the groundwater will be discharged to the storm drain.