

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
CITY OF BEVERLY HILLS  
(Beverly Canon Parking & Retail Project)**

**NPDES NO. CAG994001  
CI-8411**

**PROJECT LOCATION**

438 N. Beverly Drive  
Beverly Hills, CA 90210

**FACILITY MAILING ADDRESS**

455 N. Rexford Drive  
Beverly Hills, CA 90210

**PROJECT DESCRIPTION**

City of Beverly Hills (the City) proposes to construct a subterranean parking garage with commercial/retail above the parking structure. Dewatering is anticipated during the construction activities. The City proposes to store the extracted groundwater in a settling tank. Groundwater samples will be taken from the settling tank for analyses prior to discharge to the storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

The City will discharge up to 70,000 gallons per day (gpd) of groundwater. The water will be discharged to a storm drain at Beverly Drive (latitude 34° 04' 24", Longitude 118° 24' 18"), thence to Ballona Creek, a water of the United States. The project location is shown on Figure 1, attached.

**FREQUENCY OF DISCHARGE**

The discharge will begin in June 2002 and will last approximately four months.

**REUSE OF WATER**

Some of the groundwater will be used during construction for activities such as dust control and soil compaction. There are no other feasible reuse options for the groundwater, therefore, majority of the groundwater will be discharged to the storm drain.