

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
EQUILON ENTERPRISES, LLC
(SHELL MORMON ISLAND MARINE TERMINAL)

NPDES NO. CAG674001
CI-8467

FACILITY ADDRESS

Shell Mormon Island Marine Terminal
167 Berth (167-168), Wilmington, California

FACILITY MAILING ADDRESS

20945 S. Wilmington Avenue
Carson, CA 90810

PROJECT DESCRIPTION:

Equilon Enterprises, LLC (Equilon) proposes to discharge hydrostatic test water from storage tanks located at the Shell Mormon Island Marine Terminal, 167 Berth (167-168), Wilmington, California. The first tank to be tested is Tank M-10. Equilon will use potable water supplied by the City of Wilmington during the hydrostatic testing.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 3.40 million gallons of hydrostatic water will be discharged to the Los Angeles Harbor (Latitude: 33° 45' 21", Longitude: 118° 16' 02") a water of the United States. The hydrotest water will be discharged directly into the Los Angeles Harbor. The discharge will occur over a period of four days at a rate of 0.85 million gallons per day. The project location map and the tank layout are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge will be continuous. Equilon expects to begin hydrostatic testing in October 2002.

REUSE OF WATER:

The reuse of hydrostatic test water at the facility was evaluated. The facility is mostly paved and has no vegetation that will utilize the water for irrigation. Because of the large volume of water to be discharged, the City of Los Angeles will not accept such discharge of clean water. Since there is no reuse alternative for the hydrostatic test water, the water will be discharged into the Los Angeles Harbor.