

**STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CITY OF SAN BUENAVENTURA
(VENTURA WATER RECLAMATION FACILITY)**

**NPDES NO. CAG994002
CI-8473**

FACILITY ADDRESS

Ventura Water Reclamation Facility
1400 Spinnaker Dr.
Ventura, CA 93001

FACILITY MAILING ADDRESS

City of San Buenaventura
PO Box 99
Ventura, CA 93002

PROJECT DESCRIPTION

The City of San Buenaventura proposes to build a new influent headworks at the City's Wastewater Treatment Plant. Groundwater will be encountered during construction, and dewatering will be necessary. It is anticipated that the untreated groundwater will meet all the permit discharge limitations and the permit screening levels; however, methods of analysis for samples taken from the site prior to permit application did not have sufficiently low detection limits to demonstrate that the permit screening levels would be met for copper. The extracted groundwater will be tested after settling and prior to discharge. If necessary, removal of metals can be accomplished by passing the groundwater through activated alumina. The facility location is depicted on the attached Figures 1 and 2.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 1,700,000 gallons per day of groundwater will be discharged into the Santa Clara River Estuary, located at Latitude: 34° 14' 11"N, Longitude: 119° 15' 25"W. The Santa Clara River is a water of the United States.

FREQUENCY OF DISCHARGE

Discharge will be continuous during construction, which is projected to last approximately 6 months.

REUSE OF WATER

There is no feasible reuse option for the groundwater at the site, therefore the groundwater will be discharged to the River.