

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013

FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
VALENCIA WATER COMPANY  
(Well No. 206)

NPDES NO. CAG994001  
CI-8476

**FACILITY ADDRESS**

Feed Mill Road  
Castaic, CA 91310

**FACILITY MAILING ADDRESS**

24631 Avenue Rockefeller  
Valencia, CA 91355

**PROJECT DESCRIPTION:**

The Valencia Water Company proposes to discharge groundwater associated with the development and conducting of pumping test, on Well No. 206, located at Feed Mill Road, Castaic. The groundwater from the project will be discharged to the Santa Clara River. A desilting tank will be installed to allow sediment to settle before discharging.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Up to 4.0 million gallons per day (mgd) of groundwater will be discharged during the short-term pumping test. The test will last for approximately 8 hours a day and will be conducted during a six week time period. The groundwater will be discharged into the Santa Clara River (Latitude: 34° 25' 39", Longitude: 118° 35' 29"), a water of the United States. The site location map is shown in Figure 1.

**FREQUENCY OF DISCHARGE:**

The discharge will be intermittent. The project is proposed to be initiated in October 2002.

**REUSE OF WATER:**

Water reuse alternatives and its applicability were evaluated. A small volume of the groundwater will be used for dust control and soil compaction within the project area. The majority of the groundwater will be discharged into Santa Clara River.