

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR**

**LOS ANGELES DEPARTMENT OF WATER AND POWER
(RIVER SUPPLY CONDUIT IMPROVEMENT PROJECT, LOWER REACH)**

**NPDES NO. CAG674001
CI-8554**

FACILITY ADDRESS

Near Crystal Springs Drive
and Western Heritage Way
Los Angeles, California

FACILITY MAILING ADDRESS

Los Angeles Department of Water and Power
111 N. Hope Street, Room 1213
Los Angeles, CA 90012

PROJECT DESCRIPTION:

The City of Los Angeles, Department of Water and Power (LADWP) proposes to discharge hydrostatic test water from River Supply Conduit Improvement Project located near Crystal Springs Drive and Western Heritage Way, Los Angeles. The hydrostatic test will be performed on a 3,600 linear feet of 78-inch diameter pipeline. LADWP will use potable water from the two water hydrants along the construction site.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 895,000 gallons of hydrostatic test water will be discharged during the testing of the River Supply Conduit Improvement Project. Groundwater will be discharged into two storm drains located at Crystal Springs Drive (Latitude: 34° 08' 45", Longitude: 118° 16' 52"), and Zoo Drive (Latitude: 34° 09' 10", Longitude: 118° 17' 12"). The discharge flows to Los Angeles River, a water of the United States. The site location map is shown in Figure 1.

FREQUENCY OF DISCHARGE:

The discharge will be continuous and will last for four days.

REUSE OF WATER:

Discharge to the sewer is not feasible because of high cost of sewer connection. Due to intermittent flow and the inability to transport the wastewater economically for reuse, the groundwater will be discharged to the storm drain.