



# California Regional Water Quality Control Board

## Los Angeles Region



Terry Tamminen  
Secretary for  
Environmental  
Protection

Over 51 Years Serving Coastal Los Angeles and Ventura Counties  
Recipient of the 2001 *Environmental Leadership Award* from Keep California Beautiful

320 W. 4th Street, Suite 200, Los Angeles, California 90013  
Phone (213) 576-6600 FAX (213) 576-6640 - Internet Address: <http://www.swrcb.ca.gov/rwqcb4>

Arnold Schwarzenegger  
Governor

December 29, 2003

Mr. Steven Dahlberg, President  
Kissel Company, Inc.  
P.O. Box 2913  
Malibu, CA 90265

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED  
CLAIM NO. 7002 2030 0006 2095 4402

Dear Mr. Dahlberg::

### **GENERAL WASTE DISCHARGE REQUIREMENTS FOR WASTE DISCHARGES TO LAND BY SMALL DOMESTIC WASTEWATER SYSTEMS – PARADISE COVE BEACH CAFÉ, 28128 PACIFIC COAST HIGHWAY, MALIBU, CALIFORNIA, (FILE NO. 02- 076)**

We have completed our review of your application for Waste Discharge Requirements for wastewater generated from the Paradise Cove Beach Café to an onsite wastewater treatment and disposal system.

Regional Board staff have reviewed the information provided and have determined that the proposed discharges meet the conditions specified in the general waste discharge requirements of the State Water Resources Control Board (State Board) Water Quality Order No. 97-10-DWQ, "*General Waste Discharges to Land by Small Domestic Wastewater Treatment Systems*", adopted by this State Board on November 18, 1997. Refer to the attached Fact Sheet.

Enclosed are your Waste Discharge Requirements, consisting of Order No. 97-10-DWQ, Monitoring and Reporting Program No. 97-10-DWQ (Attachment A), and Standard Provisions-Applicable to Waste Discharge Requirements (Attachment B), Monitoring and Reporting Program No. CI-8568 and Fact Sheet. Your discharge must not exceed the water quality objectives set in the Regional Board's Water Quality Control Plan including the objectives of the Ocean Plan. Please note that the median total coliform density in the groundwater at the site shall not exceed 70 per 100 milliliters (ml) and the geometric mean enterococcus density shall not exceed 24 organisms per 100 ml for a 30-day period. In addition the wastewater discharged shall not cause the receiving groundwater to exceed 2400 micrograms per liter of ammonia-nitrogen as the daily maximum.

The Monitoring and Reporting Program requires you to implement the monitoring program on the effective date of coverage under this permit. All monitoring reports should be sent to the Regional Board, ATTN: Information Technology Unit. Please note that the Executive Officer may require you to develop and implement a groundwater monitoring program based on the results of the technical information pertaining to your septic disposal system.

When submitting monitoring or technical reports to the Regional Board per these requirements, please include a reference to "Compliance File No. CI-8568", which will assure that the reports

**California Environmental Protection Agency**



*Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.*

Steven F. Dahlberg  
Kissel Company, Inc.  
Paradise Cove Beach Cafe

- 2 -

December 29, 2003

are directed to the appropriate file and staff. Also, please do not combine other reports with your monitoring reports. Submit each type of report as a separate document.

We are sending a copy of Order No. 97-10-DWQ with Attachments A and B only to the applicant. A copy of the Order will be furnished to anyone who requests it.

If you have any additional questions, please contact Dr. Kwangil Lee at (213) 620-2269 or Ms. Toni Callaway at (213) 620-2271.

Sincerely,

Dennis A. Dickerson  
Executive Officer

Enclosures

1. State Water Resources Control Board Water Quality Order No. 97-10-DWQ- *General Waste Discharge Requirements for Discharges to Land by Small Domestic Wastewater Treatment Systems*
  - a) Attachment A: State Water Resources Control Board Monitoring and Reporting Program
  - b) Attachment B: Standard Provisions and Reporting for Waste Discharge Requirements
2. Monitoring and Reporting Program CI No. 8568
3. Fact Sheet

cc: Mr. Michael Lauffer, Office of Chief Counsel, State Water Resources Control Board  
Mr. Robert Sams, Office of Chief Counsel, State Water Resources Control Board  
Ms. Becky Christanson, Paradise Cove Mobile Home Park, HOA  
Mr. Victor Peterson, City of Malibu

***California Environmental Protection Agency***



Recycled Paper

*Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.*