

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
MONITORING AND REPORTING PROGRAM NO. CI-8568
FOR
KISSEL COMPANY, INC.
PARADISE COVE BEACH CAFE
28128 PACIFIC COAST HIGHWAY

ENROLLMENT UNDER STATE WATER RESOURCES CONTROL BOARD
ORDER NO. 97-10-DWQ (SERIES NO. 017)
(FILE NO. 02-076)

I. REPORTING REQUIREMENTS

- A. The Kissel Company, Inc. (hereafter, the Discharger) shall implement this monitoring program and the monitoring in Attachment A (Septic Tank Monitoring) on the effective date of this enrollment (December 29, 2003) under State Board Order No. 97-10-DWQ. The first monitoring report under this program, for January - March 2004, shall be received at the Regional Board by April 15, 2004.

Monitoring reports shall be received by the dates in the following schedule:

<u>Reporting Period</u>	<u>Report Due</u>
January – March	April 15
April – June	July 15
July – September	October 15
October – December	January 15

- B. If there is no discharge, during any reporting period, the report shall so state. Monitoring reports must be addressed to the Regional Board, Attention: Information Technology Unit.
- C. By April 15th of each year, beginning April 15, 2004, the Discharger shall submit an annual summary report to the Regional Board. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous calendar year. In addition, the Discharger shall explain the compliance record and the corrective actions taken or planned, which may be needed to bring the discharge into full compliance with the waste discharge requirements (WDRs).
- D. Laboratory analyses – all chemical, bacteriological, and toxicity analyses shall be conducted at a laboratory certified for such analyses by the California Department of Health Services Environmental Laboratory Accreditation Program (ELAP). The laboratory must meet the United States Environmental Protection Agency (USEPA) Quality Assurance/Quality Control (QA/QC) criteria. Pollutants shall be

December 29, 2003

analyzed using the methods described in 40 CFR Part 136; or where no methods are specified for a given pollutant, methods approved by the Regional Board shall be utilized.

- E. The method limits (MLs) employed for effluent analyses shall be lower than the permit limits established for a given parameter, unless the Discharger can demonstrate that a particular ML is not attainable and obtains approval for a higher ML from the Regional Board Executive Officer (Executive Officer). The Discharger shall submit a list of the analytical methods employed for each test and the associated laboratory QA/QC procedures upon the request of the Regional Board.
- F. Each monitoring report must affirm in writing that "All analyses were conducted at a laboratory certified for such analyses by the California Department of Health Services, and in accordance with current USEPA guideline procedures or as specified in this Monitoring Program." Proper chain of custody procedures must be followed and a copy of the chain of custody shall be submitted with the report.
- G. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses any items where the discharge limitations were not met. The Discharger shall include a statement about the cause(s) of non-compliance and the corrective actions taken or planned that may be needed to bring the discharge into full compliance with WDRs. This section shall be located at the front of the report and shall clearly list all non-compliance with WDRs, as well as all excursions of effluent limitations.
- H. The Discharger shall maintain all sampling and analytical results, including strip charts; date; exact place, and time of sampling; dates analyses were performed; analyst's name; analytical techniques used; and results of all analyses. Such records shall be retained for a minimum of three years. This period of retention shall be extended during the course of any unresolved litigation regarding this discharge, or when requested by the Regional Board.
- I. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized to demonstrate compliance with the requirements and, where applicable, shall include results of receiving water observations.
- J. Any mitigation/remedial activity including any pre-discharge treatment conducted at the site must be reported in the quarterly monitoring report.

II. WASTEWATER TREATMENT AND DISPOSAL SYSTEM MONITORING REQUIREMENTS

- A. Maintenance reporting: The Discharger shall annually submit an operation and maintenance report for the wastewater treatment system: The information to be contained in the report shall include, at a minimum, the following:
1. The name and address of the person or company responsible for the operation and maintenance of the facility;
 2. Type of maintenance(preventive or corrective action performed);
 3. Frequency of maintenance, if preventive;
 4. Any pumping required of the septic disposal system; and
 5. Maintenance records for the septic disposal system and/or wastewater treatment plant.
- B. Influent monitoring reports shall measure the monthly average and daily maximum wastewater flow from the collection system to the treatment system.
- C. An effluent sampling station shall be established at a location where representative samples of treated effluent can be obtained prior to discharge to the seepage pit and/or leachfield disposal/subsurface drip irrigation system. Monitoring shall be conducted as described in the table below. The following shall constitute the effluent monitoring program:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Analysis</u>
Total flow	gal/day	recorder	continual
pH	pH units	grab	quarterly
Total suspended solids	mg/L	grab	quarterly
BOD ₅ 20°C	mg/L	grab	quarterly
Total Nitrogen ^[1]	mg/L	grab	quarterly
Nitrate-nitrogen	mg/L	grab	quarterly
Nitrite-nitrogen	mg/L	grab	quarterly
Total dissolved solids	mg/L	grab	quarterly

^[1] Nitrate + Nitrite + ammonia + organic nitrogen as nitrogen

III. GROUNDWATER MONITORING PROGRAM

- A. On September 9, 2001, a groundwater monitoring network for both the Beach Café and the Paradise Cove Mobile Home Park was approved by the Regional Board Executive Officer (Executive Officer). After relocation of the WWTP and wastewater disposal area, additional wells were needed to fully evaluate impacts from the wastewater treatment and disposal system.

A proposal for additional groundwater monitoring wells was submitted to this Regional Board on June 11, 2002. On January 13, 2003 additional groundwater monitoring wells MW-11, MW-12, and MW-13, located closer to the wastewater treatment plant and associated disposal area, were installed. These three wells in addition to the original six well monitoring network are sufficient to satisfy the groundwater monitoring program requirement to fully evaluate the impact from the Beach Café's treated wastewater discharge on the local groundwater which ultimately discharges to the Pacific Ocean.

This groundwater monitoring program may be subject to revision after completion of the first year of baseline water quality monitoring.

- B. The following shall constitute the groundwater monitoring program:

<u>Constituent</u>	<u>Units*</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Analysis</u>
pH	pH Units	grab	quarterly
Total coliform	MPN/100mL	grab	quarterly
Fecal coliform	MPN/100mL	grab	quarterly
Enterococcus	MPN/100mL	grab	quarterly
Ammonia-N	mg/L	grab	quarterly
Nitrate-N	mg/L	grab	quarterly
Nitrite-N	mg/L	grab	quarterly
Organic nitrogen	mg/L	grab	quarterly
Total nitrogen	mg/L	grab	quarterly
Total dissolved solids	mg/L	grab	quarterly
Sulfate	mg/L	grab	quarterly
Chloride	mg/L	grab	quarterly
Boron	mg/L	grab	quarterly

* MPN/100mL: Most Probable Number per 100 milliliter; mg/L: milligrams per liter

All groundwater monitoring reports must include, at minimum, the following:

- a. Well identification, date and time of sampling;
- b. Sampler identification, and laboratory identification;

- c. Quarterly measurement of groundwater levels, recorded to 0.01 feet mean sea level; and
- d. Groundwater contour map depicting the hydraulic gradient and direction of groundwater flow across the subject tract.

IV. WASTE HAULING REPORTING

In the event that waste sludge, septage, or other wastes are hauled offsite, the name and address of the hauler shall be reported, along with types and quantities hauled during the reporting period and the location of final point of disposal. In the event that no wastes are hauled during the reporting period, a statement to that effect shall be submitted.

V. MONITORING FREQUENCIES

Specifications in this monitoring program are subject to periodic revisions. Monitoring requirements may be modified or revised by the Executive Officer based on review of monitoring data submitted pursuant to this Order. Monitoring frequencies may be adjusted to a less frequent basis or parameters and locations dropped by the Executive Officer if the Discharger makes a request and the request is backed by statistical trends of monitoring data submitted.

VI. CERTIFICATION STATEMENT

Each report shall contain the following completed declaration:

"I certify under penalty of law that this document, including all attachments and supplemental information, was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment.

Executed on the _____ day of _____ at _____.


(Signature)

(Title)"

Paradise Cove Beach Cafe
Monitoring and Reporting Program No. CI-8568

File No. 02-076

These records and reports are public documents and shall be made available for inspection during normal business hours at the office of the California Regional Water Quality Control Board, Los Angeles Region.

Ordered by: 
Dennis A. Dickerson
Executive Officer

Date: December 29, 2003