

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
SHELL OIL PRODUCTS US
(EQUILON MARINE TERMINAL)

NPDES NO. CAG674001
CI-8597

FACILITY ADDRESS

Pier B, Berth 84
Long Beach, CA

FACILITY MAILING ADDRESS

P.O. Box 817
Wilmington, CA 90748

PROJECT DESCRIPTION:

Shell Oil Products US (Shell Oil) discharges hydrostatic test water from the testing of aboveground storage tanks at their facility located at Pier B, Berth 84, Long Beach. A total of six aboveground tanks exist at the facility (Tank Nos. 1400, 35001, 35002, 35003, 55001, and 80099). In addition, Shell Oil proposes to discharge hydrostatic test water from newly constructed aboveground storage tanks associated with the Shell Equilon Marine Terminal, under this General NPDES permit. Shell Oil uses potable water supplied by the City of Long Beach Water Department to conduct hydrostatic testing of the storage tanks and pipelines at the facility.

VOLUME AND DESCRIPTION OF DISCHARGE:

Approximately 500,000 gallons per day (mgd) of hydrostatic test water will be discharged to Channel No. 2 (Latitude: 33° 46' 20", Longitude: 118° 13' 18"). The discharge from this Channel, flows into Long Beach Inner Harbor, a water of the United States. The facility location and site plan are shown in Figures 1 and 2.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided, the analytical data did not show reasonable potential for toxics to exist in hydrostatic test wastewater above the Screening Levels for *Potential Pollutants of Concern in Potable Water Used for Hydrostatic Testing in Attachment A*. In addition, the source of hydrostatic test water is from a potable water supply system that complies with the Department of Health Services Maximum Contaminant Levels for drinking water. The discharge flows into the Long Beach Inner Harbor. Therefore, the effluent limitations in Attachment B are not applicable to your discharge.

November 9, 2004

This Table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settable Solids	ml/L	0.3	0.1
Residual Chlorine	mg/L	0.1	

FREQUENCY OF DISCHARGE:

The discharge will be intermittent.

REUSE OF WATER:

Reuse of water at the facility for irrigation and dust control was evaluated, and found to be infeasible at the site. Therefore, the hydrostatic test water will be discharged into the Long Beach Inner Harbor.