

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
DEPARTMENT OF WATER AND POWER
CITY OF LOS ANGELES
(SUNSET & BARRINGTON REGULATOR STATION)**

**NPDES NO. CAG914001
CI-8623**

FACILITY ADDRESS

Sunset Blvd. & Barrington Place
Los Angeles, California

FACILITY MAILING ADDRESS

111 N. Hope St., Room 1213
Los Angeles, CA 90012

PROJECT DESCRIPTION:

The City of Los Angeles, Department of Water and Power (LADWP) proposes to discharge hydrostatic test water from a new water supply line project located near Sunset Boulevard and Barrington Place in the City of Los Angeles. The hydrostatic test will be performed on a 36-inch diameter cement mortar-lined steel pipe that is approximately 680 feet in length. LADWP will use potable water from an adjacent trunkline for the hydrostatic testing.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 55,000 gallons of hydrostatic test water will be discharged to a catch basin located approximately 200 feet east of Barrington Place on Sunset Boulevard. (Latitude: 34° 03' 59", Longitude: 118° 28' 05"). The discharge flows to Ballona Creek, a water of the United States. The project location map is shown in Figure 1.

FREQUENCY OF DISCHARGE:

The groundwater will be discharged over a 1 to 2 day period.

REUSE OF WATER:

Reuse of water at the facility for irrigation and dust control were evaluated. Due to intermittent flow and the inability to reuse the testing water economically, the wastewater will be discharged to the storm drain.