

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
EXXONMOBIL CORPORATION
(FORMER EXXON STATION 7-2827)**

**NPDES NO. CAG834001
CI-8663**

FACILITY ADDRESS

305 Carmen Drive
Camarillo, California 93010

FACILITY MAILING ADDRESS

121 E. Birch Avenue, Suite 7-2827
Flagstaff, AZ 86001

PROJECT DESCRIPTION:

ExxonMobil Corporation proposes to discharge wastewater from the groundwater cleanup project at 305 Carmen Drive, Camarillo, California. Groundwater beneath the site is impacted with petroleum-fuel. Prior to discharge, the extracted groundwater will be treated by passing it through two 2,000-lbs carbon absorption vessels containing granular activated carbon (GAC).

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 28,800 gallons per day of treated groundwater will be discharged into a storm drain located along Carmen Drive and Daily Avenue (Latitude: 34° 06' 20", Longitude: 119° 05' 35"). The discharge from the storm drain flows into Camarillo Hills Drain, thence into the Mugu Lagoon, a water of the United States. The site location map and process flow diagram are shown in Figures 1 and 2, respectively.

FREQUENCY OF DISCHARGE:

The discharge of treated groundwater will be intermittent.

REUSE OF WATER:

Offsite disposal of treated waste is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation. Since there are no feasible reuse options, the groundwater will be discharged to the storm drain.